



City of Seattle

# STANDARD PLANS FOR MUNICIPAL CONSTRUCTION

2005 EDITION






**CITY OF SEATTLE**  
2005 edition  
**STANDARD PLANS**  
**FOR**  
**MUNICIPAL CONSTRUCTION**

Prepared by  
Seattle Public Utilities  
Chuck Clarke, Director


**Reviewed and Approved by**

  
Tom Tanner  
Seattle Public Utilities

11/09/04  
Date


  
Dana Backiel  
City Light

11/09/04  
Date

  
Richard Miller  
Seattle Transportation


Date

11/23/04


  
Jim Ishihara  
Parks and Recreation

Date

11/18/04


  
Dove Alberg  
Fleets & Facilities

11-22-04  
Date

  
Shelly Yapp  
Seattle Center

11/23/04  
Date

**Adopted by**

  
Linneth Riley-Hall  
Department of Executive Administration

11/23/04  
Date

**Distributed by**

Seattle Public Utilities  
700 - 5<sup>th</sup> Avenue  
Suite 4700  
Seattle, Washington 98104  
206-684-5944

**This page left intentionally blank.**

# 2005 edition City of Seattle Standard Plans for Municipal Construction

## PREFACE

The 2005 edition City of Seattle Standard Plans for Municipal Construction (henceforth referred to as the "2005 Standard Plans") have been prepared by Seattle Public Utilities in cooperation with Seattle Department of Transportation, Seattle Parks and Recreation, Department of Executive Administration, Seattle City Light, Seattle Center, and Fleets and Facilities. This document was compiled by combining the 2003 Standard Plans with supplemental Special Provision Plans, and then revising or supplementing the resulting whole to reflect and be consistent with the 2005 edition City of Seattle Standard Specifications for Road, Bridge, and Municipal Construction (henceforth known as the "2005 Standard Specifications").

The 2005 Standard Plans apply whenever any public or private construction is performed within the Rights-of-Way of the City of Seattle including work performed by private parties at their own expense under authority granted by ordinance of the City Council or by permit of the SDOT Street Use section, and are to be used in conjunction with the 2005 Standard Specifications. Each 2005 Standard Plan has a reference to the applicable 2005 Standard Specification section(s).

For the convenience of our users, 2005 Standard Plans that are new or have been revised from the 2003 edition Standard Plans are identified in the Table of Contents with a vertical bar as shown herein. In the upper right corner of new and revised Standard Plans, "Rev Date: 2005" indicates the Standard Plan is revised from the 2003 edition, and "Date: 2005" indicated the Standard Plan is new.

Despite considerable efforts to produce 1) a completely error-free document, 2) a document consistent with the 2005 Standard Specifications, 3) a web version of this document, and 4) a pdf file compact disc version of this document, some mistakes and inconsistencies seem to defy detection until after publication. Should you discover errors in this document or inconsistencies between or among the versions, please bring them to our attention by using the "comment" feature at <http://www.seattle.gov/util/engineering>.

Should conflict be discovered between this hard copy version 2005 Standard Plans and any other version 2005 Standard Plans, these hard copy 2005 Standard Plans shall take precedence over all other versions 2005 Standard Plans. Should conflict be discovered between any version of the 2005 Standard Plans and the hard copy 2005 Standard Specifications, the hard copy 2005 Standard Specifications shall take precedence over all versions of the 2005 Standard Plans.

My sincere thanks and appreciation to all those individuals in the many City Departments who participated in the effort of providing input, discussing, and reviewing this document, and to the many City Departments for agreeing on standardizing similar constructions. Additional thanks to members of Seattle Public Utilities Technical Resources section for drafting the individual 2005 Standard Plans and preparing both the hard copy and pdf file compact disc versions, and to the Seattle Public Utilities Information Technology section for preparing the web version of the 2005 Standard Plans.

The hardcopy version and a pdf file compact disc version of this document are available at Seattle Public Utilities, The Vault, Suite 4700, 700 Fifth Avenue, Seattle, Washington 98104, 206-684-5132. The web version of this document can be found at the City of Seattle web-site "<http://www.seattle.gov/util/engineering>".

This Preface is for informational purposes only and is not to be used to interpret or affect the terms of the Contract between The City of Seattle as the Contracting Agency and the Contractor.

Brian Patton, P.E.  
Director, Engineering Support  
Seattle Public Utilities



# 2005 edition City of Seattle Standard Plans for Municipal Construction

## 000 General/Legal/Miscellaneous

Datum	Elevations & Datums	001
Abbreviations	Abbreviations	002
Standard Symbols	Electrical	003a
	Electrical	003b
	Electrical	003c
	Electrical	003d
	Signalization / Channelization & Signage	003e
	Paving	003f
	Sewer & Drainage	003g
	Sewer & Drainage	003h
	Topographic & Misc	003i
	Topographic & Misc	003j
	Topographic & Misc	003k
	Topographic & Misc	003l
	Private Utilities	003m
	Water	003n
	Water	003o
Payment	Sewer/Drainage Measurement Diagram	010
Monument	Monument Frame & Cover	020
Miscellaneous	Standard Locations for Utilities (Residential Street)	030

## 100 Landscape Planting

Trees	Deciduous Tree Planting in Planting Strip	100a
	Tree & Shrub Planting on Slopes	100b
	Coniferous Tree Planting	101
Shrub & Ground Cover	Shrub Planting	110
	Ground Cover Planting	111
	Planting Pattern	112
	Median Planting	113
Irrigation	Hose Bib Assembly & Quick Coupler Valve	121
	Irrigation Valves	122
	Irrigation Valves	123
	Irrigation Valves	124
	Irrigation Valves	125
	Pop Up & Fixed Irrigation Heads	126
	Irrigation Controller Pedestal & Enclosure Grounding	127
	Irrigation Trenches	128
	Irrigation Controller Cabinet	129
Tree Protection	Tree Protection During Construction	132
	Tree Protection During Trenching, Tunneling or Excavation	133
	Construction Around Existing Trees	134
Grading	Slope Rounding	140
	Rock Facing	141

# 2005 edition City of Seattle Standard Plans for Municipal Construction

## 200 Sewer/Drainage Appurtenances

Manholes	Type 200 Manhole	200a	
	Type 200 Manhole Top & Bottom Slabs	200b	
	Type 201 Manhole	201a	
	Type 201 Manhole Top & Bottom Slabs	201b	
	Type 202 Manhole	202a	
	Type 202 Manhole Top & Bottom Slabs	202b	
	Type 203 Manhole	203a	
	Type 203 Manhole Top & Bottom Slabs	203b	
	Type 204 Manhole	204a	
	Type 204 Manhole Top & Bottom Slabs	204b	
	Type 205 Manhole	205a	
	Type 205 Manhole Top & Bottom Slabs	205b	
	Type 206 Manhole	206a	
	Type 206 Manhole Top & Bottom Slabs	206b	
	Type 207 Manhole	207	
	Rebuild Existing Brick Manhole	208	
Materials	2'-0" Diameter Frame & Cover	230	
	Frame Extensions	231	
	Manhole Ladder Step & Handhold	232	
	Outside Drop Connection	233a	
	Inside Drop Connection	233b	
	6" or 8" Vertical Connection	234	
Catch Basins	Type 240 Catch Basin	240	
	Type 241 Catch Basin	241a	
	Type 241 Catch Basin Installations	241b	
	Type 242 Catch Basin	242	
	Precast Catch Basin Top Slab	243a	
	Precast Catch Basin Extension Risers	243b	
Inlets	Type 250 Inlet	250	
	Type 252 Inlet	252	
	Inlet/Catch Basin Location & Installation	260a	
	Catch Basin & Inlet Installation	260b	
	Typical Catch Basin Connection	261	
	Type 262 Inlet Frame	262	
	Type 263 Inlet Frame	263	
	Inlet Frame & Grate	264	
	Vaned Grate	265	
	Outlet Trap	267a	
	Outlet Trap (for DOPAR use only)	267b	
	Extension for Inlet	268	
Flow Control	Flow Control Structure	270	
	Detention Structure End Plate Details	271a	
	Detention Structure End Plate Details	271b	
	Detention Structure End Plate Details	271c	
	Flow Control Structure (Conc or DIP Detention Pipe)	272a	
	PVC Shear Gate	272b	
	Type 277 Junction Box & Installation	277	
	Vertical Clean Out/Corrugated Metal Pipe	278	



## 2005 edition City of Seattle Standard Plans for Municipal Construction

Pipe Installation	Tee Installation Corrugated Metal Pipe	279	
	8" Clean Out	280	
	Corrugated Metal Pipe Coupling Bands	282a	
	Corrugated Metal Pipe Coupling Bands	282b	
	Side Sewer Installation	283	
	Typical Sewer Trench Section	284	
	Pipe Bedding Sewer/Storm Drain	285	
Clearance Plans	Sewer & Water Spacing & Clearances	286a	
	Sewer & Water Spacing & Clearances	286b	
Drains	Bridge Drain	290	
	Subsurface Drain Pipe	291	

### **300 Watermain Appurtenances**

Pipe Connections	Connections to Existing Watermains	300a	
	Connections to Existing Watermains	300b	
	Connections to Existing Watermains	300c	
Hydrants	Type 310 Hydrant Setting Detail	310a	
	Type 310 Hydrant Setting Detail	310b	
	Type 311 Hydrant Setting Detail	311a	
	Type 311 Hydrant Setting Detail	311b	
	Fire Hydrant Marker Layout	312	
	Wall Requirements for Hydrants	313	
	Fire hydrant Locations & Clearances	314	
Valves	Cast Iron Valve Box & Operating Nut Extension	315a	
	Cast Iron Valve Box & Operating Nut Extension	315b	
Concrete Blocking	Watermain Thrust Blocking Vertical Fittings	330a	
	Watermain Thrust Blocking Vertical Fittings	330b	
	Watermain Thrust Blocking Horizontal Fittings	331a	
	Watermain Thrust Blocking Horizontal Fittings	331b	
Blow Off	2" Blow Off Type A Non Traffic Installation	340a	
	2" Blow Off Detail Type B Traffic Installation	340b	
Pipe Bedding	Watermain Trench and Bedding	350	
Miscellaneous	Watermain Electrolysis Test Station	360	
	Type 361 Valve Chamber Frame & Cover	361	
	Joint Bonding for DIP Watermains & Joint Bonding Detail	362	
	Electrolysis Test Station Wire Installation Details	363	

### **400 Street Paving & Appurtenances**

Paving	Half Section, Grading	400	
	Residential Pavement Sections	401	
	Commercial and Arterial Pavement Sections	402	
	Cement Concrete Alley Pavements	403	
	Pavement Patching	404a	
	Pavement Patching	404b	
	Types of Joints for Concrete Pavement	405	

## 2005 edition City of Seattle Standard Plans for Municipal Construction

Curbs	Type 410 Curb	410
	Curb Joints & Dowels	411
	Extruded Curb	412
	Traffic Curb Precast Cement Concrete 3' and 4' sections	413a
	Traffic Curb Precast Cement Concrete 8' section and Radial	413b
	Traffic Curbs Block Precast Cement Concrete	414
	Traffic Circle Details	415
	Sidewalks	Concrete Sidewalk Details
Sidewalk with Monolithic Curb		421
Curb Ramp Details		422a
Curb Ramp Details		422b
Bus Shelter Footing		423
Tree Pit Detail		424
Driveways		Type 430 Driveway
	Concrete Driveway Placed with Sidewalk Construction	431
Stairway, Steps	Cement Concrete Stairway & Handrail	440a
	Cement Concrete Stairway & Handrail	440b
	Cement Concrete Steps	441
	Steel Pipe Handrail	442
	Steel Pipe Railing for Bike Path	443a
	Steel Pipe Railing for Bike Path	443b
Fence	Chain Link Fence	450a
	Chain Link Fence	450b
	Chain Link Gate	450c
Miscellaneous	Temporary Pedestrian Walkway	456
	Ecology Block, Concrete	460
	Fixed & Removable Wood Bollard	463

### 500 Signalization/Lighting

Signal Controller	Signal Controller Cabinet & Foundation	500a
	Signal Controller Foundation Conduit Layout	500b
	Signalized Intersection Span Wire Type Configuration	502
	Signal & Lighting Service Connection & Light Pole Wiring Detail	505a
	Signal & Lighting Service Connection & Light Pole Wiring Detail	505b
Vehicular Signal	Vehicular Signal Mounting	510a
	Vehicular Signal Mounting	510b
	Signal Bracket Assembly	511
Pedestrian Signal	Pedestrian Signal Clamshell Mounting	520
	Pedestrian Pushbutton Post & Foundation	521
	Pedestrian Pushbutton & Mounting	522
	Pedestrian Signal & Pushbutton Mounted on Wood Pole	523
	Pedestal & Foundation	524a
	Pedestal	524b
Loop Detectors	Loop Detectors	530a
	Detector Loop Wire & Signal Cable Splice	530b



## 2005 edition City of Seattle Standard Plans for Municipal Construction

Pole Foundations	Strain Pole Foundation Detail (Type T, V, X & Z)	541a
	Strain Pole Foundation	
	Schedule / Notes (Type T, V, X & Z)	541b
	Chief Seattle Base (CSB)	542a
	Chief Seattle Street Light Pole Foundation	542b
	Street Light Pole Foundations	543
Handholes	Handholes	550a
	Handholes	550b
Poles	Wood Strain Poles	560
	Steel Mast Arm Pole	562a
	Foundation Schedule & Detail	
	(w/o METRO Trolley Loads)	562b
	Miscellaneous Steel Pole Details	563a
	<i>Miscellaneous Steel Pole Details</i>	563b
	Combined Use METRO Strain Pole Details	
	(Type V, X, & Z Poles)	566a
	Combined Use METRO Strain Pole Details	
	(Type V, X, & Z Poles)	566b
	Type T Strain Pole Details Traffic Signal Only	567a
	Type T Strain Pole Details Traffic Signal Only	567b
	Pole Band	569
Bracket Arms	Steel Street Light Pole with Bracket Arm	572
Conduit Risers	Conduit Risers	580

### 600 Signs

Overhead	Span Wire Installation	601a
	Overhead Wood Signs Span Wire Mounted	601b
	Sign Installation (Non-Spanwire Mounting)	601c
Pole Mounted	Standard Sign Installation Steel Poles	610
	SDS Bracket for Steel Mast Arm Poles	612
	SDS Bracket for Steel or Wood Poles	613
	SNS Bracket for Steel Poles	615
	Traffic Sign Mounting on Metal Poles	616
Post Mounted	Stop and Yield Sign	
	Wood Post and Anchor Installation	620
	Warning and Regulatory Sign Post	621a
	Warning and Regulatory Sign Post	
	Anchor Installation	621b
	Street Name Sign Installation	622
	Street Name Sign Pedestal Installation	623
	Post Cap	624
	Traffic Sign Posts	625
	Object Marker Installation	626
	Parking Meter Post & Accessories	627
	Surface Mount Meter Post Installation Detail	628
	Direct Burial Meter Post Installation Detail	629

## 2005 edition City of Seattle Standard Plans for Municipal Construction

Metro Bus Zone Sign Installation	630
----------------------------------	-----

### **700 Pavement Markings**


Traffic Buttons / Lane Markers	Traffic Buttons / Lane Markers	700
Channelization	Channelization Standard	710
	Typical Left Turn Channelization and Legend Placement	711
	Typical Crosswalk & Stop Line Installation Details	712
	Curb Space Marking Details	713
Legends / Symbols	Pavement Markings Legends / Symbols	720a
	Pavement Markings Legends / Symbols	720b
	Pavement Markings Legends / Symbols	721
	Bicyclist & Pedestrian Symbols	722
	Pavement Markings Legends / Symbols	723

### **800 Structures**

Walls	Support Wall	800
	Curb Wall	801



**This page left intentionally blank.**



City of Seattle

NOT TO SCALE

ELEVATIONS & DATUMS

ABAN	Abandon(ed)
ABW	Asphalt Bike Way
ACV	Automatic Control Valve
ACP	Asphalt Concrete Pavement
ADA	Americans with Disabilities Act
ADJ	Adjust
AHD	Ahead
AIC	Aerial Interconnect Cable
AL	Aluminum
AP	Angle Point
APP	Approved
APPROX	Approximate
APWA	American Public Works Association
ASPH	Asphalt
ATB	Asphalt Treated Base
AV	Air Valve
AVB	Automatic Vacuum Breaker
AVE	Avenue
AVG	Average
AW	Asphalt Walk
AWG	American Wire Gage
AWWA	American Water Works Assoc.
B&B	Ball & Burlap
BC	Bolt Circle, Back of Curb
BF	Bottom Face
BFV	Butterfly Valve
BK	Back
BLDG	Building
BLK	Block
BLKG	Blocking
BLKHD	Bulkhead
BLRD	Bollard

BLVD	Boulevard
BM	Bench Mark
BO	Blow Off
BOC	Beginning of Curb
BPD	Backflow Prevention Device
BR	Bare Root, Brick
BRG	Bearing
BRKN	Broken
BSMT	Basement
BTW	Between
BV	Ball Valve
BVC	Beginning of Vertical Curve
C&G	Curb & Gutter
CAL	Caliper
CB	Cable, Catch Basin
CBW	Concrete Bike Way
C—C	Center to Center
CC	Concrete Culvert
CD	Conduit
CDF	Controlled Density Fill
CEM	Cement
CF	Cubic Feet
CH	Chamber
CIP	Cast Iron Pipe
CL	Center Line or Class
℄	Center Line
CLF	Chain Link Fence
CLR	Clearance
CMP	Corrugated Metal Pipe
CO	Clean Out
COMP	Compression
CONC	Concrete

REF STD SPEC SEC 1-01.2



City of Seattle

NOT TO SCALE

ABBREVIATIONS

COND	Condition
CONN	Connect/Connection
CONSTR	Construction
CONT	Continuous
CORP	Corporation
CR	Cross, Curb Radius
CSB	Chief Seattle Base
CULV	Culvert
CW	Concrete Walk
CY	Cubic Yard
DB	Direct Burial Cable
DC	Direct Current
DCVA	Double Check Valve Assembly
DEPT	Department
DGV	District Gate Valve
DIA $\phi$	Diameter
DIP	Ductile Iron Pipe
DIPRA	Ductile Iron Pipe Research Assoc.
DR	Drive
DS	Downspout
DWG	Drawing
DWY	Driveway
E	East
EA	Each
ECB	Electrical Cable
ECC	Eccentric
ECD	Electrical Conduit
ED	Electrical Duct
EL/ELEV	Elevation
ELEC	Electric/Electrical
EMH	Electrical Manhole
ENCL	Enclosure

ENGR	Engineer
EOC	End of Curb
EQ	Equal
ESMT	Easement
EV	Electrical Vault
EVC	End of Vertical Curve
EW	Each Way
EX	Existing
EXP	Expansion
FACB	Fire Alarm Cable
FAHH	Fire Alarm Handhole
FC	Face of Curb
FCS	Flow Control Structure
FDN	Foundation
FF	Far Face, Finished Floor
FIG	Figure
FIPT	Female Iron Pipe Thread
FLG	Flange
FLR	Floor
FLT	Flat Bar
FM	Force Main
FO	Fiber Optics
FS	Far Side
FT	Feet
FTG	Footing
G	Gas
G REG	Gas Regulator
GA	Gauge
GAL	Gallon
GALV	Galvanize/Galvanized
GAS V	Gas Valve
GFCI	Ground Fault Circuit Interrupter

REF STD SPEC SEC 1-01.2




City of Seattle

NOT TO SCALE

ABBREVIATIONS

GIP	Galvanized Iron Pipe
GM	Gas Meter
GND	Ground
GP	Guy Pole
GPM	Gallons Per Minute
GR	Grade
GRHH	Ground Rod Handhole
GSP	Galvanized Steel Pipe
GV	Gate Valve
GVC	Gate Valve Chamber
GVL	Gravel
HB	Horizontal Bend
HEX	Hexagon/Hexagonal
HGL	Hydraulic Grade Line
HH	Handhole
HI	High
HORIZ	Horizontal
HPG	High Pressure Gas
HPS	High Pressure Sodium
HR	Hour
HSE	House
HYD	Hydrant
ID	Inside Diameter/Dimension
IE	Invert Elevation
IF	Inside Face
IN	Inch(es)
INL	Inlet
INT	Intersection
INV	Invert (Line)
IP(S)	Iron Pipe (Size)
IRC	Irrigation Controller
IRRG	Irrigation

ISO	Isolation Coupling
JB	Junction Box
JT	Joint
KV	Kilovolt
LAL	Limited Access Line
LBS	Pounds
LF	Lineal Feet
LID	Local Improvement District
LIT	Large Inlet Top (Catch Basin)
LOC	Locate/Location
LONGIT	Longitudinal
LP	Light Pole
LS	Lump Sum
LSCAPE	Landscape, Landscaping
LT	Left
LUM	Luminaire
MA	Mast Arm
MAX	Maximum
MCV	Manual Control Valve
MDV	Manual Drain Valve
MH	Manhole
MIC	Monument in Case
MIN	Minimum
MIPT	Male Iron Pipe Thread
MISC	Miscellaneous
MJ	Mechanical Joint
ML 	Monument Line
MNRL AGG	Mineral Aggregate
MOD	Modify/Modified
MON	Monument
MW	Monitor Well
N	North

REF STD SPEC SEC 1-01.2



City of Seattle

NOT TO SCALE

ABBREVIATIONS



NAD	North American Datum
NAVD	North American Vertical Datum
NF	Near Face
NGVD	National Geodetic Vertical Datum
NIC	Not In Contract
NO	Number
NOM	Nominal
NS	Near Side
NTS	Not To Scale
OC	On Center
OD	Outside Diameter/Dimension
OF	Outside Face
OH	Overhead
PAV	Pavement
PC	Point of Curvature
PCC	Point of Compound Curve
PDP	Perforated Drain Pipe
PE	Plain End
PED	Pedestrian
PH	Phase
PI	Point of Intersection
PL	Plate, Place
ℙ	Property Line
POC	Point on Curve
PP	Power Pole
PPB	Pedestrian Push Button
PR	Pair
PRC	Point of Reverse Curve
PROP	Proposed
PRKG	Parking
PRV	Pressure Reducing Valve
PS	Pipe Sewer Combined

PSD	Pipe Storm Drain
PSDD	Pipe Storm Drain Detention
PSI	Pounds per Square Inch
PSIA	Pounds per Square Inch Absolute
PSIG	Pounds per Square Inch Gauge
PSS	Pipe Sewer Sanitary
PT	Point of Tangency
PVB	Pressure Vacuum Breaker
PVC	Polyvinyl Chloride
PVT	Private
QTY	Quantity
R	Radius
R&R	Remove & Replace
R/W	Right of Way
RCP	Reinforced Concrete Pipe
RD	Roof Drain
RDWY	Roadway
RECONN	Reconnect
RED	Reducer
REF	Refer/Reference
REINF	Reinforcing/Reinforcement
RELOC	Relocate
REM	Remove
REPL	Replace
REQD	Required
RET	Retire/Retired
RET WALL	Retaining Wall
RF	Rock Facing
RGS	Rigid Galvanized Steel
RIT	Round Inlet Top
RLWY	Railway
RP	Rock Pocket

REF STD SPEC SEC 1-01.2



City of Seattle

NOT TO SCALE

ABBREVIATIONS

RPBA	Reduced Pressure Backflow Assembly
RR	Railroad
RS	Rigid Steel
RT	Right
S	South
SB	Sandbox
SCH	Schedule
SCL	Seattle City Light
SDS	Street Designation sign
SD	Service Drain
SDOT	Seattle Department of Transportation
SEC	Section
SHLD	Shield
SHT	Sheet
SL	Sleeve, Street Light
ℒ	Survey Line
SLHH	Street Light Handhole
SNS	Street Name Sign
SP	Strain Pole
SPCS	Spaces
SPEC	Specifications
SPU	Seattle Public Utilities
SQ	Square
SS	Stainless Steel, Side Sewer—Combined
SSD	Sub—Surface Drain
SSS	Side Sewer – Sanitary
SSTONE	Sandstone
ST	Street
STA	Station
STD	Standard
STL	Steel
STL P	Steel Pipe

STM LOG	Steam Log
STRUCT	Structure/Structural
SY	Square Yard
SYS	System
T	Tee
TB	Test Boring
TC	Traffic Control
TCB	Telephone Cable
TCD	Telephone Conduit
TCHH	Traffic Control Handhole
TD	Telephone Duct
TEB	Telephone Enclosure Box
TEL	Telephone
TEMP	Temporary
TF	Top Face
TH	Test Hole
THH	Telephone Handhole
TJO	Transfer of Jurisdiction Ordinance
TMH	Telephone Manhole
TN	Ton
TR	Traffic
TRCB	Traffic Signal Cable
TRCD	Traffic Signal Conduit
TRSCC	Traffic Signal Controller Cabinet
TVCB	Television Cable
TVHH	Television Handhole
TYP	Typical
UG	Underground
UIC	Underground Interconnect
UNC	Unified National Coarse
UP	Utility Pole
V	Valve, Variable

REF STD SPEC SEC 1-01.2



City of Seattle

NOT TO SCALE

ABBREVIATIONS

V/C	Vertical Curve
VAR	Variable/Varies
VB	Vertical Bend
VBOX	Valve Box
VCH	Valve Chamber
VEH	Vehicle
VERT	Vertical
VMS	Variable Message Sign
VO	Vacation Ordinance
W	Water, West
W/	With
WCR	Wheel Chair Ramp
WD	Wood/Wooden
WIF	Wrought Iron Fence
WM	Water Meter, Water Main
WMR	Water Main Radius
WP	Wood Pole
WSP	Wood Stave Pipe
WU	Western Union
WV	Water Valve
WWF	Welded Wire Fabric
XP	Transmission Pole











REF STD SPEC SEC 1-01.2



City of Seattle

NOT TO SCALE

ABBREVIATIONS


















ITEM	EXISTING	LINE WEIGHT	PROPOSED	LINE WEIGHT	CAD NOTES
Signal Controller Cabinet		.014		.020	ECAB PCABII or PCABIII draw to size
Electrical Vault		.014		.020	EVault / PEV draw to size
Electrical Cable (direct burial)	ECB	.014	ECB	.024	LT=ECd 6-1-1-1
Electrical Conduit	1" ECD	.014	1" ECD	.024	LT=ECd 6-1-1-1
Electrical Duct	12" X 12" ED	.014	12" X 12" ED	.024	LT=ECd 6-1-1-1
Combined Electrical & Telephone Duct	12" X 12" ED-TD	.014	12" X 12" ED-TD	.024	LT=ECd 6-1-1-1
Span Wire		.014		.024	
Aerial Interconnect Cable	AIC	.014	AIC	.024	
Transmission Pole (steel w/ conc base)	XP 	.014		.024	EXP PXP
City Wood Pole	PP 	.014		.024	EPP PWP
City Wood Pole w/ HPS	PP 	.014		.024	EPPLT PWP+PBARM+PLUM



City of Seattle

NOT TO SCALE

STANDARD SYMBOLS  
ELECTRICAL

ITEM	EXISTING	LINE WEIGHT	PROPOSED	LINE WEIGHT	CAD NOTES
Light Pole (metal) w/ HPS	LP 	.014		.024	ELP PLP+PBARM+PLUM
Strain Pole (metal)		.014			ESP/PSP
Combined Lighting Strain Pole HPS		.014		.024	ESPLT PSP+PBARM+PLUM
Luminaire		.014			ELUM
Mercury Vapor Luminaire		.014			EMVL
Double Light Pole		.014			EDBLT
Utility Wood Pole	PP 	.014		.024	EPP/PUP
Utility Guy Pole	GP 	.014	GP 	.024	EPP/PUP
Anchor		.014		.024	EGUY/PGUY
Ground		.014		.024	GND


















City of Seattle

NOT TO SCALE

STANDARD SYMBOLS  
ELECTRICAL

































ITEM	EXISTING	LINE WEIGHT	PROPOSED	LINE WEIGHT	CAD NOTES
Traffic Signal Mast Arm Pole		.014		.028	ESIG PMAP+PMAST# +PSIGV
Traffic Signal Mast Arm Pole w/ Luminaire		.014		.028	ESIG+ELUM PMAP+PMAST# PLUM+PSIGV
Traffic Signal on Span Wire		.014		.028	ESIG/PSIGV
Multi-Directional Traffic Signal on Span Wire		.014			ESIG
Traffic Signal Conduit		.014		.028 or .031	LT=ECd 6-1-1-1
Traffic Signal Cable		.014		.028 or .031	LT=ECd 6-1-1-1
Detector Loop, Dipole (loop schedule)		.014		.020	ELOOP1 PLOOP## drawn to size
Detector Loop, Quadrapole (loop schedule)		.014			ELOOP2
Pressure Detector		.014			drawn to size



City of Seattle

NOT TO SCALE

STANDARD SYMBOLS  
ELECTRICAL

ITEM	EXISTING	LINE WEIGHT	PROPOSED	LINE WEIGHT	CAD NOTES
Signal Pedestal		.014		.020	EPEDP PPEDP
Vehicle Signal		.014			ESIG
Vehicle Signal w/ Backplate		.014		.020	ESIGNBK PSIGV
Vehicle Signal (optically programmed)		.014		.020	ESIGOP PSIGVOP
Pedestrian Signal		.014		.020	EPEDSIG PSIGP
Pedestrian Signal (optically programmed)		.014		.020	EPEDSGOP PSIGPOP
Pedestrian Push Button Pedestal		.014			EPPBP PPPBP
Pedestrian Push Button		.014	 PPB	.020	EPPB PPPB
Illuminated Sign		.014		.020	EILLSIGN PILLSIGN
Non-illuminated Sign		.014		.020	ENILSIGN PNILSIGN
Junction Box		.014			EJB
Handhole		.014	 HH	.020	EHH / PHH#
Traffic Control Handhole		.014	 TCHH	.020	EHH PHH#
Street Light Handhole		.014	 SLHH	.020	EHH PHH#
Ground Rod Handhole		.014	 GRHH	.020	EHH PHH#
Fire Alarm Handhole		.014	 FAHH	.020	EHH








City of Seattle

NOT TO SCALE




STANDARD SYMBOLS  
ELECTRICAL

**SIGNALIZATION****CAD NOTES**

	Vehicle & Pedestrian Signal Head (?=Identification Number)	PHEX
	Illuminated Traffic Sign (?=Identification Number)	PBOX
	Cable Runs (?=Run Number per Wiring Schedule)	PTRI
	Removal/Relocation Item (?=Identification Number per Removal/Relocation Plan)	PCIR
	Construction Item (?=Identification Number per Signalization Plan)	POVAL

Signal Poles, Signal Pedestals, Push Button Pedestals &  
Push Buttons Identified by Number on Signalization Plan.

**CHANNELIZATION & SIGNAGE**





















	Install Channelization Signage (?=Channelization / Signage Identified on Plan)	INSTALL
	Remove Channelization / Signage (?=Channelization / Signage Identified on Plan)	REMOVAL
	Relocate Signage (?=Signage Identified on Plan)	RELOCATE



































City of Seattle

NOT TO SCALE

STANDARD SYMBOLS  
SIGNALIZATION / CHANNELIZATION  
& SIGNAGE

ITEM	EXISTING	LINE WEIGHT	PROPOSED	LINE WEIGHT	CAD NOTES
Cement Concrete Pavement	 6" CONC	.014	 6" CONC PAV	.020	DOTS Color 22 Suggested scale 20 Angle 45
Asphalt Concrete Pavement	 2" ASPH/6" CONC	.014	 8" -402B PAV	.020	DOTS Color 22 Suggested scale 10 Angle 45
Asphalt Concrete Surfacing	 2" ASPH	.014	 2" ASPH	.020	DOTS Color 22 Suggested scale 10 Angle 45
Curb		.014	 TYPE 410C CURB	.028	
Cement Concrete Walk	 CW	.014	 CW	.020 .028	AR-CONC Color 22 Suggested scale 1.0 Angle 45
Curb Ramp		.014		.020 .028	EWCR user modified PWCR user modified AR-CONC
Conc Dwy		.014		.020 .028	DOTS Color 22 Suggested scale 20 Angle 45
Cement Concrete Bike Way	 3" CBW	.014	 3" CBW	.020	AR-CONC Color 22 Suggested scale 1.0 Angle 45
Asphalt Concrete Bike Way	 3" ABW	.014	 3" ABW	.020	DOTS Color 22 Suggested scale 10 Angle 45
Grading	 GRADED	.014	 TO BE GRADED	.020	SPU Customized Command: ASPH
REF STD SPEC SEC					
City of Seattle		NOT TO SCALE		STANDARD SYMBOLS PAVING	

ITEM	EXISTING	LINE WEIGHT	PROPOSED	LINE WEIGHT	CAD NOTES
Manholes		.014		.031	EMH+ECASTC/ PMH LT=MH
Inlet Type 250A		.014		.031	EINL250A PINL250A
Inlet Type 250B		.014		.031	EINL250B PINL250B
Inlet Type 252		.014		.031	EINL252 PINL252
Inlet Type 268		.014			EINL250A
Catch Basin round inlet top		.014			ECB-RND
Private CB & Inlet		.014			ECB-PRIV
Catch Basin Type 151 (pre 1985)		.014			ECB151
Catch Basin Type 240A		.014		.031	ECB240A PCB240A
Catch Basin Type 240B		.014		.031	ECB240B PCB240B
Catch Basin Type 240C		.014		.031	ECB240C PCB240C
Catch Basin Type 240D				.031	PCB240D
Catch Basin Type 241		.014		.031	ECB241 PCB241
Catch Basin Type 242A		.014		.031	ECB242A PCB242A
Catch Basin Type 242B		.014		.031	ECB242B PCB242B
Catch Basin Type 277A		.014		.031	ECB277A PCB277A
Catch Basin Type 277B		.014		.031	ECB277B PCB277B
Sand Box		.014			ESB
Clean Out		.014		.031	ECO/PCO































City of Seattle

NOT TO SCALE

STANDARD SYMBOLS  
SEWER & DRAINAGE



ITEM	EXISTING	LINE WEIGHT	PROPOSED	LINE WEIGHT	CAD NOTES
Concrete Culvert		.014		.024	LT=PSS
Pipe Sewer Combined <1'-0"Dia		.014		.031	LT=PSS
Pipe Sewer Combined ≥1'-0"Dia		.014		.024	LT=PSS DOTS scale 10
Side Sewer Combined		.014		.028	LT=SD
Pipe Sewer Sanitary <1'-0"Dia		.014		.031	LT=PSS
Pipe Sewer Sanitary ≥1'-0"Dia		.014		.024	LT=PSS ANSI31 scale 20 / angle 90
Side Sewer Sanitary		.014		.028	LT=SD
Pipe Storm Drain <1'-0"Dia		.014		.031	LT=PSS
Pipe Storm Drain ≥1'-0"Dia		.014		.024	LT=PSS ANSI31 scale 10
Service Drain		.014		.028	LT=SD
Inlet & CB Connection		.014		.028	LT=SD
Open Ended Pipe		.014		.031	ETIC PTIC
Small Ditch or Stream		.014		.020	LT= ENDITCH LT= PNDITCH
Large Ditch or Stream		.014		.020	LT= WDITCH



City of Seattle

NOT TO SCALE

STANDARD SYMBOLS  
SEWER & DRAINAGE



























ITEM	EXISTING	LINE PROPOSED WEIGHT	LINE WEIGHT	CAD NOTES
Bench Mark (found or set)		.014		ESVBM
Brass Plug/Cap (found or set)		.014		ESVBP
Hub/Tack (found or set)		.014		ESVHUB
Monument in Case (found or set)		.014		ESVMIC
Conc. Mon. (found or set)		.014		ESVMON
Rebar/Cap, Pipe/Cap Rebar, Iron Pipe (found or set)		.014		ESVRB
Tack/Lead, Tack PK Nail, Spike (found or set)		.014		ESVTK
Bench Mark (not found)		.007		ESVNFBM
Brass Plug/Cap (not found)		.007		ESVNFBP
MIC. (not found)		.007		ESVNFMIC
Conc. Mon. (not found)		.007		ESVNFMON
Rebar/Cap, Pipe/Cap Rebar, Iron Pipe (not found)		.007		ESVNFRB
Tack/Lead, Tack PK Nail, Spike (not found)		.007		ESVNFTK
Survey Shot Point		.014		ESVSHOTP



City of Seattle

NOT TO SCALE

STANDARD SYMBOLS  
TOPOGRAPHIC & MISC



























ITEM	EXISTING	LINE WEIGHT	PROPOSED	LINE WEIGHT	CAD NOTES
Center Line		.014			LT=CENTER3
Monument Line		.014			LT=CENTER3
Survey Line		.014			
Right of Way Line		.028			
Lot & Ownership Line		.014			
Permanent Easement Line		.031		.02	LT=EASEMENT
Temp Const Easement Line				.07	LT=DOT2
Vacated Street or Alley		.028			LT=PSS
State Highway Limited Access Line		.028			LT=BUILDING
Building		.014			LT=BUILDING
Chain Link Fence		.014		.014	LT=CHAIN_LINK_FENCE
Wood Fence		.014		.014	LT=WOOD_FENCE
Guardrail		.014		.014	LT=GUARD_RAIL
Rock Facing		.014		.012	SPU Customized Command: ROCKWALL
Rock Facing		.014			EROCK
Riprap		.014		.012	ERIPRAP PRIPRAP
Tree <1'-0" DIA	 	.014	PER DRAWINGS		EDECIDSM/ECONFSM PDECIDSM/PCONFSM draw to scale
Tree ≥1'-0" DIA	 	.014	PER DRAWINGS		ESTRUNK+ESDCANOP ESTRUNK+PSDCANOP draw to scale



City of Seattle

NOT TO SCALE

STANDARD SYMBOLS  
TOPOGRAPHIC & MISC

















ITEM	EXISTING	LINE WEIGHT	PROPOSED	LINE WEIGHT	CAD NOTES
Shrub or Bush		.014		.020	ESHRUB PSHRUB
Ground, Grade Line		.014		.014	LT=DASHED2
Grade (arrow downhill)		.014		.014	
Rail Road Tracks		.014			SPU Customized Command
City Limits		.024			LT=BORDER
Slope Line				.014	
Contours		.014		.014	
Slope Angle Horiz:Vert		.014		.014	
Vertical Curve		.014		.014	
Depression		.014		.014	
Stump		.014			ESTUMP
Top of Cut Toe of Fill				.014	
Dimension Line		.014		.014	
Match Line		.014		.020	
Test Hole & Number (test boring)		.014		.003	ESVBM
Bench Mark		.014			ESVBM



City of Seattle

NOT TO SCALE

STANDARD SYMBOLS  
TOPOGRAPHIC & MISC

ITEM	EXISTING	LINE WEIGHT	PROPOSED	LINE WEIGHT	CAD	NOTES
Monitor Well	MW 	.014				EMWELL
Street Name Sign		.014				ESNS
US Mail Box		.014				EMAILUS
Private Mail Box		.014				EMAILPVT
Bollard		.014				EBLRD/PBLRD
Post		.014				EPOST
Parking Meter		.014				EPRKM
Rectangular Casting		.014				ECASTR
Circular Casting		.014				ECASTC
Column		.014				ECOLUMN
Jersey Barrier		.014		.020		PJERSEY
Tree Pit		.014		.020		PTPIT or draw to scale
North Arrow horizontal						NORTHHOR
North Arrow vertical		.012				NORTHVER






















City of Seattle

NOT TO SCALE

STANDARD SYMBOLS  
TOPOGRAPHIC & MISC





































ITEM	EXISTING	LINE PROPOSED WEIGHT	LINE CAD WEIGHT	NOTES
Telephone Cable (direct burial)		.014		LT=TEL 6-1-1 (typical)
Telephone Conduit		.014		
Telephone Duct		.014		
Telephone Enclosure		.014		ETELNCL
Telephone Manhole		.014		draw to scale
Telephone Pole		.014		
Telephone Handhole		.014		EHH draw to scale
Television Cable (direct Burial)		.014		LT=TV 6-1-1-1
Television Handhole		.014		EHH draw to scale
Telegraph Manhole		.014		draw to scale
Steam Log		.014		LT=STEAM 2-2
Steam Vault		.014		draw to scale
Gas Main		.014		LT=GAS 6-1-6 (typical)
Gas Valve		.014		EVALVE
Gas Meter		.014		EGM
Gas Regulator		.014		EGREG
Petroleum or Oil		.014		
Abandon(ed)		.014		.024



City of Seattle

NOT TO SCALE

STANDARD SYMBOLS  
PRIVATE UTILITIES












ITEM	EXISTING	LINE WEIGHT	PROPOSED	LINE WEIGHT	CAD NOTES
Watermain <8"Dia		.014		.031	LT=WATER 6-6 (typical)
Watermain ≤8"<1'-0"Dia		.014		.031	
Watermain ≥1'-0"Dia		.014		.031	DOTS scale 20
11 1/4° Bend w/ Conc Blocking		.014		.031	EHB11 PHB11 + PCONCBLK
22 1/2° Bend		.014		.031	EHB22 PHB22
45° Bend		.014		.031	EHB45 PHB45
90° Bend		.014		.031	EHB90 PHB90
Cross		.014		.031	ECROSS / PCROSS
Tee		.014		.031	ETEE / PTEE
Pipe Sleeve				.031	PSLEEVE
Plug w/ Conc Blocking		.014		.031	PTIC + PCONCBLK EPLUG
Hydrant		.014		.031	EHYD + ETEE PHYD + PTEE
Water Meter		.014		.031	EWM / PWM
Valve Box		.014			EVBX
Gate Valve		.014		.031	EVALVE PVALVE
Gate Valve w/ Chamber		.014		.031	EWGV PWGV
Gate Valve w/ Vault Chamber		.014		.031	EWGVVCH PWGVVCH
Reducer		.014		.031	ERED / PRED



City of Seattle

NOT TO SCALE

STANDARD SYMBOLS  
WATER


ITEM	EXISTING	LINE WEIGHT	PROPOSED	LINE WEIGHT	CAD NOTES
Air Valve		.014		.031	EAV / PAV
Blowoff		.014		.031	EBO / PBO
Butterfly Valve w/ Valve Box		.014		.031	EVALVE PVALVE
Butterfly Valve w/ Chamber		.014		.031	EWGV PWGV
Water Chamber		.014			EWCH
Sprinkler Head		.014			ESPRKHD
Irrigation Valve		.014			EIRRGV



City of Seattle

NOT TO SCALE

STANDARD SYMBOLS  
WATER

**NOTES:**

1. MEASUREMENT PER LINEAR FOOT. PIPE ENDING IN STRUCTURE MEASURED TO EITHER INSIDE FACE OR TO CENTERLINE OF STRUCTURE AS INDICATED, OR TO TEE OR WYE AS INDICATED.
2. TEE OR WYE INCLUDING PLUG - UNIT PRICE EACH
3. ALL PIPE SHALL BE MEASURED ON THE SLOPE ALONG THE CENTERLINE OF PIPE TO NEAREST 0.10 LF.


REF STD SPEC DIVISION 7



City of Seattle

NOT TO SCALE

SEWER/DRAINAGE  
MEASUREMENT DIAGRAM



City of Seattle

NOT TO SCALE

MONUMENT FRAME &amp; COVER




City of Seattle

NOT TO SCALE

STANDARD LOCATIONS  
FOR UTILITIES  
(RESIDENTIAL STREET)

REF STD SPEC SEC 1-07.16, 1-07.17 & 1-07.28



**NOTES:**

- SERVICE LATERALS OR APPURTENANCES:  
1'-8" TO 2'-6" DEPTH FROM CURB TO PROPERTY LINE RESERVED FOR SERVICE LATERALS AND APPURTENANCES  
SANITARY SIDE SEWER MINIMUM COVER IS 2'-6" AT PROPERTY LINE AND 5'-0" AT THE CURB  
SERVICE DRAIN MAY RUN UNDER THE SIDEWALK, THROUGH THE CURB OR THROUGH RESERVED SPACES IDENTIFIED IN NOTE 1
- ELECTRIC POWER, GAS, TELEPHONE, TELEVISION AND TREES SHALL BE INSTALLED IN THE SAME RELATION TO THE CURB ON STREETS WITH PAVEMENT WIDTHS FROM 25'-0" TO 36'-0"
- LAYOUT IS APPLICABLE TO 60'-0" R/W AND 25'-0" RESIDENTIAL PAVING
- REDUCING CLEARANCE BETWEEN A NEW UTILITY AND EXISTING TREE/PLANTING STRIP, REDUCING CLEARANCE BETWEEN A NEW/REPLACEMENT TREE AND EXISTING UTILITY OR CHANGING THE 10'-6" WIDTH OF PLANTING STRIP REQUIRES REVIEW AND APPROVAL OF THE ENGINEER AND MAY REQUIRE ADDITIONAL MITIGATING MEASURES

REV DATE: 2005

STANDARD PLAN NO 030

STAKE TREE WITH (2) TREATED 2"Ø LODGEPOLE PINE DOWELED TREE STAKES (8'-0" LENGTH) LOOP EACH TIE AROUND HALF TREE LOOSELY TO PROVIDE 1" SLACK FOR TRUNK GROWTH

"CHAINLOCK" OR EQUAL TREE TIE MATERIAL (1" WIDTH) NAIL OR STAPLE TREE TIE MATERIAL TO STAKE TO HOLD VERTICALLY. LOOP EACH TIE AROUND HALF TREE LOOSELY TO PROVIDE 1" SLACK FOR TRUNK GROWTH

2"-3" MULCH DEPTH (TAPERED AT TRUNK)

MULCH TREE PIT MIN 5'-0" LENGTH X FULL PLANTING STRIP WIDTH BETWEEN CURB AND SIDEWALK (FOR PLANTING STRIPS LESS THAN 6'-0" WIDE.) PROVIDE 5'-0"Ø MULCH RING FOR PLANTING STRIPS WIDER THAN 6'-0"


SIDEWALK

ROUGHEN SIDES OF PLANTING HOLE. MAXIMIZE EXCAVATED AREA WITHOUT UNDERMINING ADJACENT PAVING/CURB

REMOVE ALL WIRE & STRING, AND REMOVE ALL BURLAP FROM TOP 2/3 OF ROOTBALL

NATIVE BACKFILL SOIL AMENDMENT WITH 25% (@1/3 CU YD) DECOMPOSED ORGANIC MULCH AMENDMENT FOR ENTIRE TREE PIT AREA X ROOTBALL DEPTH

UNDISTURBED SUBGRADE (PROVIDES FIRM BASE SO THAT ROOTBALL WILL NOT SINK)



#### NOTES:

1. INSTALLATION INCLUDES REMOVAL OF STAKES ONE YEAR AFTER INSTALLATION
2. SHAPE SOIL SURFACE TO PROVIDE 3' DIAMETER WATERING RING
3. TREE CLEARANCES SHALL BE PER STD PLAN NO 030
4. SEE STD PLAN NO 424 FOR TREE PIT DETAIL.
5. ADJUST TREE TIES DURING ESTABLISHMENT TO ALLOW ROOM FOR GROWTH (@1" SLACK)

— SET TOP OF ROOT CROWN 2" ABOVE ADJACENT CURB & SIDEWALK GRADE

3" TO 4" HIGH WATERING RING (SEE NOTE 2)

TREE PIT DEPTH= ROOTBALL DEPTH (MEASURE BEFORE DIGGING TO AVOID OVEREXCAVATION)

DRIVE STAKES 6" TO 1'-0" INTO UNDISTURBED SOIL BELOW ROOTBALL

DRIVE STAKE AT ROOTBALL EDGE (TYP)(SEE NOTE 1)

MIN WIDTH OF TREE PIT=2 TIMES ROOTBALL DIAMETER OR 5'-0", WHICHEVER IS GREATER

MULCH AREA TO BE CLEAR OF GRASS, WEEDS, ETC. TO REDUCE COMPETITION WITH TREE ROOTS


REF STD SPEC SEC 8-02



City of Seattle

NOT TO SCALE

DECIDUOUS TREE PLANTING  
IN PLANTING STRIP

**NOTES:**

1. STAKE TREES PER STD PLAN NO 100a
2. ONE STAKE PER TREE ON WINDWARD SIDE; SECOND STAKE ON LEEWARD SIDE
3. SLOPES STEEPER THAN 2:1 MAY REQUIRE AN APPROVED EMBANKMENT STABILIZATION SYSTEM TO CREATE A LEVEL TREE PIT SUCH AS:
  - ROCK FACING
  - PRECAST CONCRETE WALL UNITS
  - TIMBER WALL
  - MANUFACTURED SLOPE RETENTION UNITS
4. CHAINLOCK TREE TIE. LOOP EACH TIE AROUND TREE LOOSELY TO PROVIDE 1" SLACK FOR DIAMETER GROWTH.
5. SHAPE SOIL TO PROVIDE 3' DIAMETER OR ROOTBALL DIAMETER, WHICHEVER IS GREATER, WATERING RING.
6. REMOVE ALL WIRE AND STRING. REMOVE TOP 2/3 OF BURLAP.

REF STD SPEC SEC 8-02




City of Seattle


NOT TO SCALE

TREE & SHRUB PLANTING  
ON SLOPES





REF STD SPEC SEC 8-02




REF STD SPEC SEC 8-02



City of Seattle

NOT TO SCALE

SHRUB PLANTING




REF STD SPEC SEC 8-02



City of Seattle

NOT TO SCALE

GROUND COVER PLANTING




REF STD SPEC SEC 9-14



City of Seattle

NOT TO SCALE


PLANTING PATTERN



QUANT PER 10'-0" LF MEDIAN

○ GROUNDCOVER	30
⊗ SHRUB	5

DETAIL AT TREE PLAN



QUANT PER END CAP

⊗ PERENNIAL TYPE 1	4
⊙ PERENNIAL TYPE 2	6
⊗ PERENNIAL TYPE 3	5
○ EVERGREEN GROUNDCOVER TYPE 1	13
⊗ EVERGREEN GROUNDCOVER TYPE 2	12


END CAP DETAIL

TYP STREET TREE  
2" - 2 1/2" CALIPER  
@ 30' - 0" OC

CHAINLOCK TREE TIE.  
LOOP EACH TIE AROUND  
TREE LOOSELY TO PROVIDE  
1" SLACK FOR DIAMETER  
GROWTH

(2) 2" ⌀ LODGEPOLE PINE  
DOWELED TREE STAKES  
(8' - 0" LENGTH)

SEE STD PLAN NO 100  
FOR SUPPLEMENTAL TREE  
PLANTING INFORMATION




PLACE 3" OF PLANTING SOIL  
& MIX WITH SUBSOIL  
BEFORE ADDING  
SUBSEQUENT QUANTITIES OF  
PLANTING SOIL (IN 6" LIFTS)  
COMPACTED TO 85%

NATIVE SUBGRADE TO BE  
SCARIFIED TO A DEPTH OF  
6" PRIOR TO PLACEMENT OF  
FILL. CALL FOR INSPECTION  
BEFORE FILLING

3" BARK MULCH

SEE STD PLAN NO's 110 &  
111 FOR SUPPLEMENTAL  
SHRUB AND GROUNDCOVER  
PLANTING INFORMATION



SOIL PREPARATION DETAIL

REF STD SPEC SEC 8-02




City of Seattle

NOT TO SCALE


MEDIAN PLANTING

# STANDARD PLAN NO 121


REV DATE: 2003




ABOVE GROUND HOSE BIB



BELOW GROUND HOSE BIB



BRACE DETAIL - PLAN VIEW



ELEVATION VIEW

QUICK COUPLER VALVE  
TURF OR BED AREAS


REF STD SPEC SEC 8-03




City of Seattle

NOT TO SCALE

HOSE BIB ASSEMBLY AND  
QUICK COUPLER VALVE

**NOTE:**

"U" SHAPED CUT-OUT IN VALVE BOX THAT ALLOWS 2" CLEARANCE FROM TOP OF PIPE TO TOP OF "U"

AUTOMATIC CONTROL VALVEMANUAL DRAIN VALVE


REF STD SPEC SEC 8-03



City of Seattle

NOT TO SCALE

IRRIGATION VALVES



REF STD SPEC SEC 8-03



City of Seattle


NOT TO SCALE

IRRIGATION VALVES



# STANDARD PLAN NO 124

REV DATE: 2003



REF STD SPEC SEC 8-03





City of Seattle

NOT TO SCALE

IRRIGATION VALVES

# STANDARD PLAN NO 125

REV DATE: 2003



REF STD SPEC SEC 8-03




City of Seattle

NOT TO SCALE

IRRIGATION VALVES


# STANDARD PLAN NO 126

REV DATE: 2003




**POP UP ROTOR HEAD**  
TURF AREAS

**NOTE:**  
USE TEFLON TAPE ON  
ALL THREADED FITTINGS



**POP UP SPRAY HEAD**  
(SHRUB BED AREAS)  
AT EDGE OF PAVEMENT



**FIXED SHRUB RISER**  
SHRUB BED AREAS



REF STD SPEC SEC 8-03



City of Seattle

NOT TO SCALE

POP UP & FIXED  
IRRIGATION HEADS



REF STD SPEC SEC 8-03




City of Seattle

NOT TO SCALE


IRRIGATION CONTROLLER  
PEDESTAL AND ENCLOSURE  
GROUNDING

# STANDARD PLAN NO 128


REV DATE: 2003




MAIN LINE



SLEEVE TRENCHING



LATERAL LINE



POWER SUPPLY TRENCH

REF STD SPEC SEC 8-03



City of Seattle

NOT TO SCALE


IRRIGATION TRENCHES

# STANDARD PLAN NO 129

REV DATE: 2003

## NOTES:

1. NEMA 3R RAINPROOF CABINET
2. NO 12 GA PREGALVANIZED STEEL WELDED SEAM CONSTRUCTION
3. TWO SCREENED, GASKETED LOUVERED VENTS
4. REMOVABLE EQUIPMENT MOUNTING PAN
5. VANDALPROOF LOCKABLE SLIDE BAR ACROSS FRONT DOOR
6. PADMOUNT DESIGN WITH 2" INSIDE FLANGE ON BOTTOM
7. DOOR:
  - 3 POINT LATCH
  - CONCEALED HINGE
  - LIFT-OFF TYPE (UPON OPENING)
  - CLOSED CELL NEOPRENE GASKET
8. PAINT:
  - OVEN BAKED ENAMEL
  - DARK GREEN OUTSIDE
  - WHITE INSIDE
  - PREGALVANIZED METAL TREATED WITH COPPER SULFATE PRIOR TO PAINTING
9. ACTUAL CABINET DIMENSIONS ARE PROJECT SPECIFIC AND WILL BE SPECIFIED ON THE DRAWINGS.



SECTION A-A




REF STD SPEC SEC 8-03



City of Seattle

NOT TO SCALE

IRRIGATION  
CONTROLLER CABINET




REF STD SPEC SEC 1-07.16(2)



City of Seattle

NOT TO SCALE

TREE PROTECTION  
DURING CONSTRUCTION

FENCING/ROOT PROTECTION

CHAIN LINK FENCING TO BE PROVIDED AND MAINTAINED AT DRIPLINE

ENGINEER'S APPROVAL REQUIRED FOR USE/ACCESS WITHIN ZONE B. PERMISSION FOR USE/ACCESS REQUIRES SURFACE PROTECTION FOR ALL UNFENCED, UNPAVED SURFACES WITHIN ZONE B

\* SURFACE PROTECTION MEASURES

1. MULCH LAYER, 6"-8" DEPTH
2. 3/4" PLYWOOD
3. STEEL PLATES

TRENCHING/EXCAVATIONZONE A (CRITICAL ROOT ZONE)

1. NO DISTURBANCE ALLOWED WITHOUT SITE-SPECIFIC INSPECTION AND APPROVAL OF METHODS TO MINIMIZE ROOT DAMAGE
2. SEVERANCE OF ROOTS LARGER THAN 2" DIA REQUIRES ENGINEER'S APPROVAL
3. TUNNELING REQUIRED TO INSTALL LINES 3'-0" BELOW GRADE OR DEEPER

ZONE B (DRIPLINE)

1. OPERATION OF HEAVY EQUIPMENT AND/OR STOCKPILING OF MATERIALS SUBJECT TO ENGINEER'S APPROVAL. SURFACE PROTECTION\* MEASURES REQUIRED
2. TRENCHING ALLOWED AS FOLLOWS:
  - EXCAVATION BY HAND OR WITH HAND-DRIVEN TRENCHER MAY BE REQUIRED
  - LIMIT TRENCH WIDTH. DO NOT DISTURB ZONE A. MAINTAIN 2/3 OR MORE OF ZONE B IN UNDISTURBED CONDITION
3. TUNNELING MAY BE REQUIRED FOR TRENCHES DEEPER THAN 3'-0"

ZONE C (FEEDER ROOT ZONE)

1. OPERATION OF HEAVY EQUIPMENT AND/OR STOCKPILING OF MATERIALS SUBJECT TO ENGINEER'S APPROVAL. SURFACE PROTECTION\* MEASURES MAY BE REQUIRED
2. TRENCHING WITH HEAVY EQUIPMENT ALLOWED AS FOLLOWS:
  - MINIMIZE TRENCH WIDTH
  - MAINTAIN 2/3 OR MORE OF ZONE C IN UNDISTURBED CONDITION

REF STD SPEC SEC 1-07.16 (2)



City of Seattle

NOT TO SCALE

TREE PROTECTION DURING  
TRENCHING, TUNNELING OR  
EXCAVATION



		TREES IN PLANTING STRIPS	TREES IN TREE PITS
HEAVY EQUIPMENT OPERATION	ROOT PROTECTION	<p>ALL NON-PAVED PLANTING STRIP SURFACES SUBJECT TO IMPACT (COMPACTION) BY CONSTRUCTION ACTIVITY SHALL BE PROTECTED WITH 6"-8" MULCH LAYER OR 3/4" PLYWOOD PANELS</p> <p>PROVIDE WOOD PLANKING OR STEEL PANELS UNDER BACKHOE STABILIZERS PLACED ANYWHERE IN THE PLANTING STRIP [1-07.16(2)]</p> <p>NO STORAGE OF MATERIALS OR EQUIPMENT IN THE PLANTING STRIP SHALL BE ALLOWED WITHOUT PROPER SURFACE PROTECTION <u>AND</u> WRITTEN AUTHORIZATION FROM THE ENGINEER</p>	<p>RETAIN EXISTING PAVING DURING CONSTRUCTION</p> <p>SCHEDULE PAVEMENT REPLACEMENT TO MINIMIZE EXPOSURE OF SURFACE ROOTS TO DRYING, EQUIPMENT DAMAGE, COMPACTION, ETC. EXPOSURE FOR LONGER THAN 48 HOURS REQUIRES MULCH APPLICATION</p>
	CANOPY PROTECTION	OVERHEAD BRANCHING LIKELY TO BE DAMAGED BY EQUIPMENT OPERATION SHALL BE BROUGHT TO THE ATTENTION OF THE ENGINEER WITH PREVENTIVE MEASURES (PRUNING OR TIE-BACK OF BRANCHES) APPROVED BY THE ENGINEER AND PROPERLY EXECUTED BEFORE COMMENCEMENT OF THE WORK	
	TRUNK PROTECTION	PROVIDE CHAIN LINK CONSTRUCTION FENCE IN INDIVIDUAL FENCE INSTALLATIONS FOR EACH TREE OR THE LENGTH OF THE PLANTING STRIP.	PROVIDE 5'-0" MIN HEIGHT FENCE INSTALLATIONS FOR EACH TREE TO ENCLOSE ENTIRE TREE PIT OPENING.
SIDEWALK RECONSTRUCTION		<p>ROOT PRUNE <u>ONLY</u> AS APPROVED BY THE ENGINEER</p> <p>MAINTAIN 2'-0" <u>MIN</u> CLEARANCE FROM FLARE OF TRUNK WHEN SETTING FORMS.</p>	PROVIDE 5'-0" X 5'-0" OR 4'-0" X 6'-0" (24 SQ FT MIN) TREE PITS IN NEW SIDEWALK FOR <u>NEW</u> TREES. TREE PIT SIZE FOR EXISTING TREES SHALL BE ELONGATED (8'-0" TO 12'-0" +). PITS MAY BE REQUIRED TO MINIMIZE ROOT IMPACTS WHILE MAINTAINING REQUIRED SIDEWALK WIDTH
TRENCH OR TUNNELING		SEE STD PLAN NO 133	


REF STD SPEC SEC 1-07.16(2)



City of Seattle

NOT TO SCALE

CONSTRUCTION AROUND  
EXISTING TREES




REF STD SPEC SEC 2-03




City of Seattle

NOT TO SCALE

SLOPE ROUNDING



SECTION



ELEVATION

		MINIMUM ROCK	
(h)	(d)	SIZE(BASE)	SIZE(TOP)
2 FEET	3 INCHES	2-MAN	1-MAN
4 FEET	6 INCHES	3-MAN	2-MAN
6 FEET	9 INCHES	4-MAN	2-MAN
8 FEET	12 INCHES	5-MAN	2-MAN

$\phi = 14^{\circ} \pm 1^{\circ}$

REF STD SPEC SEC 2-08





City of Seattle

NOT TO SCALE

ROCK FACING

**NOTES:**

1. TYPE A MANHOLE DESIGNATES MANHOLES WITH PRECAST CONCENTRIC CONE SECTIONS.
2. TYPE B MANHOLE DESIGNATES MANHOLES WITH TOP SLABS.
3. TOP SLAB AND BASE SECTION DETAILS, SEE STANDARD PLAN NO 200b.
4. MAXIMUM DIMENSION FROM OUTSIDE MANHOLE WALL TO THE FIRST PIPE JOINT, THE GREATER OF 1/2 INSIDE PIPE DIAMETER OR 1'-0".
5. FOR TYPE A MANHOLE, LOCATE MANHOLE STEPS ON THE SIDE PERPENDICULAR TO THE DIRECTION OF THE FLOW IN THE CHANNEL.
6. FOR TYPE B MANHOLE, LOCATE MANHOLE STEPS OPPOSITE TO THE DOWNSTREAM OPENING.
7. TOTAL HEIGHT OF AN EXTENSION, MANHOLE FRAME AND LEVELING BRICKS SHALL NOT EXCEED 2'-2".
8. MANHOLE BASE SECTIONS SHOWN IN SECTION A-A AND SECTION B-B ARE TYPICAL FOR TYPE A AND TYPE B MANHOLES.
9. THE MAXIMUM HOLE SIZE SHALL BE THE OUTSIDE DIAMETER OF THE PIPE PLUS THE MANHOLE WALL THICKNESS. THE MINIMUM HOLE SIZE SHALL BE THE OUTSIDE DIAMETER OF THE PIPE PLUS 4 INCHES. MINIMUM DISTANCE BETWEEN HOLES IS 8 INCHES.
10. PRECAST MANHOLE COMPONENTS SHALL CONFORM TO ASTM C 478. JOINTS BETWEEN PRECAST COMPONENTS SHALL BE RUBBER GASKETED CONFORMING TO ASTM C 443.



REF STD SPEC SEC 7-05



City of Seattle

NOT TO SCALE

TYPE 200 MANHOLE





1. MATERIAL: CONCRETE—CLASS AX  
REINFORCING STEEL—ASTM A 615 GR 60
2. TOP SLAB IS DESIGNED FOR 3'-0" MAX COVER  
BASE IS DESIGNED FOR 20'-0" MAX COVER
3. HEIGHT 8'-0" TO 12'-0":  
MIN. REQUIRED SOIL BEARING = 3300 LBS/SQ FT
4. HEIGHT 12'-0" TO 20'-0":  
MIN. REQUIRED SOIL BEARING = 3800 LBS/SQ FT

TYPE 200 MANHOLE  
TOP & BOTTOM SLABS

**NOTES:**

1. TYPE A MANHOLE DESIGNATES MANHOLES WITH PRECAST CONCENTRIC CONE SECTIONS.
2. TYPE B MANHOLE DESIGNATES MANHOLES WITH TOP SLABS.
3. TOP SLAB AND BASE SECTION DETAILS, SEE STANDARD PLAN NO 201b.
4. MAXIMUM DIMENSION FROM OUTSIDE MANHOLE WALL TO THE FIRST PIPE JOINT, THE GREATER OF 1/2 INSIDE PIPE DIAMETER OR 1'-0".
5. FOR TYPE A MANHOLE, LOCATE MANHOLE STEPS ON THE SIDE PERPENDICULAR TO THE DIRECTION OF THE FLOW IN THE CHANNEL.
6. FOR TYPE B MANHOLE, LOCATE MANHOLE STEPS OPPOSITE TO THE DOWNSTREAM OPENING.
7. TOTAL HEIGHT OF AN EXTENSION, MANHOLE FRAME AND LEVELING BRICKS SHALL NOT EXCEED 2'-2".
8. MANHOLE BASE SECTIONS SHOWN IN SECTION A-A AND SECTION B-B ARE TYPICAL FOR TYPE A AND TYPE B MANHOLES.
9. THE MAXIMUM HOLE SIZE SHALL BE THE OUTSIDE DIAMETER OF THE PIPE PLUS THE MANHOLE WALL THICKNESS. THE MINIMUM HOLE SIZE SHALL BE THE OUTSIDE DIAMETER OF THE PIPE PLUS 4 INCHES. MINIMUM DISTANCE BETWEEN HOLES IS 8 INCHES.
10. PRECAST MANHOLE COMPONENTS SHALL CONFORM TO ASTM C 478. JOINTS BETWEEN PRECAST COMPONENTS SHALL BE RUBBER GASKETED CONFORMING TO ASTM C 443.



\*FOR SEPARATE CAST-IN-PLACE BASE


REF STD SPEC SEC 7-05




City of Seattle

NOT TO SCALE

TYPE 201 MANHOLE



## SECTION A-A



TYPE 201 MH-TOP SLAB

## NOTES:

1. MATERIAL: CONCRETE-CLASS AX  
REINFORCING STEEL-ASTM A 615 GR 60
2. TOP SLAB IS DESIGNED FOR 3'-0" MAX COVER  
BASE IS DESIGNED FOR 20'-0" MAX COVER
3. HEIGHT 8'-0" TO 12'-0":  
MIN. REQUIRED SOIL BEARING = 3300 LBS/SQ FT
4. HEIGHT 12'-0" TO 20'-0":  
MIN. REQUIRED SOIL BEARING = 3800 LBS/SQ FT

REF STD SPEC SEC 7-05




City of Seattle



NOT TO SCALE

TYPE 201 MANHOLE  
TOP & BOTTOM SLABS

## REV DATE: 2003








REF STD SPEC SEC 7-05



City of Seattle

NOT TO SCALE

TYPE 202 MANHOLE  
TOP & BOTTOM SLABS




REF STD SPEC SEC 7-05



City of Seattle



NOT TO SCALE

TYPE 203 MANHOLE



## NOTES:

1. MATERIAL: CONCRETE—CLASS AX  
REINFORCING STEEL—ASTM A 615 GR 60
2. TOP SLAB IS DESIGNED FOR 10'-0" MAX COVER FOR TYPE A AND 3'-0" MAX COVER FOR TYPE B
3. BASE IS DESIGNED FOR 20'-0" MAX COVER
4. HEIGHT 8'-0" TO 12'-0":  
MIN REQUIRED SOIL BEARING = 3300 LBS/SQ FT
5. HEIGHT 12'-0" TO 20'-0":  
MIN REQUIRED SOIL BEARING = 3800 LBS/SQ FT





REF STD SPEC SEC 7-05



City of Seattle

NOT TO SCALE

TYPE 203 MANHOLE  
TOP & BOTTOM SLABS



## NOTES:

1. TYPE A MH DESIGNATES A MH TOP SLAB WITH A 4'-0" DIA ACCESS.
2. TYPE B MH DESIGNATES A MH TOP SLAB WITH A 2'-0" DIA ACCESS.
3. TOP SLAB AND BASE SECTION DETAILS, SEE STD PLAN NO 204.B.
4. MAX DIMENSION FROM OUTSIDE MH WALL TO THE FIRST PIPE JOINT. THE GREATER OF 1/2 INSIDE PIPE DIAMETER OR 1'-0".
5. TOTAL HEIGHT OF FRAME EXTENSIONS, MH FRAME AND COVER, AND LEVELING BRICKS SHALL NOT EXCEED 2'-2".
6. MH BASE SECTIONS SHOWN IN SECTION A-A AND SECTION B-B ARE TYPICAL FOR TYPE A AND TYPE B MHS.
7. MAX HOLE SIZE IS EQUAL TO THE OUTSIDE DIAMETER OF THE PIPE PLUS THE MH WALL THICKNESS. MIN DISTANCE BETWEEN HOLES IS 1'-0".


REF STD SPEC SEC 7-05



City of Seattle




NOT TO SCALE

TYPE 204 MANHOLE



## NOTES:

1. MATERIAL: CONCRETE—CLASS AX  
REINFORCING STEEL—ASTM A 615 GR 60
2. TOP SLAB IS DESIGNED FOR 10'-0" MAX COVER FOR TYPE A AND 3'-0" MAX COVER FOR TYPE B
3. BASE IS DESIGNED FOR 20'-0" MAX COVER
4. HEIGHT 8'-0" TO 12'-0":  
MIN REQUIRED SOIL BEARING = 3300 LBS/SQ FT
5. HEIGHT 12'-0" TO 20'-0":  
MIN REQUIRED SOIL BEARING = 3800 LBS/SQ FT




REF STD SPEC SEC 7-05



City of Seattle

NOT TO SCALE

TYPE 204 MANHOLE  
TOP & BOTTOM SLABS

**NOTES:**

1. TYPE A MH DESIGNATES A MH TOP SLAB WITH A 4'-0" DIA ACCESS.
2. TYPE B MH DESIGNATES A MH TOP SLAB WITH A 2'-0" DIA ACCESS.
3. TOP SLAB AND BASE SECTION DETAILS, SEE STD PLAN NO 205b.
4. MAX DIMENSION FROM OUTSIDE MH WALL TO THE FIRST PIPE JOINT. THE GREATER OF 1/2 INSIDE PIPE DIAMETER OR 1'-0".
5. TOTAL HEIGHT OF FRAME EXTENSIONS, MH FRAME AND COVER, AND LEVELING BRICKS SHALL NOT EXCEED 2'-2".
6. MH BASE SECTIONS SHOWN IN SECTION A-A AND SECTION B-B ARE TYPICAL FOR TYPE A AND TYPE B MHS.
7. MAX HOLE SIZE IS EQUAL TO THE OUTSIDE DIAMETER OF THE PIPE PLUS THE MH WALL THICKNESS. MIN DISTANCE BETWEEN HOLES IS 1'-0".

REF STD SPEC SEC 7-05





City of Seattle

NOT TO SCALE


TYPE 205 MANHOLE

## REV DATE: 2003



NOT TO SCALE

TYPE 205 MANHOLE  
TOP & BOTTOM SLABS



## NOTES:

1. TYPE A MH DESIGNATES A MH TOP SLAB WITH A 4'-0" DIA ACCESS.
2. TYPE B MH DESIGNATES A MH TOP SLAB WITH A 2'-0" DIA ACCESS.
3. TOP SLAB AND BASE SECTION DETAILS, SEE STD PLAN NO 206b.
4. MAX DIMENSION FROM OUTSIDE MH WALL TO THE FIRST PIPE JOINT, THE GREATER OF 1/2 INSIDE PIPE DIAMETER OR 1'-0" EXCEPT PVC AND CMP.
5. TOTAL HEIGHT OF FRAME EXTENSIONS, MH FRAME AND COVER, AND LEVELING BRICKS SHALL NOT EXCEED 2'-2".
6. MH BASE SECTIONS SHOWN IN SECTION A-A AND SECTION B-B ARE TYPICAL FOR TYPE A AND TYPE B MHS.
7. MAX HOLE SIZE IS EQUAL TO THE OUTSIDE DIAMETER OF THE PIPE PLUS THE MH WALL THICKNESS. MIN DISTANCE BETWEEN HOLES IS 1'-0".

REF STD SPEC SEC 7-05





City of Seattle


NOT TO SCALE

TYPE 206 MANHOLE




## REV DATE: 2003






SECTION B-B

NOTE:  
REINFORCING STEEL SHALL BE  
DEFORMED BARS CONFORMING TO  
ASTM A 615 GR 60 AND SHALL  
HAVE A MIN COVER OF 2"



SECTION A-A



SECTION THRU C


REF STD SPEC SEC 7-05



City of Seattle

NOT TO SCALE

TYPE 207 MANHOLE

**NOTES:**

1. NEW MANHOLE STEPS AND HANDHOLDS SHALL BE INSTALLED AND LOCATED 1'-0" OC FROM THE FIRST EXISTING STEP IN THE MANHOLE AND SHALL MATCH THE EXISTING TYPE OF STEP. ANY SUBSTITUTIONS SHALL BE APPROVED BY THE ENGINEER. A MINIMUM 1'-9" CLEAR OPENING SHALL BE MAINTAINED.
2. FOR 7" RIGID PAVEMENT, THE RING AND COVER SHALL BE CONSTRUCTED TO THE FINISHED GRADE OF THE PAVEMENT. REINFORCEMENT SHALL BE PLACED AROUND THE CASTING AT MID-POINT BETWEEN THE FINISH GRADE OF THE RIGID PAVEMENT AND THE TOP OF THE FLANGE. #4 REINFORCING BARS SHALL BE USED IN THE CONFIGURATION OF 2 SEPARATE SQUARES OFF-ROTATED 45 DEGREES FROM EACH OTHER AND GIVING A MINIMUM CLEARANCE OF 2" AT THE SHORTEST DISTANCE WITH THE FRAME.
3. FOR PAVEMENT DEPTH GREATER THAN 7", USE FRAME EXTENSION(S) AS SHOWN IN STANDARD PLAN NO 231 TO BRING THE COVER UP TO THE LEVEL OF THE FINISHED PAVEMENT WITHOUT EMBEDDING BOTTOM FLANGE OF THE CASTING IN THE PAVEMENT.


REF STD SPEC SEC 7-05



City of Seattle

NOT TO SCALE

REBUILD EXISTING  
BRICK MANHOLE

**NOTES:**

1. DESIGNATE LOCKING COVER AS TYPE 230L FOR USE IN NON-VEHICULAR TRAFFIC AREAS.
2. FOR 7" RIGID PAVEMENT, THE FRAME AND COVER SHALL BE CONSTRUCTED TO THE FINISHED GRADE OF THE PAVEMENT. REINFORCEMENT SHALL BE PLACED AROUND THE CASTING AT MID-POINT BETWEEN THE FINISHED GRADE OF THE PAVEMENT AND THE TOP OF THE FLANGE. #4 REINFORCING BARS SHALL BE USED IN THE CONFIGURATION OF 2 SEPARATE SQUARES OFF-ROTATED 45 DEGREES FROM EACH OTHER AND GIVING A CLEARANCE OF 2 INCHES AT THE SHORTEST DISTANCE WITH THE FRAME
3. FOR RIGID PAVEMENT DEPTH GREATER THAN 7", USE FRAME EXTENSION(S) (STANDARD PLAN NO 231) TO BRING THE COVER UP TO THE LEVEL OF THE FINISHED PAVEMENT WITHOUT EMBEDDING THE BOTTOM FLANGE OF THE CASTING IN THE PAVEMENT
4. COVER THICKNESS IS MEASURED FROM THE BOTTOM OF THE PATTERN
5. REFER TO SECTION 5-05 FOR OTHER REQUIREMENTS FOR REINFORCING BARS
6. FRAMES SHALL BE MANUFACTURED FROM CAST IRON OR DUCTILE IRON
7. COVERS SHALL BE MANUFACTURED FROM DUCTILE IRON


REF STD SPEC SEC 7-05



City of Seattle

NOT TO SCALE

2'-0" DIAMETER  
FRAME & COVER



SECTION OF FRAME EXTENSION

- NOTES:
- 1. DIMENSION "A" REFERS TO HEIGHT OF FRAME EXTENSION ABOVE MANHOLE FRAME
  - 2. DIMENSIONS "B", "C" AND "D" SHALL MATCH THE MANHOLE FRAME AND COVER THAT THE FRAME EXTENSION TO BE USED ON
  - 3. WHEN FRAME EXTENSIONS ARE USED ON A NEW MANHOLE FRAME AND COVER, THE FRAME EXTENSION SHALL BE PERMANENTLY ATTACHED TO THE MANHOLE FRAME AT THE FACTORY, NOT IN THE FIELD. APPROVAL OF ATTACHMENT METHOD IS REQUIRED
  - 4. FRAME EXTENSIONS SHALL BE DUCTILE OR CAST IRON



REF STD SPEC SEC 7-20



City of Seattle

NOT TO SCALE

FRAME EXTENSIONS



- NOTE:**
- 1. DIMENSIONS FOR THE MH LADDER AND STEP ARE MINIMUM REQUIREMENTS ONLY.
  - 2. STEPS AND HANDHOLDS SHALL BE INSTALLED AT 1'-0" SPACING. WHEN THE DISTANCE FROM THE LAST (HIGHEST) STEP OR HANDHOLD TO THE TOP OF THE MH FRAME EXCEEDS 1'-0" AND ANOTHER STEP OR HANDHOLD CANNOT BE INSTALLED BECAUSE OF THE LOCATION OF THE MH FRAME, A HANDHOLD SHALL BE INSTALLED BETWEEN THE TOP 2 LAYERS OF BRICK.
  - 3. IF BOTH STEPS AND LADDER ARE REQ'D IN ANY MH, THEY SHALL BE FROM THE SAME MANUFACTURER.

REF STD SPEC SEC 7-05



City of Seattle

NOT TO SCALE

MANHOLE LADDER,  
STEP AND HANDHOLD



1. CONCRETE FOR DROP CONNECTION SUPPORT SHALL BE CL 5 (11/2)
2. DUCTILE IRON PIPE SHALL BE ANSI/AWWA C151/A21.51 CL 50. DUCTILE IRON FITTINGS SHALL BE ANSI/AWWA C111/A21.11
3. BACKFILL AND COMPACT SPACE AROUND DROP CONNECTION WITH SELECTED MATERIAL OR TYPE 17 MINERAL AGGREGATE
4. DROP CONNECTIONS SHALL BE USED WHERE DROP IS NOT MORE THAN 20'-0"
5. ADDITIONAL PIPES MAY BE REQUIRED FOR DROP CONNECTION TO ENTER MANHOLE STRUCTURE (SEE DRAWINGS)


DUCTILE IRON OUTSIDE DROP CONNECTION

REF STD SPEC SEC 7-08



City of Seattle

### OUTSIDE DROP CONNECTION

**NOTE:**

1. PROVIDE PIPE MANUFACTURER RECOMMENDATION FOR PIPE HANGER AND CONCRETE ANCHORAGE TO SPU FOR APPROVAL.
2. SIZE MH TO MEET MINIMUM INSIDE CLEARANCE.
3. CLEAN-OUT SHALL BE LOCATED OPPOSITE OF MH ACCESS.
4. DUCTILE IRON PIPE C151/A21.51 CL 50, DUCTILE IRON FITTINGS SHALL BE ANSI/AWWA 6111/A21.11
5. PVC PIPE & ELBOW ASTM D 2241 CL200

**INSIDE DROP**

(18" DIAMETER PIPE MAXIMUM)

REF STD SPEC SEC 7-08




City of Seattle



NOT TO SCALE

INSIDE DROP CONNECTION



**NOTES:**

1. PIPE AND FITTINGS SHALL BE PVC PER ASTM D 3034 SDR 35
2. ALL PIPES AND FITTINGS ARE TO BE THE SAME DIAMETER. THE DIAMETER IS TO BE SPECIFIED ON THE PLANS
3. PVC TEE INSERTS SHALL BE BY "INSERT A TEE" OR EQUAL AND SHALL INCLUDE RUBBER SLEEVE, PVC ADAPTER HUB AND STAINLESS STEEL BAND. INSERT SHALL BE INSTALLED IN A CORE DRILLED HOLE PER MANUFACTURER'S INSTRUCTIONS. INSERT SHALL BE FLUSH WITH THE INSIDE WALL OF THE MAIN.
4. LOCATE EDGE OF CORE DRILLED HOLE 1'-0" MINIMUM FROM EXISTING PIPE JOINT AND 2'-0" FROM THE EDGE OF ANY EXISTING OR NEW CONNECTIONS
5. VERTICAL CONNECTION SHALL NOT BE USED UNLESS DEPTH FROM SURFACE TO TOP OF PIPE IS 20'-0" OR GREATER
6. VERTICAL CONNECTIONS ON MAINS OTHER THAN CONCRETE, CLAY OR BRICK CONSTRUCTION SHALL BE PER DRAWINGS
7. CONCRETE HAUNCHING IS TO BE CLASS 5 (1 1/2) CONCRETE



REF STD SPEC SEC 7-08 &amp; 7-17




City of Seattle

NOT TO SCALE

6" OR 8" VERTICAL CONNECTION

# STANDARD PLAN NO 240

REV DATE: 2003



## NOTES:

1. FRAME & GRATE OR FRAME & COVER SHALL BE LOCATED OVER TRAP
2. INVERT OF INLET PIPE SHALL BE 2" MIN ABOVE INVERT OF OUTLET PIPE
3. FRAME AND GRATE SHALL BE LOCATED OVER OUTLET TRAP



REF STD SPEC SEC 7-05




City of Seattle

NOT TO SCALE

TYPE 240 CATCH BASIN




SECTION D-D



## NOTES:

1. THIS CATCH BASIN IS FOR INSTALLATIONS IN ALLEYS AND UNPAVED AREAS IN THE RIGHT-OF-WAY. ANY OTHER USE IN THE R/W WILL REQUIRE APPROVAL OF SPU
2. FOR CURB DISCHARGE INSTALLATION SEE STD PLAN NO 241b
3. INSTALL PER STD PLAN NO 261
4. MATERIAL: CONCRETE CLASS AX REINFORCING STEEL ASTM A615 GR60
5. INLET INVERT EL. TO BE HIGHER THAN OUTLET INVERT EL.




REF STD SPEC SEC 7-05






City of Seattle

NOT TO SCALE

TYPE 241 CATCH BASIN



PLAN



REF STD SPEC SEC 7-05 & 7-08




City of Seattle

NOT TO SCALE

TYPE 241 CATCH BASIN  
INSTALLATIONS

## REV DATE: 2005




1. MATERIAL: CONCRETE: CLASS AX  
REINFORCING STEEL: ASTM A 615 GR 60
2. INSTALL & LOCATE PER STD PLANS  
NOS 260 & 261
3. A.1 OR B.1 CAN ONLY BE USED WHEN  
SPECIFIED ON CONTRACT PLANS
4. FOR TYPE 242A.1 OR B.1 ROTATE  
CATCH BASIN 180° FROM STANDARD.  
SEE STD PLAN NO 260
5. OUTLET TRAP TO BE LOCATED DIRECTLY  
BELOW FRAME AND GRATE

## TYPE 242 CATCH BASIN

# STANDARD PLAN NO 243a

REV DATE: 2003




REF STD SPEC SEC 7-05




City of Seattle

NOT TO SCALE

PRECAST CATCH BASIN  
TOP SLAB



- NOTES:
1. CONCRETE: CLASS AX
  2. REINFORCING STEEL: ASTM A615 GR 60



REF STD SPEC SEC 7-05




City of Seattle

NOT TO SCALE

PRECAST CATCH BASIN  
EXTENSION RISERS


# STANDARD PLAN NO 250

REV DATE: 2003




SECTION A-A

NOTE:  
INSTALL AND LOCATE  
PER STD PLAN NO 260



SECTION B-B



SECTION C-C  
TYPE A ONLY

REF STD SPEC SEC 7-05




City of Seattle

NOT TO SCALE

TYPE 250 INLET











REF STD SPEC SEC 7-05



City of Seattle

NOT TO SCALE

TYPE 252 INLET



**NOTE**

INLET/CB SHALL NOT BE PLACED IN CROSSWALKS OR IN FRONT OF WHEELCHAIR RAMPS


REF STD SPEC SEC 7-05




City of Seattle

NOT TO SCALE


INLET / CATCH BASIN LOCATION & INSTALLATION



TYPE 242A CB  
(TYPE 250A INLET SIMILAR)  
NOTE - TYPE 240C GRATE




TYPE 242B CB  
(TYPE 250B INLET SIMILAR)



TYPE 242A.1 CB

#### NOTES:

1. TYPE 242A.1 OR B.1 INSTALLATION IS ROTATED 180° FROM TYPE 242A OR 242B
2. A.1 IS SHOWN, B.1 IS SIMILAR
3. A.1 OR B.1 CAN ONLY BE USED WHEN SPECIFIED ON DRAWINGS



CURB DETAIL (PLAN VIEW) FOR  
TYPE 242B CB & TYPE 250B INLET



REF STD SPEC SEC 7-05




City of Seattle

NOT TO SCALE

CATCH BASIN &  
INLET INSTALLATION



SECTION C-C



SECTION D-D

**NOTES:**

1. CONNECTIONS SHALL MAINTAIN A MINIMUM OF 2% AND A MAXIMUM OF 50% GRADE
2. TYPE A CONNECTION MAY BE USED UNDER THE FOLLOWING CIRCUMSTANCES:
  - A. THE MAXIMUM OF 50% GRADE IS NOT EXCEEDED
  - B. THERE IS NO INTERFERENCE WITH EXISTING OR PROPOSED UTILITIES


REF STD SPEC SEC 7-08



City of Seattle

NOT TO SCALE

TYPICAL CATCH BASIN  
CONNECTION






REF STD SPEC SEC 9-12



City of Seattle

NOT TO SCALE

TYPE 262 INLET FRAME



REF STD SPEC SEC 9-12



City of Seattle

NOT TO SCALE


TYPE 263 INLET FRAME

## REV DATE: 2003




### INLET FRAME & GRATE

## REV DATE: 2003




VANED GRATE





TYPE A

FOR USE WITH OUTLET PIPE WHICH SLOPES 10% OR LESS



TYPE B

FOR USE WITH OUTLET PIPE WHICH SLOPES MORE THAN 10%

NOTES:

1. TRAP TO BE MADE OF 22 GA (0.0336") GALVANIZED SHEET METAL OR 18 GA (0.05") ALUMINUM
2. ALL JOINTS TO BE SEAMED AND SOLDERED, OR WELDED
3. ALL LONGITUDINAL JOINTS TO BE RIVETED OR WELDED
4. DIAMETER "D" IS NOMINAL DIAMETER OF OUTLET PIPE


REF STD SPEC SEC 9-12




City of Seattle

NOT TO SCALE


OUTLET TRAP




PLAN  
TYPE C TRAP




PLAN  
TYPE D TRAP




SECTION A-A



SECTION B-B



TRAP HOOK  
TRAP HOOKS MAY BE ROUND  
OR SQUARE IN CROSS-SECTION



TRAP INSTALLATION

- NOTES:
1. TYPE 267C TRAP TO BE USED WITH 8" ID OUTLET PIPE.  
TYPE 267D TRAP TO BE USED WITH 4" OR 6" ID OUTLET PIPE
  2. TRAP MAY BE CAST IRON ASTM A 48 CLASS 25 OR CAST STEEL ASTM A 27 GRADE 70-36
  3. TRAP AND TRAP HOOK TO HAVE A BITUMINOUS COATING INSIDE AND OUT




REF STD SPEC SEC 7-05



City of Seattle

NOT TO SCALE

OUTLET TRAP  
(FOR DOPAR USE ONLY)



THESE DIMENSIONS MAY BE CHANGED IF  
NECESSARY TO FIT EXISTING CASTINGS

REF STD SPEC SEC 9-05




City of Seattle


NOT TO SCALE

EXTENSION FOR INLET

## REV DATE: 2003





PIPE SUPPORT  
DETAIL B





DETAIL C

\*SPECIFIC DESIGN INFORMATION AS INDICATED ON CONSTRUCTION DRAWINGS  
NOTE - INVERT OF DETENTION PIPE HIGHER THAN INVERT OF OUTLET PIPE

## FLOW CONTROL STRUCTURE



TYPE A



TYPE B

NOTE:  
FOR D1, D2, t, S, S1, N & W  
VALUES AND GENERAL NOTES SEE  
STD PLAN NO 271c


REF STD SPEC SEC 7-16




City of Seattle

NOT TO SCALE

DETENTION STRUCTURE END  
PLATE DETAILS

**NOTE:**

FOR D1, D2, t, S, S1, N & W  
VALUES AND GENERAL NOTES SEE  
STD PLAN NO 271c

**TYPE C**

REF STD SPEC SEC 7-16



City of Seattle

NOT TO SCALE

DETENTION STRUCTURE END  
PLATE DETAILS

PIPE DIAMETER		END PLATE THICKNESS	STIFFENER TYPE & SIZE	STIFFENER SPACING			SIZE W
D1	D2			t	S1	S	
TYPE A							
30"	—	1/4"	FLAT 2 1/2" X 1/4"	6"	6"	3	3/16"
36"	—	1/4"	FLAT 3" X 1/4"	6"	6"	4	3/16"
48"	—	1/4"	FLAT 4 1/4" X 1/4"	8"	8"	4	3/16"
60"	—	3/8"	L 2 1/2" X 2" X 3/8"	10"	10"	4	1/4"
72"	—	3/8"	L 3" X 3" X 3/8"	6"	10"	6	1/4"
TYPE B							
30"	6"	1/4"	FLAT 2 1/2" X 1/4"	5 1/2"	5 1/2"	3	3/16"
	8"			5"	5"	3	
	12"			4"	6"	2	
36"	6"	1/4"	FLAT 3" X 1/4"	6"	5 1/2"	4	3/16"
	8"			6"	5"	4	
	12"			5 1/2"	5 1/2"	3	
48"	6"	1/4"	FLAT 4 1/4" X 1/4"	8"	8"	4	3/16"
	8"			6"	8"	4	
	12"			4"	7 1/2"	4	
60"	6"	3/8"	L 2 1/2" X 2" X 3/8"	7"	9"	5	1/4"
	8"			10"	10"	4	
	12"			6"	10"	4	
72"	6"	3/8"	L 3" X 3" X 3/8"	8"	8"	7	1/4"
	8"			8"	9"	6	
	12"			8"	10"	5	
TYPE C							
48"	30"	1/4"	FLAT 4 1/4" X 1/4"	2"	8"	1	3/16"
60"	36"	3/8"	L 2 1/2" X 2" X 3/8"	2"	7"	2	1/2"
72"	36"	3/8"	L 2" X 3" X 3/8"	3"	8 1/2"	3	1/4"

NOTES:

- DESIGNS VALID FOR PIPE INSTALLED WITH 6'-0" OR LESS OF COVER FROM CROWN OF PIPE TO GRADE. MAXIMUM WATER SURCHARGE 3'-0" ABOVE CROWN OF PIPE
- END PLATE MATERIAL: ALUMINUM 6061-T6
- DESIGNS SHALL BE USED ONLY FOR ALUMINUM CMP

REF STD SPEC SEC 7-16




City of Seattle

NOT TO SCALE


DETENTION STRUCTURE END  
PLATE DETAILS

# STANDARD PLAN NO 272a


REV DATE: 2003




CONNECTION & CONTROL DEVICE  
DETAIL A



PIPE SUPPORT  
DETAIL B



PLAN



ELEVATION

FLOW CONTROL STRUCTURE & DETENTION PIPE

DETENTION PIPE DIAMETER	FCS * (MH SIZE)	UPSTREAM * (MH SIZE)
18"	201B	201A OR B
24"	201B	201A OR B
30"	202B	202B
36"	202B	202B
48"	203B	203B
60"	204B	204B
72"	205B	205B

\*SPECIFIC DESIGN INFORMATION AS INDICATED ON  
CONSTRUCTION DRAWINGS

REF STD SPEC SEC 7-16




City of Seattle

NOT TO SCALE

FLOW CONTROL STRUCTURE  
(CONC OR DIP DETENTION PIPE)






TOP VIEW


DIA	A	B*	C*
4"	4 1/2"	8"	2"
6"	6 5/8"	10"	2 1/2"
8"	8 5/8"	12"	3"
10"	10 3/4"	14"	3"
12"	12 3/4"	16"	3"

\*MINIMUM

DIA=OUTLET PIPE DIAMETER



FRONT VIEW



SIDE VIEW

REF STD SPEC SEC 7-16




City of Seattle

NOT TO SCALE

PVC SHEAR GATE


## REV DATE: 2003



## TYPE 277 JUNCTION BOX & INSTALLATION

STANDARD PLAN NO 278

REV DATE: 2003





REF STD SPEC SEC 7-19 & 7-16.2



City of Seattle

NOT TO SCALE

VERTICAL CLEAN OUT/  
CORRUGATED METAL PIPE



## SECTION A-A

## NOTES:

1. CORRUGATED FLANGE PLATE AND NON-CORRUGATED PIPE TO BE SAME MATERIAL AND HAVE SAME COATING AS CMP
2. BOLTS TO BE GALV STEEL MEETING ASTM A 307 OR STAINLESS STEEL MEETING ASTM A 193

REF STD SPEC SEC 7-17 &amp; 7-16.2




City of Seattle

NOT TO SCALE

TEE INSTALLATION  
CORRUGATED METAL PIPE

# STANDARD PLAN NO 280

REV DATE: 2003




REF STD SPEC SEC 7-19



City of Seattle

NOT TO SCALE

8" CLEAN-OUT




REF STD SPEC SEC 7-16.2 &amp; 9-05



City of Seattle

NOT TO SCALE

CORRUGATED METAL  
PIPE COUPLING BANDS





REF STD SPEC SEC 7-16.2 & 9-05



City of Seattle

NOT TO SCALE

CORRUGATED METAL  
PIPE COUPLING BANDS



FOR PIPES 48" DIAMETER & LARGER  
(HELICAL OR ANNULAR)

REF STD SPEC SEC 7-16.2 & 9-05





City of Seattle

NOT TO SCALE

CORRUGATED METAL  
PIPE COUPLING BANDS





FOR PIPES 48" DIAMETER & LARGER  
(HELICAL OR ANNULAR)


REF STD SPEC SEC 7-16.2 & 9-05



City of Seattle

NOT TO SCALE

CORRUGATED METAL  
PIPE COUPLING BANDS

**NOTES:**

1. ALL HOUSE PLUMBING OUTLETS MUST BE CONNECTED TO THE SEWER. NO DOWNSPOUTS OR STORM DRAINAGE MAY BE CONNECTED, EXCEPT TO A SEPARATE STORM DRAINAGE SYSTEM.
  2. 2'-6" MIN DISTANCE FROM HOUSE, EXCEPT FOR SOIL PIPE CONNECTION.
  3. 1'-6" MIN COVER OF PIPE.
  4. 2'-6" MIN COVER AT PROPERTY LINE.
  5. 5'-0" MIN COVER AT CURB LINE.
  6. LAY PIPE IN STRAIGHT LINE BETWEEN BENDS. MAKE ALL CHANGES IN GRADE OR LINE WITH BENDS OR WYES.
  7. STANDARD 4" TO 6" INCREASER.
  8. 6" SEWER PIPE: MIN SIZE IN STREET, AND ELSEWHERE AS DIRECTED. 2% MIN GRADE, 100% MAX.
  9. 4" SEWER PIPE: MIN SIZE ON PROPERTY. 2% MIN GRADE, 100% (45°) MAX.
  10. TEST "T" WITH PLUG
  11. REMOVABLE PLUG.
- A. CONSTRUCTION IN STREET MUST BE DONE BY A LICENSED SIDE SEWER CONTRACTOR.  
 B. ALL CONSTRUCTION SHALL BE IN ACCORDANCE WITH CURRENT SIDE SEWER ORDINANCES.  
 C. ALL CONSTRUCTION REQUIRES A PERMIT AND PAYMENT OF FEE. COMPLETE LEGAL DESCRIPTIONS OF PROPERTY AND DIMENSIONS A, B, C AND D THAT SHOW THE SIZE AND LOCATION OF THE HOUSE ARE REQUIRED FOR ISSUANCE OF THE PERMIT.  
 D. ORDINANCE 97016 APPLIES TO INSTALLATION OF SIDE SEWER.


REF STD SPEC SEC 7-18



City of Seattle

NOT TO SCALE

SIDE SEWER INSTALLATION



TYPICAL TRENCH SECTION  
(SEWER & STORM DRAIN)

NOTE:  
FOR PAVEMENT REMOVAL  
AND RESTORATION SEE  
STD PLAN NO 404

REF STD SPEC SEC 7-17




City of Seattle

NOT TO SCALE


TYPICAL SEWER TRENCH SECTION

# STANDARD PLAN NO 285


REV DATE: 2003




CLASS A BEDDING  
(CONCRETE BEDDING)



CLASS B BEDDING



CLASS C BEDDING



CLASS D BEDDING



MINERAL AGGREGATE PER STD SPEC 4-01  
TYPE 9 FOR RIGID PIPE  
TYPE 22 FOR FLEXIBLE PIPE



CONCRETE  
(4 SACK MIN 1 1/2" MAX AGGREGATE)



SELECTED NATIVE MATERIAL

## NOTES:

1. FOR TRENCH WIDTH SEE STD PLAN NO 284
2. A=4" WHEN ID IS LESS THAN 2'-6"
- A=6" WHEN ID IS 2'-6" OR MORE
3. FOR CLASS D BEDDING EXCAVATE FOR BELL

REF STD SPEC SEC 7-17




City of Seattle

NOT TO SCALE


PIPE BEDDING  
SEWER / STORM DRAIN

## NOTES


1. EXCEPTIONS TO STD PLAN NO. 286 SHALL BE APPROVED BY SEATTLE PUBLIC UTILITIES, WATER QUALITY DIVISION.
2. "SEWER" INCLUDES SANITARY SEWER, COMBINED SEWER AND SIDE SEWER.
3. WHERE MINIMUM CLEARANCES CANNOT BE MET, SEWER SHALL BE CONSTRUCTED OF MATERIALS AND WITH JOINTS THAT ARE EQUIVALENT TO WATER MAIN STANDARDS INCLUDING WATER MAIN PRESSURE TESTING REQUIREMENTS.
4. NO VERTICAL CLEARANCE REQUIRED.
5. IF MINIMUM VERTICAL SEPARATION CANNOT BE MET, WATER MAIN SHALL BE A STANDARD SINGLE 18'-0" NOMINAL LENGTH DUCTILE IRON WATER MAIN SECTION CENTERED AT THE POINT OF CROSSING.
6. SEWER SHALL HAVE ADEQUATE FOUNDATION SUPPORT TO PREVENT SETTLEMENT ON THE WATER MAIN AND TO PREVENT DEFLECTION OF WATER MAIN JOINTS.
7. CROSSINGS AT AN ANGLE BETWEEN 90° AND 45° MAY OCCUR BETWEEN 9'-0" AND 6'-0" OF WATER MAIN JOINT. FOR CROSSINGS LESS THAN 45°, SEE NOTE 1.
8. ORDINANCE 97016 APPLIES TO SIDE SEWERS. SEE STD SPEC SEC 1-07.17(2)A.



PARALLEL INSTALLATION



CROSSING WATER OVER SEWER



STANDARD SINGLE 18'-0" NOMINAL LENGTH DUCTILE IRON WATER MAIN SECTION CENTERED AT THE POINT OF CROSSING

CROSSING WATER UNDER SEWER

REF STD SPEC SEC 1-07.17 &amp; 7-11




City of Seattle

NOT TO SCALE

SEWER & WATER  
SPACING & CLEARANCES

STANDARD PLAN NO 286b

REV DATE: 2003



REF STD SPEC SEC 1-07.17 & DIV 7




City of Seattle

NOT TO SCALE

SEWER & WATER  
SPACING & CLEARANCES


## REV DATE: 2003



1. ALL 1/4" STEEL & L3"x 2"x 1/2" TO BE A-36.
2. 6"Ø PIPE TO BE STANDARD WEIGHT STEEL.
3. AFTER FABRICATION, DRAIN ASSEMBLY TO BE HOT DIP GALVANIZED.
4. VANED GRATE TO BE PER STD PLAN NO 265.

NOT TO SCALE

BRIDGE DRAIN

NOTES:

1. ASTM D 2241 SDR 21 CLASS 200 PVC PIPE.
2. SLOT DIMENSIONS ARE 0.040" WIDE X 1.00" LONG  
SPACED ALONG PIPE AT 0.25" ON CENTER

REF STD SPEC SEC 9-05 .3(1)






City of Seattle

NOT TO SCALE

PVC SUBSURFACE DRAIN PIPE



**NOTES**

1. ALL FITTINGS SHALL BE DUCTILE IRON
2. ALL EXCAVATION SHALL PROVIDE A MINIMUM OF 1'-0" CLEAR AROUND PIPE AND FITTINGS.
3. THESE PLANS ARE FOR DIP AND CIP WATERMAINS 12" OR SMALLER DIA OTHER SIZES AND TYPES SEE PROJECT DRAWINGS
4. REDUCED PRESSURE BACKFLOW ASSEMBLY (RPBA) SHALL BE INSTALLED AS A UNIT (TWO SHUT-OFF VALVES, RELIEF PORT, TWO CHECK VALVES AND FOUR TEST COCKS). WHEN RPBA IS CONNECTED TO HYDRANT AND THE HOSE BIB FAUCET SAMPLE THEY SHALL BE CAPPED WHEN NOT IN USE. ASSEMBLY SHALL BE TESTED WHEN INSTALLED BY A WASHINGTON STATE CERTIFIED BACKFLOW ASSEMBLY TESTER (BAT) AND A CURRENT TEST REPORT SHALL BE ON SITE. FOR INSTALLATION PROCEDURES CALL 684-3536.

**LEGEND**

- ① CLEAN & DISINFECTED POTABLE WATER HOSE ONLY. SIZE FLUSHING RISER PER TABLE IN STD SPEC SEC 7-11.3(12)
- ② HYDRANT PERMIT REQUIRED
- ③ CHECK WITH SEWER UTILITY BEFORE DISCHARGE TO SEWERS
- ⑥ CONTRACTOR TO DETERMINE ALIGNMENT & GRADE OF EXISTING PIPE PRIOR TO INSTALLING NEW WATERMAIN. ENGINEER TO DETERMINE OUTSIDE DIAMETER OF EXISTING PIPE WHEN CONTRACTOR EXCAVATES TO DETERMINE ALIGNMENT & GRADE.
- ⑦ ALL EXCAVATION, PIPE, FITTINGS (EXCEPT AS NOTED BELOW), OTHER MATERIAL, BEDDING, BACKFILL, COMPACTION & STREET RESTORATION BY CONTRACTOR. ALL MATERIALS SHALL BE ON JOB SITE PRIOR TO SHUTDOWN OF EXISTING MAIN.
- ③ INSTALLED BY CONTRACTOR
- ④ CONNECTION PIPE: CONTRACTOR FURNISHED, INSTALLED BY SPU
- ⑤ WATERMAIN WITH PLAIN ENDS
- ⑥ MECHANICAL JOINT SLEEVE WITH SPACER CUT TO FIT GAP, FURNISHED AND INSERTED AT TIME OF CONNECTION BY SPU
- ⑦ TAPPING SLEEVE & TAPPING VALVE FURNISHED AND INSTALLED BY SPU
- ⑧ APPLIES TO PIPES 4" THROUGH 12". ALL LARGER SIZES TO BE ADDRESSED ON DRAWINGS
- ⑨ MECHANICAL JOINT SLEEVE, FURNISHED BY CONTRACTOR AND INSTALLED BY SPU, SPACERS BY SPU WHERE REQUIRED

REF STD SPEC SEC 7-11



City of Seattle

NOT TO SCALE

CONNECTIONS TO  
EXISTING WATERMAINS


ELEVATION



TABLE


SIZE WATERMAIN	L1	L2
4" $\phi$ THRU 10" $\phi$	10'-0"	14'-0"
12" $\phi$	12'-0"	16'-0"
LARGER THAN 12" $\phi$	PER DRAWINGS	

PLAN




CONNECTIONS TO EXISTING MAIN, WITH A NEW TEE OR CROSS  
(CUT IN NEW TEE)

ELEVATION



PLAN



CONNECTIONS TO EXISTING MAIN, STUB  
OR END OUTLET OF TEE OR CROSS

REF STD SPEC SEC 7-11



FOR LEGEND AND NOTES SEE STD PLAN NO 300a



City of Seattle

NOT TO SCALE


CONNECTIONS TO  
EXISTING WATERMAINS



TABLE

SIZE WATERMAIN	DISTURBANCE ZONE
UP TO & INCLUDING 10" $\phi$	10'-0"
OVER 10" $\phi$	12'-0"

\* SPU MAY INCREASE DISTURBANCE ZONE.  
SEE CONTRACT DOCUMENTS



REF STD SPEC SEC 7-11


FOR LEGEND AND NOTES SEE STD PLAN NO 300a



City of Seattle

NOT TO SCALE

CONNECTIONS TO  
EXISTING WATERMAINS



REF STD SPEC SEC 7-14




City of Seattle

NOT TO SCALE

TYPE 310 HYDRANT SETTING DETAIL






REF STD SPEC SEC 7-14




City of Seattle

NOT TO SCALE



TYPE 311 HYDRANT SETTING DETAIL




ALTERNATE A  
TIEBOLT RESTRAINT



ALTERNATE B  
MECHANICAL JOINT GLAND W/LUGS



SECTION A-A



DETAIL C NOTES:

1. TO BE CAST OF DUCTILE IRON IN CONFORMANCE WITH ASTM A 536 CLASS 80-55-06
2. AFTER CLEANING, THE CASTING SHALL BE HOT DIPPED IN ASPHALTIC VARNISH, ROYSTON ROSKOTE #612XM
3. TOLERANCES PER DIPRA HANDBOOK


REF STD SPEC SEC 7-14



City of Seattle

NOT TO SCALE


TYPE 311 HYDRANT SETTING DETAIL



TRAFFIC ISLAND MARKER POST LAYOUT FOR  
FIRE HYDRANTS IN PARKING AREAS

### NOTES

1. LAYOUT OF MARKER POST SHALL BE VERIFIED FIRST WITH SPU AND SEATRAN
2. MARKER POST WITH HIGH INTENSITY REFLECTORIZED BANDS PROVIDED BY SPU



MARKER POST LAYOUT FOR  
FIRE HYDRANTS IN PARKING AREAS

REF STD SPEC SEC 7-14





City of Seattle

NOT TO SCALE

FIRE HYDRANT MARKER LAYOUT





REF STD SPEC SEC 2-08, 7-14 &amp; 8-15



City of Seattle

NOT TO SCALE

WALL REQUIREMENTS  
FOR HYDRANTS

# STANDARD PLAN NO 314

REV DATE: 2003

3'-0" MIN, 15'-0" MAX ON CORNERS  
7'-0" MAX MIDBLOCK

CURB OR EDGE OF  
TRAVELED PORTION  
OF ROADWAY

CORNER

R/W MARGIN

5'-0" STD  
5'-0" MIN

DRIVEWAY

## NOTES:

1. NO PARKING ZONE  
WITHIN 15'-0"  
RADIUS OF  
FIRE HYDRANT
2. MIN DISTANCE  
FROM BACK FACE OF  
HYDRANT TO FRONT  
EDGE OF CONCRETE  
WALK SHALL BE 2'-0"

R/W MARGIN

TREE

5'-0" MIN

LOT LINE

3'-0" MIN  
(TYP)  
OTHERWISE  
EASEMENT IS  
REQUIRED

10'-0" MIN

SIDE SEWER

10'-0" STD  
N OR E

CL STREET

UTILITY POLE, GUARD  
POST, BUILDING WALL  
OR ANY OTHER FIXED  
STRUCTURE

3'-0" CLR  
MIN

5'-0" STD

R/W MARGIN

SEE DETAIL A

MID-BLOCK

CORNER

FACE OF CURB

3'-0" MIN

1'-6"

2'-0"  
2'-0"

EXPANSION JOINT

SCORED SECTION  
OF CURB RAMP

DETAIL A  
HYDRANT NEAR CURB RAMP



REF STD SPEC SEC 7-14




City of Seattle

NOT TO SCALE

FIRE HYDRANT  
LOCATIONS & CLEARANCES



NOTE:  
VALVE BOX FOR USE ON 12" OR  
SMALLER VALVE INSTALLATIONS




REF STD SPEC SEC 7-12

FOR LEGEND  AND NOTES SEE STD PLAN NO 315b


City of Seattle

NOT TO SCALE


CAST IRON VALVE BOX &  
OPERATING NUT EXTENSION





OPERATING NUT EXTENSION DETAIL 1



SECTION B-B



EXTENSION PIECE 2 WHEN REQUIRED



PLASTIC FOAM RING DETAIL

NOTES:

1. FRAME AND COVER SHALL BE TESTED FOR ACCURACY OF FIT AND SHALL BE MARKED IN SETS FOR DELIVERY
2. CASTINGS AND EXTENSIONS SHALL BE HOT-DIPPED IN ASPHALTIC VARNISH ROYSTON ROSKOTE #612XM OR 2 COATS OF MASTIC ROYSTON INSIDE AND OUT.
3. VALVE BOXES SHALL BE RICH #045: TOP SECTION, LID AND BASE; OR OLYMPIC FOUNDRY: LID #1908-33, TOP SECTION #1106-33, BASE SECTION #1301-33
4. ALL CASTINGS SHALL BE DUCTILE OR GREY CAST IRON

LEGEND:

- 1 AN OPERATING NUT EXTENSION SHALL BE INSTALLED WHEN THE GROUND SURFACE IS MORE THAN 2'-6" ABOVE THE VALVE OPERATING NUT. THE OPERATING NUT EXTENSION SHALL EXTEND INTO THE TOP SECTION OF THE STANDARD VALVE BOX AND SHALL CLEAR THE BOTTOM OF THE LID BY 6" MIN
- 2 EXTENSION PIECES (WHEN USED) SHALL CONFORM TO MINIMUM THICKNESS REQUIREMENTS AND SHALL FIT INTO THE TOP SECTION AND OVER THE BOTTOM SECTION

REF STD SPEC SEC 7-12 & 9-30




City of Seattle

NOT TO SCALE


CAST IRON VALVE BOX & OPERATING NUT EXTENSIONS

# STANDARD PLAN NO 330a

REV DATE: 2003



TYPE A BLOCKING FOR 11 1/4° & 22 1/2° VERTICAL BENDS						
PIPE SIZE NOM DIA INCHES	TEST PRESSURE PSI	VB VERTICAL BEND DEGREES	NO OF CU FT OF CONC BLOCKING	S SIDE OF CUBE FEET	d DIA OF SHACKLE RODS (2) INCHES	L DEPTH OF RODS IN CONCRETE INCHES
4"	300	11 1/4	8	2	3/4	18
		22 1/2	12	2 1/4		24
6"	300	11 1/4	12	2 1/4	3/4	24
		22 1/2	27	3		
8"	300	11 1/4	16	2 1/2	3/4	24
		22 1/2	43	3 1/2		
12"	300	11 1/4	64	4	1	24
		22 1/2	125	5	1	36



TYPE B BLOCKING FOR 45° VERTICAL BENDS						
PIPE SIZE NOM DIA INCHES	TEST PRESSURE PSI	VB VERTICAL BEND DEGREES	NO OF CU FT OF CONC BLOCKING	S SIDE OF CUBE FEET	d DIA OF SHACKLE RODS (4) INCHES	L DEPTH OF RODS IN CONCRETE INCHES
4"	300	45	27	3	3/4	20
6"			64	4		
8"			125	5		
12"			216	6	1	30


FOR NOTES SEE STD PLAN NO 330b  
REF STD SPEC SEC 7-11



City of Seattle

NOT TO SCALE

WATERMAIN THRUST BLOCKING  
VERTICAL FITTINGS



TYPE C

TYPE "C" BLOCKING FOR 1 1/4", 2 1/2", 45° AND 90° VERTICAL BENDS									
THRUST BLOCK AREA IN SQUARE FEET									
SOIL	FIRM SILT OR FIRM SILTY SAND			COMPACT SAND			COMPACT SAND & GRAVEL		
FITTING	90° BEND	TEE 45° BEND & DEAD END	1 1/4" & 2 1/2" BEND	90° BEND	TEE 45° BEND & DEAD END	1 1/4" & 2 1/2" BEND	90° BEND	TEE 45° BEND & DEAD END	1 1/4" & 2 1/2" BEND
4"	5.8	4.2	1.7	2.9	2.1	1.0	2.2	1.6	1.0
6"	13.3	9.4	3.8	6.7	4.7	1.9	5.0	3.5	1.4
8"	23.3	16.7	6.7	11.7	8.4	3.4	8.8	6.3	2.5
12"	53.0	37.5	15.0	26.5	18.8	7.5	20.0	14.0	5.6
AREAS CALCULATED ON 300 PSI TEST PRESSURE AND 3'-0" MIN COVER OVER WATERMAIN									

## NOTES:

1. LOCATION AND SIZE OF BLOCKING FOR PIPE LARGER THAN 12" DIAMETER AND FOR SOIL TYPES DIFFERENT THAN SHOWN SHALL BE DETERMINED BY THE ENGINEER
2. ALL BLOCKING FOR VERTICAL FITTINGS (POURED IN PLACE) SHALL BEAR AGAINST UNDISTURBED NATIVE GROUND
3. ALL POURED THRUST BLOCKS SHALL BE BACKFILLED AFTER MIN. 1 DAY. PRESSURE TESTING SHALL OCCUR AFTER CONCRETE HAS REACHED f'c
4. ALL BLOCKING SHALL BE CONCRETE CL 5 (1 1/2)
5. AFTER INSTALLATION, SHACKLE RODS & TURNBUCKLES SHALL BE CLEANED AND COATED WITH 2 COATS OF ASPHALTIC VARNISH, ROYSTON ROYKOTE #612M OR APPROVED EQUAL
6. SHACKLE RODS SHALL BE FUSION BONDED EPOXY COATED ROUND MILD STEEL, ASTM A 36, WITH THREADS ON ENDS ONLY
7. BLOCKING AGAINST FITTINGS SHALL BEAR AGAINST THE GREATEST FITTING SURFACE AREA POSSIBLE, BUT SHALL NOT COVER OR ENCLOSE BELL ENDS, JOINT BOLTS OR GLANDS. REASONABLE ACCESS TO BOLTS AND GLANDS SHALL BE PROVIDED


REF STD SPEC SEC 7-11




City of Seattle

NOT TO SCALE


WATERMAIN THRUST BLOCKING  
VERTICAL FITTINGS




UNBALANCED CROSS




CROSS WITH PLUG




PLUGGED TEE



HORIZONTAL BEND



TEE




PIPE & CAP

THRUST BLOCK AREA IN SQUARE FEET (SEE STD PLAN NO 331b)														
PIPE SIZE	SOIL		FIRM SILT OR FIRM SILTY SAND				COMPACT SAND				COMPACT SAND & GRAVEL			
	FITTING	90° BEND	TEE	45° BEND CAP OR PLUG	11 1/4° & 22 1/2° BEND	90° BEND	TEE	45° BEND CAP OR PLUG	11 1/4° & 22 1/2° BEND	90° BEND	TEE	45° BEND CAP OR PLUG	11 1/4° & 22 1/2° BEND	
	4"	7.0	4.2	4.2	1.7	2.9	2.1	2.1	1.0	2.2	1.6	1.6	1.0	
	6"	13.3	9.4	9.4	3.8	6.7	4.7	4.7	1.9	5.0	3.5	3.5	1.4	
	8"	23.3	16.7	16.7	6.7	11.7	8.4	8.4	3.4	8.8	6.3	6.3	2.5	
	12"	53.0	37.5	37.5	15.0	26.5	18.8	18.8	7.5	20.0	14.0	14.0	5.6	
AREAS CALCULATED ON 300 PSI TEST PRESSURE AND 3'-0" MIN COVER OVER WATERMAIN														

ECOLGY BLOCKS, PER STD PLAN NO 460,  
MAY BE USED IN LIEU OF POURED-IN-PLACE  
BLOCKING FOR FITTINGS IN SHADED  
PORTION OF TABLE



**NOTES:**

1. LOCATION AND SIZE OF BLOCKING FOR PIPE LARGER THAN 12" DIAMETER AND FOR SOIL TYPES DIFFERENT THAN SHOWN SHALL BE DETERMINED BY THE ENGINEER.
2. ALL BLOCKING FOR HORIZONTAL FITTINGS (POURED IN PLACE) SHALL BEAR AGAINST UNDISTURBED NATIVE GROUND.
3. ALL POURED THRUST BLOCKS SHALL BE BACKFILLED AFTER MIN. 1 DAY. PRESSURE TESTING SHALL OCCUR AFTER CONCRETE HAS REACHED f'c.
4. ALL BLOCKING TO BE CONCRETE CL 5 (11/2).
5. BLOCKING AGAINST FITTINGS SHALL BEAR AGAINST THE GREATEST FITTING SURFACE AREA POSSIBLE, BUT SHALL NOT COVER OR ENCLOSE BELL ENDS, JOINT BOLTS OR GLANDS. ACCESS TO BOLTS AND GLANDS SHALL BE PROVIDED.
6. ALL HORIZONTAL BLOCKING THRUST AREAS SHALL BE CENTERED ON PIPE.
7. WHERE POURED-IN-PLACE BLOCKING IS REQUIRED AT A POINT OF CONNECTION TO AN EXISTING WATERMAIN, THE BLOCKING SHALL BE INSTALLED PRIOR TO CONNECTION.
8. TEMPORARY BLOCKING, IF USED, SHALL BE APPROVED BY ENGINEER.

REF STD SPEC SEC 7-11




City of Seattle

NOT TO SCALE

WATERMAIN THRUST BLOCKING  
HORIZONTAL FITTINGS





REF STD SPEC SEC 7-11



City of Seattle

NOT TO SCALE

2" BLOW OFF TYPE A  
NON TRAFFIC INSTALLATION

## REV DATE: 2003




WHERE TAPE-WRAPPED DUCTILE IRON  
PIPE IS USED, THE MECHANICAL JOINT  
CAP, CORP AND SADDLE (IF REQUIRED)  
SHALL BE WRAPPED PER AWWA C214



### 2" BLOW OFF DETAIL TYPE B TRAFFIC INSTALLATION

# STANDARD PLAN NO 350

REV DATE: 2003



REF STD SPEC SEC 7-10




City of Seattle

NOT TO SCALE

WATERMAIN TRENCH AND BEDDING


## REV DATE: 2003



NOT TO SCALE

## WATERMAIN ELECTROLYSIS TEST STATION

## REV DATE: 2003



Technical drawing of a circular manhole cover. The cover has a diameter of  $40'' \pm \text{DIA}$ . The central area features a grid pattern of raised bars, with the text "(LETTERING AS REQUIRED)" in the center. The grid bars are spaced at  $1\frac{1}{2}''$ . The cover is surrounded by a flange with six lifting lugs. The flange thickness is  $\frac{3}{4}''$ , and the distance from the center to the flange edge is  $4''$ . The cover is mounted on a base with a diameter of  $7\frac{1}{16}''$ . The base has a thickness of  $3''$ . The cover is secured by six bolts, each with a diameter of  $\frac{1}{4}''$ . The cover is labeled "6 SPACES @  $25\frac{1}{16}''$ ".

BAR  $3/4'' \phi$

$R=7/8''$

5  $1/2''$

2" SQUARE NUTS


RIVETED

6  $3/4''$

TYPE 361  
H=91/4"




DESIGNATE  
SHALLOW  
FRAME AS  
TYPE 361S  
H=41/4"

f=MACHINED  
FINISH




SECTION A-A


## TYPE 361 VALVE CHAMBER FRAME & COVER

SLIP JOINT BOND CONNECTIONMECHANICAL JOINT BOND CONNECTIONCONNECTION SEQUENCE:


1. REMOVE PIPE COATING TO BRIGHT & CLEAN METAL



2. STRIP INSULATION FROM TEST STATION WIRE, INSTALL ADAPTER SLEEVE



3. HOLD MOLD FIRMLY WITH OPENING AWAY FROM OPERATOR AND IGNITE



4. REMOVE SLAG AND ALLOW TO COOL

5. 16 OUNCE HAMMER TEST PER STD. SPEC SEC 7- 11.3(15)01

6. FINAL CONNECTION TO BE MADE WATERTIGHT WITH MASTIC COATING OR PREFORMED THERMITE WELD CAP

THERMITE WELD CONNECTION

REF STD SPEC SEC 7-11




City of Seattle


NOT TO SCALE

JOINT BONDING FOR DIP WATERMAINS  
& JOINTS BONDING DETAIL


NOTE:  
WIRE INSTALLATION PER  
STD SPEC SEC 9-30.12(3)



STANDARD 3-WIRE TEST STATION



INSULATING COUPLING 5-WIRE TEST STATION



INSULATING FLANGE 5-WIRE TEST STATION


TYPE E NEOPRENE  
FACED PHENOLIC  
INSULATING GASKET

PHENOLIC OR SPIRAL  
WOUND MYLAR  
INSULATING SLEEVE  
(LENGTH OF SLEEVE  
TO BE 1/16" LESS  
THAN SPACING  
BETWEEN STEEL  
WASHERS)

PHENOLIC INSULATING  
WASHER

STEEL WASHER

PETROLATUM TAPE  
ENCLOSE ENTIRE  
FLANGE ASSEMBLY



INSULATING FLANGE SECTION DETAIL


REF STD SPEC SEC 7-11.3(15) & 9-30.12



City of Seattle

NOT TO SCALE

ELECTROLYSIS TEST STATION  
WIRE INSTALLATION DETAILS



REF STD SPEC SEC 2-03




City of Seattle


NOT TO SCALE

HALF SECTION, GRADING







401A-CEMENT CONCRETE PAVEMENT WITH INTEGRAL CURB



401B-CEMENT CONCRETE PAVEMENT WITH EXISTING CURB &amp; GUTTER



401C-ASPHALT CONCRETE ON CEMENT CONCRETE BASE



401D-ASPHALT CONCRETE OVER CRUSHED ROCK BASE

**NOTES:**

1. CONC CL 6 (1 1/2) UNLESS OTHERWISE SPECIFIED ON DRAWINGS
2. FOR JOINT DETAILS, SEE STD PLAN NO 405


REF STD SPEC SEC 4-04, 5-04, 5-05 &amp; 8-04




City of Seattle

NOT TO SCALE


RESIDENTIAL PAVEMENT  
SECTIONS



402A-CEMENT CONCRETE PAVEMENT ON CRUSHED ROCK



402B-ASPHALT CONCRETE ON CEMENT CONCRETE ON CRUSHED ROCK



402D-ASPHALT CONCRETE ON CRUSHED ROCK BASE

**NOTES:**

1. PAVEMENT WIDTH AND THICKNESS AS SPECIFIED ON DRAWINGS
2. CONC CL 6.5 (1 1/2) UNLESS OTHERWISE SPECIFIED ON DRAWINGS
3. TIE BARS AND DOWELL BARS ARE REQUIRED FOR CEMENT CONCRETE PAVEMENT AND BASE (SEE STD PLAN NO 405)
4. FOR THICKENED EDGE AND JOINT DETAILS, SEE STD PLAN NO 405



REF STD SPEC SEC 4-04, 5-04, 5-05 &amp; 8-04



City of Seattle

NOT TO SCALE

COMMERCIAL AND  
ARTERIAL PAVEMENT  
SECTIONS

**NOTES:**

1. WHEN ALLEY PAVEMENT IS 16'-0" OR WIDER  
PLACE CONSTRUCTION JOINT TYPE II PER  
STD PLAN NO 405 ALONG CENTERLINE OF ALLEY
2. CONC CL 6(1 1/2)
3. SPECIFIC APPLICATION OF THIS STANDARD PLAN  
SHALL CONSIDER ADA ACCESSIBLE ROUTE  
FOR ENTIRE ALLEY

REF STD SPEC SEC 5-05



City of Seattle

NOT TO SCALE

CEMENT CONCRETE ALLEY  
PAVEMENTS

HALF SECTIONRIGID PAVEMENT WITH  
ASPHALT CONCRETE  
SURFACESAW ASPHALT (REMOVE  
LOOSENED AREAS)EXISTING ASPHALT  
PAVEMENT

EXISTING RIGID BASE


TRIM VERTICALLY

COMPACTED SUBGRADE

MIN WIDTH FOR RESTORATION\*\*

ASPHALT\*\*  
CONCRETE CL ACONC CLASS 6.5  
(1 1/2) HES\*\*

12"

HALF SECTION  
CEMENT CONCRETE  
PAVEMENT

SAW CONCRETE (1/3 D)

EXISTING CONCRETE  
PAVEMENTCOMPACTED MINERAL  
AGGREGATE TYPE 2 FOR  
ARTERIAL AND  
COMMERCIAL ACCESS  
STREETS.

TRENCH WIDTH\*


TYPICAL PATCH FOR RIGID PAVEMENTHALF SECTIONFLEXIBLE PAVEMENT  
RESTORATION FOR  
RESIDENTIAL STREETS

EXISTING OIL MAT

EXISTING EARTH OR  
GRANULAR BASECOMPACTED MINERAL  
AGGREGATE TYPE 2COMPACTED  
SUBGRADE

MIN WIDTH FOR RESTORATION\*\*

12"


ASPHALT\*\*  
CONCRETE CL A

TRENCH WIDTH\*

TYPICAL PATCH FOR FLEXIBLE PAVEMENT

SAW ASPHALT

4"

HALF SECTION  
FLEXIBLE PAVEMENT  
RESTORATION FOR  
ARTERIAL AND  
COMMERCIAL ACCESS  
STREETEXISTING ASPHALT  
CONCRETE SURFACE

EXISTING FLEXIBLE BASE

ASPHALT CL E\*\*

COMPACTED MINERAL  
AGGREGATE TYPE 2\* TRENCH WIDTH REFERS TO MAX TRENCH  
WIDTH AS CALLED OUT ON STD PLAN NOS 284 & 350\*\* ACTUAL WIDTH AND DEPTH OF RESTORATION MAY BE  
INCREASED TO MEET REQUIREMENTS OF "STREET  
AND SIDEWALK PAVEMENT OPENING AND RESTORATION RULES"


REF STD SPEC SEC 2-02, 5-04, &amp; 5-05



City of Seattle

NOT TO SCALE

PAVEMENT PATCHING



ASPHALT OVER RIGID BASE OF BRICK OR STONE BLOCK PAVEMENT

NOTES:

1. WHEN A STONE OR BRICK PAVEMENT IS OVERLAYED WITH ASPHALT, THE STREET SURFACE PAVEMENT BECOMES AN ASPHALT STREET OVER RIGID BASE
2. IF A STONE OR BRICK PAVEMENT IS NOT OVERLAYED, THE METHOD OF RESTORATION IS IN KIND

\* TRENCH WIDTH REFERS TO MAX TRENCH WIDTH AS CALLED OUT ON STD PLAN NOS. 284 & 350  
\*\* ACTUAL WIDTH AND DEPTH OF RESTORATION MAY BE INCREASED TO MEET REQUIREMENTS OF "STREET AND SIDEWALK PAVEMENT OPENING AND RESTORATION RULES"


REF STD SPEC SEC 2-02, 5-04 & 5-05




City of Seattle

NOT TO SCALE


PAVEMENT PATCHING



CONTRACTION JOINTS




CONSTRUCTION JOINTS




KEYWAY DETAIL

FOR JOINTS WITH THICKENED EDGE  $T=d+3'$   
OTHERWISE  $T=d$




THROUGH JOINTS



THICKENED EDGE DETAIL

(NOT NEEDED FOR TYPE A JOINTS WIDTH  $d \geq 10'$ )  
(NOT NEEDED FOR TYPE B JOINTS WIDTH  $d \geq 9'$ )



NEW TO OLD JOINTS

TABLE

PAVEMENT THICKNESS	DOWEL BAR SIZE
6" TO 8"	1" X 18" @ 12"
9" TO 11"	1 1/4" X 18" @ 12"
12" & OVER	1 1/2" X 18" @ 12"

## NOTES:

- WHERE REQUIRED AT LONGITUDINAL JOINTS, TIE BARS SHALL BE 5/8" X 2'-6" @ 3'-0", DEFORMED GRADE 40 OR BETTER, EPOXY COATED. WHERE REQUIRED AT TRANSVERSE JOINTS, DOWEL BARS SHALL BE SIZED AS SHOWN IN THE TABLE, SMOOTH ROUND GRADE 60 OR BETTER, EPOXY COATED AND GREASED
- LONGITUDINAL JOINT SPACING SHOULD NOT EXCEED 15'-6" (TO BACK OF CURB). TRANSVERSE JOINT SPACE SHALL NOT EXCEED 15'-0". THE AREA OF THE PANEL SHALL NOT EXCEED 225 SQUARE FEET
- JOINT OFFSETS AT RADIUS POINTS SHOULD BE AT LEAST 1'-6" LONG
- JOINT INTERSECTION ANGLES OF LESS THAN 60 DEGREES SHALL BE USED
- WHEN A JOINT IS CLOSER THAN 1'-0" TO A CASTING, THEN A MINOR ADJUSTMENT IN THE JOINT LOCATION SHOULD BE MADE BY SKEWING OR SHIFTING THE JOINT ALIGNMENT TO MEET THE CASTING AT 90° OR NORMAL TO THE CASTING.
- WHERE POSSIBLE, LONGITUDINAL JOINTS SHOULD MATCH LANE MARKINGS
- LONGITUDINAL JOINTS ARE TO BE CONSTRUCTION JOINTS UNLESS PAVED BY MACHINE CAPABLE OF PLACING AND FINISHING CONCRETE FOR TWO OR MORE PANEL WIDTHS (IN WHICH CASE A CONTRACTION JOINT IS ALLOWED)
- DOWEL BARS SHALL NOT BE PLACED WITHIN 1'-0" OF THE EDGE OF PAVEMENT OR A PARALLEL JOINT


REF STD SPEC SEC 5-05 &amp; 6-02




City of Seattle

NOT TO SCALE

TYPES OF JOINTS FOR  
CONCRETE PAVEMENT



410B CURB & GUTTER



410C CURB

NOTES:

1. "H" SHALL BE 6" FROM FINISHED ROADWAY GRADE UNLESS OTHERWISE SHOWN ON DRAWINGS
2. GUTTER SHALL BE SLOPED THE SAME AS ADJACENT PAVEMENT OR 2% MIN, WHICHEVER IS GREATER.
3. SEE STD PLAN NO 411 FOR CURB DOWELS

REF STD SPEC SEC 8-04



City of Seattle


NOT TO SCALE

TYPE 410 CURB




## CURB JOINTS & DOWELS





EXTRUDED ASPHALT CONCRETE CURB



EXTRUDED CEMENT CONCRETE CURB

NOTE:  
ALTERNATELY, THE USE OF EPOXY BONDING AGENT,  
IN PLACE OF #3 DEFORMED BARS, WILL BE ALLOWED.


REF STD SPEC SEC 8-06




City of Seattle

NOT TO SCALE


EXTRUDED CURB




413C CURB PLAN




SECTION C-C




SECTION D-D




413C NOSING



SECTION B-B




SECTION A-A



INSTALLATION DETAIL FOR  
STRAIGHT 413C CURB

NOTE: INSTALL 8" #4 REBAR IN EVERY OTHER  
HOLE AND FILL HOLE WITH GROUT



SECTION E-E


REF STD SPEC SEC 8-07




City of Seattle

NOT TO SCALE

TRAFFIC CURB PRECAST  
CEMENT CONCRETE  
3' AND 4' SECTIONS




PLAN




SECTION F-F

8" STRAIGHT 413A CURB




413A RADIAL CURB




SECTION G-G

413 A RADIAL CURB		
UNIT	RADIUS	CURB RETURN ANGLE( $\phi$ )MULTIPLE
R1	1'- 3"	45°00'
R2	1'-10"	30°00'
R3	2'- 6"	22°30'
R4	5'- 0"	11°27.54'
R5	10'- 0"	5°43.77'
FOR RADII GREATER THAN 10'-0" USE SEGMENTS OF STRAIGHT CURB		

RADIUS CURB TABLE



PLAN



SECTION H-H


REF STD SPEC SEC 8-07




City of Seattle

NOT TO SCALE

TRAFFIC CURB PRECAST  
CEMENT CONCRETE  
8" SECTION AND RADIAL



414 A BLOCK



414 C BLOCK

REF STD SPEC SEC 8-07




City of Seattle

NOT TO SCALE


BLOCK TRAFFIC CURBS  
PRECAST CEMENT CONCRETE

# STANDARD PLAN NO 415

REV DATE: 2003



TYPICAL TRAFFIC CIRCLE




TRAFFIC CIRCLE REFLECTOR LAYOUT

## SPACING CHART

DIAMETER OF CIRCLE	DEGREE OF SPACING
≤12'-0"	EVERY 45°
<20'-0"	EVERY 30°
>20'-0"	EVERY 22 1/2°

(FACING VEHICLE APPROACHES)




TYPICAL SECTION

## NOTES:

1. DIMENSIONS ABOVE PAVEMENT EXTENSION TO MATCH SECTION DETAILED ELSEWHERE ON THIS STD PLAN
2. EXTEND CURB DEPTH TO MATCH ADJACENT ASPHALT THICKNESS OR 7" WHICHEVER IS GREATER

CEMENT CONCRETE MOUNTABLE CURB (DOWELED) AS DETAILED ABOVE

NEW CONCRETE PAVEMENT TYPE 401A



SEE TYP SECTION ABOVE FOR DIMENSIONS

EXTRA DEPTH CEMENT CONCRETE MOUNTABLE CURB

EXISTING ASPHALT PAVEMENT

TYPICAL SECTIONS


REF STD SPEC SEC 8-02, 8-04 & 8-08






City of Seattle

NOT TO SCALE


TRAFFIC CIRCLE DETAILS

SIDEWALK

5'-0" WIDE

SECTION A-ASIDEWALKGREATER THAN  
5'-0" WIDESECTION B-BNOTES:

1. WHEN PLANTING STRIP PAVEMENT IS APPROVED, JOINT MATERIAL WILL BE REQUIRED AT THE PERIMETER OF THE PLANTING STRIP PAVEMENT
2. WHEN EXISTING PARKING METERS ARE TO BE REMOVED FOR NEW SIDEWALK CONSTRUCTION, CONTACT SEATTLE DEPARTMENT OF TRANSPORTATION A MINIMUM OF 2 WORKING DAYS PRIOR TO SCHEDULED WORK TO COORDINATE REMOVAL OF METER HEADS

SECTION C-C


REF STD SPEC SEC 8-14



City of Seattle

NOT TO SCALE

CONCRETE SIDEWALK DETAILS

**NOTES:**

1. "H" SHALL BE 6" FROM FINISHED GRADE UNLESS OTHERWISE SPECIFIED
2. VERTICAL BACKFACE OF CURB SHALL BE FORMED AGAINST NATIVE EARTH WHERE PRACTICAL, OTHERWISE BY BACKFORM LEFT IN PLACE


REF STD SPEC SEC 8-14



City of Seattle




NOT TO SCALE

SIDEWALK WITH  
MONOLITHIC CURB




	MIN.	MAX.
A	1.6 "	2.4 "
B	0.65 "	1.5 "
C	50% TO 65% OF D	
D	0.9 "	1.4 "

TRUNCATED DOMES PATTERN -DETECTABLE WARNING




SECTION A-A

CURB MONOLITHIC WITH RAMP.  
NEW PAVEMENT BLOCKED OUT FULL DEPTH.  
EXISTING PAVEMENT REMOVED AT FACE OF CURB



SECTION B-B



## NOTES:

- TWO CURB RAMPS SHALL BE INSTALLED AT EACH CORNER UNLESS DIRECTED OTHERWISE BY SDOT. SEE STD PLAN NO 422b.
- CURB RAMPS SHALL BE CONSTRUCTED WITH COMPANION RAMPS ON OPPOSITE SIDES OF THE STREET UNLESS DIRECTED OTHERWISE BY SDOT
- WHERE CURB IS INSTALLED AT A LOCATION WITH NO SIDEWALK, CURB SHALL BE DEPRESSED FOR FUTURE CURB RAMP INSTALLATION.
- TYPE 422a CURB RAMP SHALL BE USED. HOWEVER IF NOT FEASIBLE, THEN TYPE 422b CURB RAMP MAY BE INSTALLED WITH THE APPROVAL OF SDOT
- NEW PAVEMENT SHALL BE BLOCKED OUT FULL DEPTH. EXISTING PAVEMENT SHALL BE REMOVED AT THE FACE OF THE CURB.
- MIN DISTANCE BETWEEN ADJACENT CURB RAMPS SHALL BE 3'-0".
- CURB RAMPS SHALL BE ISOLATED FROM ALL OTHER CONCRETE BY THROUGH JOINTS.
- RAMPS SHALL HAVE A COARSE TEXTURED SURFACE OBTAINED WITH A 3/4" 9-11 FLATTENED EXPANDED METAL MESH BEING PRESSED INTO THE STILL FRESH CONCRETE. THE LONG AXIS OF THE DIAMOND PATTERN SHALL BE ALIGNED WITH THE SLOPE OF THE RAMP.
- ADDITIONAL SIDEWALK PAVING MAY BE NECESSARY IN THE PLANTING STRIP OR AT THE BACK OF SIDEWALK TO ACCOMMODATE ACCESS TO THE RAMP. A MINIMUM 4'-0"x5'-0" 2% GRADE LANDING SHALL BE PROVIDED AT THE TOP OF RAMP ON TYPE 422a.
- THE SIDEWALK THICKENED EDGE SHALL BE CONTINUED THROUGH BOTH WINGS ON TYPE 422a AND BOTH RAMPS ON TYPE 422b. SEE STD. PLAN NO 420.
- THE WINGS ON TYPE 422a SHALL HAVE A SLIGHTLY BRUSHED FINISH PARALLEL TO THE CURB.
- MIN LATERAL CLEARANCE FROM INLETS, POLES, HYDRANTS AND OTHER ABOVE GROUND OBSTACLES SHALL BE 1'-0" MINIMUM FROM THE SCORED AND THE DETECTABLE WARNING PORTIONS OF THE CURB RAMP.
- INLETS SHALL BE SO LOCATED THAT GUTTER FLOW DOES NOT FLOW PAST THE CURB RAMP.
- DETECTABLE WARNING SURFACE BE "CITY OF SEATTLE SAFETY YELLOW", AND SHALL BE LOCATED 6 INCHES OF THE CURB FACE. SEE STD SPEC SEC 8-3(7)A.
- CURB RAMP SHALL BE PERPENDICULAR TO THE CURB.
- THE RAMP PORTION OF THE TYPE 422a CURB RAMP SHALL BE WHOLLY CONTAINED WITHIN THE MARKED CROSSING (SEE STD PLAN NO. 422b)

REF STD SPEC SEC 8-14




City of Seattle

NOT TO SCALE


CURB RAMP DETAILS






THE LANDING PORTION OF THE TYPE 422b CURB RAMP SHALL BE WHOLLY CONTAINED WITHIN THE MARKED CROSSING

PLAN




CURB MONOLITHIC WITH RAMP. NEW PAVEMENT BLOCKED OUT FULL DEPTH. EXISTING PAVEMENT REMOVED AT FACE OF CURB



SECTION B-B

SEE STD PLAN NO 422a FOR NOTES



TYPICAL CURB RAMP LOCATIONS

REF STD SPEC SEC 8-14





City of Seattle


NOT TO SCALE

CURB RAMP DETAILS

## REV DATE: 2003



## BUS SHELTER FOOTING



- TREE PIT DIMENSIONAL REQUIREMENTS:
- 24 SQ FT MIN TREE PIT SIZE
  - 3'-6" MIN REQ'D BETWEEN TREE C & FACE OF CURB
  - 2'-0" MIN REQ'D BETWEEN TREE C & CONC SIDEWALK
  - 5'-0" MIN CONC WALKING SURFACE

NOTE:  
INSTALLATIONS REQUIRING LESS THAN  
STANDARD MIN CLEARANCES SHALL BE  
ALLOWED ONLY WITH SPECIFIC APPROVAL  
BY SEATTLE TRANSPORTATION



FOR ADDITIONAL SIDEWALK  
SCORING REQUIREMENTS  
SEE STD PLAN NO 420

REF STD SPEC SEC 8-02 & 8-14


## NOTES:

1. CONCRETE SHALL BE CL 6 (1 1/2) OR CL 6 (3/4) AT CONTRACTOR'S OPTION
2. ON ARTERIAL STREETS WHERE TRAVELED LANE IS NEXT TO CURB, THIS DISTANCE SHALL BE 5'-0"
3. WHEN EXISTING PARKING METERS ARE TO BE REMOVED FOR NEW DRIVEWAY CONSTRUCTION, CONTACT SDOT A MINIMUM OF 2 WORKING DAYS PRIOR TO SCHEDULED WORK TO COORDINATE REMOVAL OF METER HEADS
4. REF STD PLAN NO 431 FOR CONCRETE DRIVEWAY PLACED WITH SIDEWALK CONSTRUCTION
5. THE RAMP SECTION CONCRETE SHALL HAVE A COARSE TEXTURED SURFACE OBTAINED BY A 3/4" 9-11 FLATTENED EXPANDED METAL MESH BEING PRESSED INTO THE STILL FRESH CONCRETE. THE LONG AXIS OF THE DIAMOND PATTERN SHALL BE ALIGNED WITH THE SLOPE OF THE RAMP
6. DRIVEWAY WIDTH GREATER THAN 15'-0" SHALL HAVE A TRANSVERSE CONTRACTION JOINT AT OR NEAR CENTER
7. THIS DISTANCE IS 1'-0", HOWEVER ON ARTERIALS AND COMMERCIAL STREETS WHERE THE LANE OF TRAVEL IS ADJACENT TO CURB THIS DISTANCE SHALL BE 3'-6"


TYPE 430A




SECTION A-A



DETAIL B



SECTION B-B



TYPE 430B


REF STD SPEC SEC 8-19



City of Seattle

NOT TO SCALE

TYPE 430 DRIVEWAY



SECTION A-A

NOTES:

- 1. DRIVEWAY WIDTH GREATER THAN 15'-0" SHALL HAVE TRANSVERSE CONTRACTION JOINT AT ITS CENTER
- 2. DRIVEWAY CONCRETE SHALL BE CLASS 6(3/4) OR 6(1 1/2) AT CONTRACTOR'S OPTION
- 3. SIDEWALK CONCRETE SHALL BE CLASS 5(3/4)

REF STD SPEC SEC 8-14 & 8-19




City of Seattle

NOT TO SCALE

CONCRETE DRIVEWAY PLACED WITH SIDEWALK CONSTRUCTION


## REV DATE: 2005




CEMENT CONCRETE  
STAIRWAY & HANDRAIL

# STANDARD PLAN NO 440b


REV DATE: 2003




DETAIL A





DETAIL B  
SEE NOTE 11 ON STD  
PLAN NO 440a




DETAIL C




SECTION C-C



SECTION D-D



DETAIL E



DETAIL F



REF STD SPEC SEC 8-18



City of Seattle

NOT TO SCALE

CEMENT CONCRETE  
STAIRWAY & HANDRAIL

**NOTES:**

1. CEMENT CONCRETE SHALL BE CL 6 (3/4) TROWEL FINISH
2. NUMBER OF STEPS SHALL SUIT INDIVIDUAL CONDITIONS WITH UNIFORM TREAD AND RISER DIMENSIONS AS FOLLOWS:  
TREADS SHALL BE 11" MIN - 1'-0" MAX  
RISERS SHALL BE 5" MIN - 7" MAX
3. STEP WIDTH SHALL MATCH WIDTH OF EXISTING WALK, BUT SHALL BE NO LESS THAN 2'-6" WIDE
4. STEPS WITH 4 OR MORE RISERS MUST INCLUDE HANDRAIL. SEE STD PLAN NO 440
5. REINFORCING STEEL ASTM A 615 GR 60
6. TREAD SLOPES OUTWARD @ 1%

REF STD SPEC SEC 8-18



City of Seattle


NOT TO SCALE

CEMENT CONCRETE STEPS



# STANDARD PLAN NO 442



REV DATE: 2003



City of Seattle

NOT TO SCALE

STEEL PIPE HANDRAIL



SECTION A-A

NOTES:

1. RAILING SHALL BE HOT DIP GALVANIZED AFTER FABRICATION
2. ALL POSTS SHALL BE PLUMB AND RAILS PARALLEL TO GRADE
3. PIPE MATERIAL SHALL CONFORM TO ASTM A53
4. REINFORCING STEEL ASTM A615 GR 60
5. IF THE CONCRETE WALK SLOPE IS 5% OR GREATER A GRIPPING HANDRAIL IS REQUIRED
6. PIPE DIAMETERS SHOWN ARE "NOMINAL" DIAMETERS AS GIVEN IN AMERICAN INSTITUTE OF STEEL CONSTRUCTION MANUAL







REF STD SPEC SEC 8-18



City of Seattle

NOT TO SCALE

STEEL PIPE RAILING  
FOR BIKE PATH




REF STD SPEC SEC 8-18




City of Seattle

NOT TO SCALE


STEEL PIPE RAILING  
FOR BIKE PATH




CHAIN LINK FENCE TYPE 1



CHAIN LINK FENCE TYPE 3



CHAIN LINK FENCE TYPE 4



CHAIN LINK FENCE TYPE 6


REF STD SPEC SEC 8-12



City of Seattle

NOT TO SCALE

CHAIN LINK FENCE



## ROLL FORMED SECTIONS

TYPE	MEMBER									
	BRACE RAIL & TOP RAIL					LINE & BRACE POST				
	ROUND		H-COLUMN		ROLL FORMED		ROUND		H-COLUMN	
	ID PIPE INCHES	WEIGHT PER FT POUNDS	SIZE INCHES	WEIGHT PER FT POUNDS	SIZE INCHES	WEIGHT PER FT POUNDS	ID PIPE INCHES	WEIGHT PER FT POUNDS	SIZE INCHES	WEIGHT PER FT POUNDS
1	1.25	2.27	1.25X1.62	1.35	15/8X1 1/4	1.35	2	3.65	2 1/4	4.0
3							1 1/2	2.72	1 7/8	2.72
4							1 1/2	2.72	1 7/8	2.72
6			1.25X1.62	1.35			2	3.65	2 1/4	4.0
									15/8X1 7/8	2.34
									15/8X1 7/8	2.34

TYPE	MEMBER							
	END, CORNER & PULL POSTS				GATE POST		ALL POSTS	
	ROUND		ROLL FORMED		ROUND		LENGTH	
	ID PIPE INCHES	WEIGHT PER FT POUNDS	SIZE INCHES	WEIGHT PER FT POUNDS	ID PIPE INCHES	WEIGHT PER FT POUNDS		
1	2 1/2	5.79	3 1/2X	5.14	3 1/2	9.1	8'-8"	
3	2	3.65					8'-8"	
4	2	3.65					5'-6"	
6	2 1/2	5.79					5'-6"	

## NOTES:

1. ALL CONCRETE POST BASES SHALL BE 10" MINIMUM DIAMETER, CL 5 (1 1/2)
2. POSTS SHALL BE SPACED AT 10'-0" MAXIMUM INTERVALS UNLESS OTHERWISE DIRECTED BY THE ENGINEER
3. TOP OR BOTTOM TENSION WIRES SHALL BE PLACED WITHIN THE LIMITS OF THE FIRST FULL FABRIC WEAVE
4. THE ILLUSTRATIVE DETAIL SHOWN HEREON SHALL NOT BE CONSTRUED AS LIMITING TO HARDWARE DESIGN OR POST SELECTION FOR ANY PARTICULAR FENCE TYPE
5. CONCRETE OR GROUT AROUND POST AT GROUND LINE SHALL BE MOUNDED FOR DRAINAGE


REF STD SPEC SEC 8-12



City of Seattle

NOT TO SCALE

CHAIN LINK FENCE



NOTES:

1. FENCE FABRIC SHALL BE SECURED TO GATE FRAMES WITH KNUCKLED SELVAGE ALONG TOP EDGE FOR TYPES 4&6 CHAIN LINK FENCE INSTALLATIONS
2. MINIMUM POST LENGTH:  
TYPES 1&3: 8'-8"  
TYPES 4&6: 5'-6"
3. CONCRETE OR GROUT AROUND POST AT GROUND LINE SHALL BE MOUNDED FOR DRAINAGE


REF STD SPEC SEC 8-12



City of Seattle


NOT TO SCALE

CHAIN LINK GATES



NOTE:

1. IF THE SLOPE OF THE TEMPORARY CROSSING IS 5% OR GREATER, A GRIPPING HANDRAIL SHALL BE ADDED THAT COMPLIES WITH ADA STANDARDS
2. ENDS OF THE TEMPORARY CROSSING SHALL BE SLOPED TO ALLOW ADA ACCESS
3. SURFACE OF WALKWAY SHALL BE SKID RESISTANT



TABLE

BRIDGE LENGTH	PLANK SIZE	NAIL SIZE
10'-0" OR LESS	2" X 12"	20 PENNY
11'-0" TO 14'-0"	3" X 12"	40 PENNY
15'-0" TO 20'-0"	4" X 12"	60 PENNY

LUMBER: DOUGLAS FIR #2 OR BETTER  
POSTS & RAILS S4S  
PLANKS - ROUGH


REF STD SPEC SEC 1-07.23



City of Seattle

NOT TO SCALE

TEMPORARY PEDESTRIAN  
WALKWAY






CONCRETE TONGUE & GROOVE BLOCK





## REV DATE: 2003




REF STD SPEC SEC 8-02



City of Seattle

NOT TO SCALE

## FIXED & REMOVABLE WOOD BOLLARD




DIMENSION	TYPE II	TYPE III	AUXILIARY
A	28" TO 34"	36" TO 48"	24"
B	16" TO 20"	20" TO 28"	22"
C	38" TO 52"	50" TO 58"	-

### SIGNAL CONTROLLER CABINET—TYPES II & III

#### NOTES:

1. TRAFFIC SIGNAL CONTROLLER CABINET SHALL BE FURNISHED BY THE CITY
2. EXACT CABINET DIMENSIONS & ANCHOR BOLT LOCATIONS SHALL BE PROVIDED BY THE TRAFFIC SIGNAL SHOPS
3. PLACE CABINET DOOR ON SIDEWALK SIDE OF FOUNDATION
4. SEAL CABINET TO FOUNDATION WITH GREY OR CLEAR SILICON TO PREVENT MOISTURE FROM ENTERING THE CABINET



### SIGNAL CONTROLLER FOUNDATION—TYPES II & III

SEE STD PLAN NO 500b FOR CONDUIT LAYOUT



REF STD SPEC SEC 8-31 & 8-32



City of Seattle


NOT TO SCALE

SIGNAL CONTROLLER  
CABINET & FOUNDATION



CONDUIT LAYOUT—TYPE II SIGNAL CONTROLLER FOUNDATION

ALL MEASUREMENTS TO  
CENTER OF CONDUIT



CONDUIT LAYOUT—TYPE III SIGNAL CONTROLLER FOUNDATION


REF STD SPEC SEC 8-31 & 8-32



City of Seattle

NOT TO SCALE

SIGNAL CONTROLLER  
FOUNDATION CONDUIT LAYOUT





REF STD SPEC SEC 9-31, 9-32, 9-33 &amp; 9-34




City of Seattle

NOT TO SCALE

**SIGNALIZED INTERSECTION  
SPAN WIRE TYPE  
CONFIGURATION**



- NOTES:
- 1. FOR METAL POLES WITH ONLY OVERHEAD ACCESS, CONDUCTORS SHALL ENTER POLE THROUGH CABLE OUTLETS
  - 2. CONDUCTORS SHALL BE CONTINUOUSLY COLOR CODED  
LINE 1 = BLACK  
LINE 2 = RED  
LINE 3 = BLUE  
NEUTRAL = WHITE  
GROUND = GREEN



OVERHEAD SERVICE CONNECTION


REF STD SPEC SEC 8-30 & 8-31



City of Seattle

NOT TO SCALE

SIGNAL & LIGHTING  
SERVICE CONNECTION &  
LIGHT POLE WIRING DETAIL




REF STD SPEC SEC 8-30 &amp; 8-31




City of Seattle

NOT TO SCALE


**SIGNAL & LIGHTING  
SERVICE CONNECTION &  
LIGHT POLE WIRING DETAIL**

TYPICAL SIGNAL FACES




W/ TUNNEL VISORS &  
5" BACKPLATE (LOUVERED)

MAST ARM MOUNTINGNOTE:

BACKPLATES HAVE  
BEEN OMITTED  
FROM VARIOUS  
VIEWS FOR CLARITY

BRACKET MOUNTING

FOR BRACKET ASSEMBLY  
SEE STD PLAN NO 511

SIGNAL HANGER DETAILPEDESTAL TOP MOUNTING

FOR PEDESTAL SEE STD PLAN NO 524b


REF STD SPEC SEC 8-31



City of Seattle

NOT TO SCALE

VEHICULAR SIGNAL MOUNTING



SUSPENDED SIGNAL MOUNTING DETAIL

REF STD SPEC SEC 8-31




City of Seattle

NOT TO SCALE

VEHICULAR SIGNAL MOUNTING






REF STD SPEC SEC 8-31



City of Seattle

NOT TO SCALE


SIGNAL HEAD BRACKET  
ASSEMBLY



ELEVATION

SECTION A-A

METAL POLE MOUNT



PEDESTAL MOUNT

WOOD POLE MOUNT

**NOTES:**

1. BOLT AND WASHERS SHALL BE STAINLESS STEEL
2. MOUNTING SHALL BE AS FOLLOWS:
  - ON METAL POLES THINNER THAN 7 GAUGE, USE 3/8" STAINLESS STEEL RIVNUTS
  - ON METAL POLES 7 GAUGE OR THICKER, DRILL AND TAP FOR 3/8" BOLT (STAINLESS STEEL RIVNUTS OPTIONAL)
  - ON POLES FILLED WITH OR MADE FROM CONCRETE USE 3/8" X 2 1/2" STUD BOLT ANCHORS WITH HEX NUT
3. FOR STREET NAME SIGNS MOUNTED ON TOP OF PEDESTAL SEE STD PLAN NO 623

REF STD SPEC SEC 8-31




City of Seattle

NOT TO SCALE

PEDESTRIAN SIGNAL  
CLAMSHELL MOUNTING

# STANDARD PLAN NO 521

REV DATE: 2003





REF STD SPEC SEC 8-31 & 8-32




City of Seattle

NOT TO SCALE


PEDESTRIAN PUSHBUTTON POST & FOUNDATION



R-37L  
MODIFIED  
(PART NO H3)



R-37R  
MODIFIED  
(PART NO H3R)



#### NOTES:

1. MOLDED ONE-PIECE ALUMINUM CONSTRUCTION
2. SIGNS SHALL BE FABRICATED FROM BAKED-ON ENAMEL DIRECTLY ON BOTH SIDES OF THE EXTRUSION

REF STD SPEC SEC 8-31




City of Seattle

NOT TO SCALE

PEDESTRIAN PUSHBUTTON & MOUNTING

# STANDARD PLAN NO 523

REV DATE: 2005



## NOTES:

1. GROUND ALL PEDESTRIAN SIGNALS AND PUSHBUTTONS WITH GREEN INSULATED #8 COPPER WIRE
2. ALL STEEL HARDWARE SHALL BE HOT DIP GALV OR STAINLESS STEEL


REF STD SPEC SEC 8-31




City of Seattle

NOT TO SCALE

PEDESTRIAN SIGNAL &  
PUSHBUTTON MOUNTED ON  
WOOD POLE




BOTTOM VIEW




PEDESTAL FOUNDATION

NOTE: INSTALL UFER GROUND TO FOUNDATION (SEE STD PLAN NO 500a)



PEDESTRIAN SIGNAL  
PEDESTAL MOUNTING DETAIL



SQUARE ALUMINUM BASE PEDESTAL



REF STD SPEC SEC 8-32



City of Seattle

NOT TO SCALE

PEDESTAL & FOUNDATION




REF STD SPEC SEC 8-32

SEE STD PLAN NO. 524a  
FOR PEDESTAL FOUNDATION


City of Seattle

NOT TO SCALE


PEDESTAL




DIPOLE LOOP  
DETECTORS



CURB/PAVEMENT ENTRANCE  
FOR DETECTOR LOOP WIRES



SECTION A-A



PAVEMENT JOINT OR CRACK DETAIL

NOTES:

1. FILL CUT AFTER VERTICAL PLACEMENT AND TESTING WITH HOT PAVING GRADE LIQUID ASPHALT ASTM D 312 TYPE III OR QUICK SETTING HIGH STRENGTH GROUT
2. SHARP EDGE TOOLS SHALL NOT BE USED IN PLACING CONDUCTORS IN SAW CUTS
3. EACH PAIR OF LOOP WIRES IN THE RETURN CUT SHALL BE TWISTED A MINIMUM OF 3 TURNS PER FOOT AND MAY SHARE COMMON RETURN CUTS WITH OTHER TWISTED PAIRS
4. TAPE LOOP WIRE A MINIMUM OF 2 TURNS AT EACH CORNER
5. REMOVE SHARP CORNER EDGES IN SAW CUTS WHERE LOOP WIRE WILL BE BENT AROUND
6. PERFORM RESISTANCE AND CONTINUITY TESTS PRIOR TO SEALING LOOP WIRES
7. COIL 5'-0\"/>

REF STD SPEC SEC 8-31




City of Seattle

NOT TO SCALE


LOOP DETECTORS





DETECTOR LEAD-IN WIRE SPLICE DETAIL

NOTE:  
SOLDER CONNECTION AFTER CRIMPING



SIGNAL CABLE SPLICE

REF STD SPEC SEC 8-31



City of Seattle

NOT TO SCALE

DETECTOR LOOP WIRE AND  
SIGNAL CABLE SPLICE



## REV DATE: 2005



STRAIN POLE  
FOUNDATION DETAIL  
(TYPE T, V, X & Z)

FOUNDATION SCHEDULE											
POLE TYPE	PROJECTION		VERTICAL REINFORCING	DEPTH (LATERAL BEARING)		ANCHOR BOLTS (TOTAL 4 PER POLE)	ANCHOR PLATE DIMENSIONS				
	P	P* (CHIEF SEATTLE BASE)		100#/SF/FT	150/SF/FT		SIZE	BOLT CIRCLE DIA	BOLT HOLE	CENTER HOLE	CORNER RADIUS
T	7½"	8"	8 #7	8'-0"	7'-6"	1½" DIA X 54"	⅜" X 16" X 16"	14½"	1⅝"	10"	1⅝"
V	9"	9"	8 #8	9'-6"	8'-6"	1¾" DIA X 72"	⅜" X 16" X 16"	18"	1⅞"	12½"	1⅝"
X	10"	10"	12 #8	12'-6"	10'-6"	2" DIA X 72"	⅜" X 18" X 18"	20"	2⅛"	14"	2"
Z	11½"	11½"	12 #8	15'-0"	13'-0"	2½" DIA X 72"	½" X 20" X 20"	22"	2⅝"	15"	2¼"

\* SEE STD PLAN NO 542a AND 542b



### POLE FOUNDATION NOTES

1. CONCRETE STRENGTH SHALL BE CLASS AX AIR ENTRAINED, 3/4" MAX SIZE COARSE AGGREGATE.
2. ANCHOR BOLTS FOR TYPE V,X,Z: ASTM F 1554-99, GRADE 105, CLASS 2A INCLUDING SUPPLEMENTARY REQUIREMENTS S2, S3 AND S5. ANCHOR BOLTS FOR TYPE T: ASTM A576 (TYPE 1040 OR 1045) FY=55 KSI MIN., ASTM A675 GRADE 90 OR ASTM A36 MOD FY=55 KSI. NUTS: ASTM A563 HEAVY HEX GRADE DH. HARDENED STEEL WASHERS: ASTM F436.
3. ANCHOR PLATE: ASTM A36. HOT DIP GALVANIZED.
4. ALL REINFORCING BARS SHALL BE DEFORMED BILLET STEEL CONFORMING TO ASTM CLASS A615, GRADE 60.
5. ANCHOR BOLTS SHALL BE HOT DIP GALVANIZED ASTM A153 INCLUDING NUTS & WASHERS (FULL LENGTH) WITH A MINIMUM OF 18" OF THREADS ON TOP & 12" ON BOTTOM
6. LATERAL BEARING IS BASED ON THE SOIL CLASSIFICATION USED IN THE 1997 UNIFORM BUILDING CODE UNDER TABLE 18-I-A.
7. TAPE THE TOP OF ANCHOR BOLTS WITH CORROSION PROTECTION TAPE PER STD SPEC SEC 8-32.3(2)A PRIOR TO POURING CONCRETE.


REF STD SPEC SEC 8-32



City of Seattle

NOT TO SCALE


STRAIN POLE FOUNDATION  
SCHEDULE & NOTES  
(TYPE T,V,X & Z)

**NOTES:**

1. FOR POLE DIAMETER GREATER THAN 9 1/2" BUT NOT MORE THAN 10" OD, A 10" COLLAR SHALL BE USED & THE FLUTES ON THE TOP OF THE COLLAR MAY HAVE TO BE GROUND OFF TO ALLOW A SNUG FIT AGAINST THE POLE
2. FOR POLE DIAMETER GREATER THAN 10" BUT NOT MORE THAN 12 1/2" OD, A 12" COLLAR SHALL BE USED
3. FOR POLE DIAMETER IN EXCESS OF 12 1/2" BUT NOT MORE THAN 13" OD, THE COLLAR SHALL NOT BE USED. SOME GRINDING MAY BE REQUIRED TO ALLOW THE TWO PIECE CAST BASE TO FIT SNUGLY AROUND THE POLE
4. SEE STD PLAN NO 542b FOR TYPE T, V, X & Z STRAIN POLE FOUNDATION DETAILS
5. BASE SHALL BE EMBEDDED 1 1/2" AT LOW POINT OF SIDEWALK GRADE

POLE TYPE	G	P
T	6 1/2"	8"
V	6 1/2"	9"
X	7"	10"
*Z	11 1/2"	11 1/2"

\*CSB WILL NOT FIT OVER ANCHOR BOLT NUTS THEREFORE BOLTS MUST BE SET BELOW SIDEWALK







REF STD SPEC SEC 8-32



City of Seattle

NOT TO SCALE

CHIEF SEATTLE BASE (CSB)



BOLT PATTERN MUST BE DIAMOND SHAPE TO CURB.

TO BE USED FOR CONCRETE FILLED POLE, BOLTS ARE PARALLEL TO CURB.

NOTES:

1. FOR TYPE "A" FOUNDATION ALIGN THE CHIEF SEATTLE BASE ACCESS COVER ON THE SAME SIDE WITH THE POLE HANDHOLE, AND CONDUITS.
2. TAPE TOP OF ANCHOR BOLTS WITH CORROSION PROTECTION TAPE PER SPECS.
3. FOR TYPE "A" FOUNDATION, THE TOP 3 1/2" SHALL BE FORMED INTO A SQUARE AND POURED PRIOR TO SETTING POLES.
4. FOR TYPE "B" FOUNDATION, THE TOP 5 1/2" SHALL BE FORMED INTO A SQUARE AND POURED AFTER SETTING THE POLE.
5. INSTALL UFER GROUND IN FOUNDATION (SEE STD PLAN NO 500a)

REF STD SPEC SEC 8-32




City of Seattle

NOT TO SCALE


CHIEF SEATTLE STREET LIGHT POLE FOUNDATION

# STANDARD PLAN NO 543


REV DATE: 2005




PLAN



IN EARTH  
(TYPE B)



IN SIDEWALK  
(TYPE A)



ON AN INCLINE

## NOTES:

1. 5 FT WHERE LOCATED ON FILL OR WHERE SLOPE IS 3:1 OR STEEPER.
2. TOP 3 1/2" TO BE FORMED INTO A 36" SQUARE BLOCKOUT AND POURED SEPARATELY IN TYPE A AND IN ONE PIECE IN TYPE B.
3. BOLT CIRCLE-11 1/2" TYP. (TRANSFORMER BASE-15" TYP.)
4. SEE STD PLAN NO 563 FOR POLE MOUNTING AND GROUT DETAIL.
5. TAPE TOP OF ANCHOR BOLTS W/CORROSION PROTECTION TAPE PER SPECS 8-32.3(2)A
6. SEE STD PLAN NO 572 FOR STEEL STREET LIGHT POLE DETAIL AND CITY LIGHT MATERIAL STD NO 5739.8 FOR ALUMINUM STREET LIGHT POLE.
7. ANCHOR BOLTS SHALL BE HOT DIP GALVANIZED (ASTM A 153) FULL LENGTH AND FABRICATED FROM ASTM A 307 OR A 576.
8. INSTALL UFER GROUND IN FOUNDATION (SEE STD PLAN NO 500a)

REF STD SPEC SEC 8-32



City of Seattle

NOT TO SCALE

STREET LIGHT POLE  
FOUNDATIONS


## HANDHOLE SCHEDULE

HANDHOLE TYPE	TOP UNIT INSIDE DIMENSIONS			EXTENSION UNIT(E)	LID DIMENSIONS		
	L	W	H		L	W	
1	19"	14"	12"	12"	17"	13"	
2	28"	17"	12"	12"	26 3/8"	17 1/2"	
3	36"	24"	12"	12"	35"	24"	
4	24" DIA	VAR		NA	NA	NA	
5	36"	24"	32"	NA	35"	24"	
6	42"	42"	38 1/2"	NA	33 1/2"	35 1/2"	
GRHH		8" DIA		NA			


REV DATE: 2005

## NOTES:


1. THE COVER SHALL HAVE 1/16" TO 1/8" CLEARANCE ON EACH EDGE WITHIN THE FRAME AFTER GALVANIZING
2. THE GROUND ROD SHALL EXTEND 4" ABOVE THE BOTTOM OF THE HANDHOLE
3. TYPE 1, 2, 3, 5 & 6 HANDHOLE COVERS SHALL HAVE "TC" OR "SL" ON THEM, AS APPROPRIATE
4. TYPE 4 HANDHOLE SHALL BE INSTALLED IN ROADWAYS, PARKING LOTS, ETC
5. FOR PAVEMENT DEPTH GREATER THAN 7" USE FRAME EXTENSIONS (SEE STD PLAN NO 231) TO BRING THE COVER UP TO THE LEVEL OF THE FINISHED PAVEMENT WITHOUT EMBEDDING THE BOTTOM FLANGE OF THE CASTING IN THE PAVEMENT
6. A 4' LENGTH OF #8 THWN OR THHN COPPER WIRE SHALL BE SECURED FROM THE HANDHOLE LID TO THE FRAME. WITH A 4'-0" LENGTH FROM FRAME THAT CAN BE HOOKED UP TO A GROUND ROD
7. BUNDLE CABLE IN HANDHOLES TO PROVIDE ORDERLY GROUPING OF CABLES
8. ALL HANDHOLE LIDS AND FRAMES SHALL HAVE A NON-SKID SURFACE (SEE STD SPEC SEC 9-34.6)
9. CONDUIT ELBOWS OR SWEEPS INTO HANDHOLE SHALL BE DETERMINED IN THE FIELD BY THE ENGINEER.





## HANDHOLE INSTALLATION DETAIL



## TYPE 5 HANDHOLE



## TYPE 1&amp;2 HANDHOLE

TYPE 3 HANDHOLE  
(COVER SAME AS TYPE 5)TYPE 4 HANDHOLE  
TRAFFIC BEARING

REF STD SPEC SEC 8-33



City of Seattle

NOT TO SCALE

HANDHOLES

SPRING ASSISTED GALVANIZED  
PLATE COVER  
W/ LOCKING LATCH  
W/ NON-SKID SURFACE  
W/O PENTAHEAD BOLT

1  $\frac{1}{2}$ " DIA LIFT HOLES,  
1 EACH SIDE

GALVANIZED "C" CHANNEL,  
2' LONG, 1 EACH SIDE

(2) 2  $\frac{1}{2}$ " DIA GROUND  
ROD KNOCKOUTS


KNOCKOUT ALL SIDES  
(SEE KNOCKOUT DETAIL)

GALVANIZED PULLING IRON,  
1 EACH SIDE


6" DIA DRAIN HOLE

(4)  $4\frac{3}{4}$ " DIA KNOCKOUT,  
ALL SIDES

6" MIN MINERAL  
AGGREGATE TYPE 9



TYPE 6 HANDHOLE



REF STD SPEC SEC 8-33



City of Seattle

NOT TO SCALE

HANDHOLES




# STANDARD PLAN NO 560

REV DATE: 2003


POLES SHALL BE MARKED (BRANDED) BY MANUFACTURER WITH THE FOLLOWING INFORMATION:

1. CLASS
2. LENGTH
3. MANUFACTURER
4. TYPE OF PRESERVATIVE

LENGTH OF POLE	"H"
20'-0" & 25'-0"	5'-0"
30'-0"	5'-6"
35'-0" & 40'-0"	6'-0"




WOOD POLE DOWN & SIDEWALK GUY



PLAN

POLE TOE SHALL CONSIST OF BUILDING BLOCKS, BROKEN CONCRETE OR STONES LAYERED WITH SAND AND GRAVEL. THE LAYERS SHALL BE WELL TAMPED SO THE VOIDS ARE FILLED SOLIDLY WITH SAND AND GRAVEL.

WOOD POLE KEYING STANDARD



ELEVATION


REF STD SPEC SEC 8-32 AND SCL CONSTRUCTION GUIDELINES D6-4



City of Seattle

NOT TO SCALE

WOOD STRAIN POLES

**NOTES:**

- POLE AND MAST ARM DESIGN SHALL CONFORM TO "AASHTO STANDARD SPECIFICATIONS FOR STRUCTURAL SUPPORTS FOR HIGHWAY SIGNS, LUMINAIRES, AND TRAFFIC SIGNALS" (1994 EDITION) AND EE1-TDJ 135 AND 139.
- EACH SIGNAL COUPLING LOCATION SHALL SUPPORT THE FOLLOWING:  
FOR 3 SECTION SIGNAL HEAD - WIND LOAD AREA = 9 SF  
DESIGN WEIGHT = 60 LBS.  
FOR 4 SECTION SIGNAL HEAD - WIND LOAD AREA = 12 SF  
DESIGN WEIGHT = 80 LBS.
- THE POLE SHALL BE DESIGNED FOR A LUMINAIRE MOUNTED AT A NOMINAL 35' MOUNTING HEIGHT WITH A WIND LOAD AREA OF 3.2 SF AND A DESIGN WEIGHT OF 75 LBS. ANY PROPOSED SIGN SHALL BE ACCOMMODATED IN THE POLE DESIGN PER DRAWINGS. FOR LUMINAIRE ARM DESIGN, SEE STANDARD PLAN NO 572. MAST ARM AND LUMINAIRE ARM FLANGE PLATES SHALL HAVE ASTM A325 BOLTS W/LOCK WASHERS.
- POLE SHAFT AND MAST ARM SHALL BE FABRICATED FROM THE FOLLOWING: ASTM A572 GRADE 50, 60 OR 65 OR ASTM A595 GRADE A OR B.
- ALL PLATES & HANDHOLE REINFORCING RIM SHALL FABRICATED FROM ASTM A36



REF STD SPEC SEC 8-32



City of Seattle

NOT TO SCALE



STEEL MAST ARM POLE




### POLE FOUNDATION NOTES

1. CONCRETE STRENGTH SHALL BE CLASS AX AIR ENTRAINED.
2. ANCHOR BOLTS SHALL HAVE  $F_y = 55$  KSI MIN, NUTS: ASTM A563 HEAVY HEX GRADE DH. HARDENED STEEL WASHERS: ASTM F436.
3. BOTTOM ANCHOR PLATE: ASTM A36. HOT DIP GALVANIZED.
4. ALL REINFORCING BARS SHALL BE DEFORMED BILLET STEEL CONFORMING TO ASTM CLASS A615, GRADE 60.
5. ANCHOR BOLTS SHALL BE HOT DIP GALVANIZED ASTM A153 INCLUDING NUTS & WASHERS (FULL LENGTH) WITH A MINIMUM OF 18" OF THREADS ON TOP & 12" ON BOTTOM.
6. LATERAL BEARING IS BASED ON THE SOIL CLASSIFICATION USED IN THE 1997 UNIFORM BUILDING CODE UNDER TABLE 18-I-A.
7. TAPE THE TOP OF ANCHOR BOLTS WITH CORROSION PROTECTION TAPE PER STD SPEC SEC 8-32.3(2)A PRIOR TO POURING CONCRETE.
8. SEE STD PLAN NO 541A FOR FOUNDATION DETAILS.

MAST ARM SCHEDULE			POLE SCHEDULE		
MAST ARM LENGTH	FLANGE PLATE		POLE BASE PLATE		
	BOLT CIRCLE "B"	THREADED BOLT DIA	SIZE	BOLT CIRCLE "A"	BOLT HOLE
15'-0" TO 30'-0"	11"	1" -8NC	1 1/2" X 16" X 16"	14 1/2"	1 13/16"
31'-0" TO 40'-0"	12"	1 1/4" -7NC	1 3/4" X 18" X 18"	16 1/2"	2 1/16"
41'-0" TO 45'-0"	13 1/8"	1 1/4" -7NC	1 3/4" X 18" X 18"	18"	2 1/16"
46'-0" TO 60'-0"	14"	1 1/2" -6NC	2" X 20" X 20"	20"	2 5/16"



ANCHOR PLATE  
PER FOUNDATION SCHEDULE



INCLINED CONDITION

FOUNDATION SCHEDULE										
MAST ARM LENGTH	FOUNDATION DEPTH (LATERAL BEARING)		ANCHOR BOLTS (FY=55 KSI MIN.)			VERTICAL REINFORCING	ANCHOR PLATE DIMENSIONS			
	150/SF/FT	100#/SF/FT	PROJECTION	BOLT CIRCLE DIA	SIZE (J HOOK)		SIZE	BOLT CIRCLE DIA	BOLT HOLE	CENTER HOLE
15'-30'	7'-6"	8'-0"	7½"	14½"	1½" X 54" X 6"	8 #7	—	—	—	—
31'-40'	8'-6"	9'-6"	9"	16½"	1¾" X 60" X 6"	8 #8	⅜" X 16" X 16"	16½"	1⅞"	1⅝"
41'-45'	8'-6"	9'-6"	9"	18"	1¾" X 60" X 6"	8 #8	⅜" X 16" X 16"	18"	1⅞"	1⅝"
46'-60'	10'-6"	12'-6"	10"	20"	2" X 60" X 6"	12 #8	⅜" X 18" X 18"	20"	2⅞"	14"



REF STD SPEC SEC 8-32




City of Seattle

NOT TO SCALE



STEEL MAST ARM POLE  
FOUNDATION SCHEDULE & DETAIL  
(W/O METRO TROLLEY LOADS)



NOTE:  
GROUT SHALL BE PREMIXED,  
NON-SHRINK AND NON-METALLIC



POLE MOUNTING & GROUT DETAIL  
(EXCEPT FOR POLES W/ CHIEF SEATTLE BASE)



SECTION C-C  
STRUCTURAL CARBON STEEL  
PLATES SHALL BE ASTM A36


REF STD SPEC SEC 8-32




City of Seattle

NOT TO SCALE

MISCELLANEOUS STEEL  
POLE DETAILS




CABLE OUTLET DETAIL



FESTOON OUTLET BOX

- NOTES:
1. ALL OUTLETS SHALL BE PLUGGED WITH THREADED INSERT PLUGS DURING SHIPMENT TO PREVENT DAMAGE TO THREADS
  2. REMOVE BURRS AND SHARP EDGES TO PREVENT DAMAGE TO ELECTRICAL CABLE
  3. SPLIT COUPLING SHALL EXTEND INTO THE POLE 1/2" MAX AS SHOWN



FESTOON OUTLET DETAIL  
(METAL POLES)


REF STD SPEC SEC 8-30 & 8-32




City of Seattle

NOT TO SCALE


MISCELLANEOUS STEEL  
POLE DETAILS




POLE BASE PLATE WELD DETAIL



STRAIN POLE



POLE BASE PLATE



POLE BASE DETAIL

REF STD SPEC SEC 8-32



City of Seattle

NOT TO SCALE

COMBINED USE METRO STRAIN  
POLE DETAILS (TYPE V, X & Z POLES)

POLE TYPE	DEAD LOAD MOMENT KIP-FT (AT GROUND LINE)	POLE SCHEDULE						
		GROUND LINE DIA. "A"		POLE BASE PLATE SIZE		BOLT CIRCLE DIA. "B"	BOLT HOLE	ANCHOR BOLTS
		STD	CSB	STD	CSB			
V	51	12"	12"	1 $\frac{3}{4}$ " X 18" X 18"	1 $\frac{3}{4}$ " X 23" X 23"	18'	2 $\frac{1}{16}$ "	1 $\frac{3}{4}$ " DIA. X 72"
X	93	14"	12" $\frac{1}{2}$ "	2" X 20" X 20"	2" X 23" X 23"	20"	2 $\frac{5}{16}$ "	2" DIA. X 72"
Z	164	15"	—	2 $\frac{1}{2}$ " X 23" X 23"	—	22"	2 $\frac{1}{16}$ "	2 $\frac{1}{2}$ " DIA. X 72"

### POLE NOTES

1. THE YIELD MOMENT SHALL BE 2X THE DEAD LOAD MOMENT. THE ULTIMATE PLASTIC MOMENT SHALL BE 2.5 X THE DEAD LOAD MOMENT.
2. POLE SHAFT AND REINFORCING SLEEVE. ASTM A 572 GRADE 50, 60 OR 65 (Fy = 50, 60 OR 65 KSI RESPECTIVELY), OR ASTM A 595 GRADE A OR B (Fy = 55 OR 60 KSI RESPECTIVELY).
3. BASE PLATE AND HANDHOLE REINFORCING RIM: ASTM A 36 OR ASTM A 572 GRADE 42. BASE PLATE Fy  $\geq$  0.65 POLE SHAFT Fy. THE BASE PLATE THICKNESS MAY BE REDUCED BY  $\frac{1}{4}$ " IF ASTM A 572 GRADE 42 STEEL IS USED.
4. REINFORCING SLEEVE SHALL BE FABRICATED FROM THE SAME MATERIAL TYPE AND YIELD STRENGTH AS THE POLE SHAFT.
5. POLE SHAFTS SHALL HAVE NO MORE THAN TWO LONGITUDINAL WELDS IN EACH PLY.
6. MINIMUM SHAFT WALL THICKNESS OF EACH PLY SHALL BE 0.239" (3 GAUGE). POLE SHALL HAVE A MAXIMUM OF TWO PLYS NOT INCLUDING THE  $\frac{1}{4}$ " REINFORCING SLEEVE.
7. MAXIMUM SILICON CONTENT IN STEEL SHALL BE 0.04%. SEE STD SPEC SECTION 9-33.1(3) FOR GENERAL GALVANIZING REQUIREMENTS.
8. POLE DIAMETER FOR 12 OR MORE SIDED POLES SHALL BE MEASURED FROM THE FLAT TO FLAT DIMENSION.
9. POLES SHALL MEET DEFLECTION CRITERIA STATED IN STD SPEC SECTION 9-33.2(2) WITH THE DEAD LOAD APPLIED AT 25' ABOVE GROUNDLINE.
10. POLE STRENGTH SHALL MEET REQUIREMENTS OF AASHTO STANDARD SPECIFICATIONS FOR STRUCTURAL SUPPORTS FOR HIGHWAY SIGNS, LUMINAIRES AND TRAFFIC SIGNALS (1994 EDITION).


REF STD SPEC SEC 8-32



City of Seattle

NOT TO SCALE

COMBINED USE METRO  
STRAIN POLE  
DETAILS (TYPE V,X,Z POLES)



REF STD SPEC SEC 8-32



City of Seattle


NOT TO SCALE

TYPE T STRAIN POLE DETAILS  
TRAFFIC SIGNAL ONLY



## POLE NOTES

1. THE DEAD LOAD MOMENT AT THE GROUNDLINE SHALL BE 40 KIP-FT. THE YIELD MOMENT SHALL BE 2X DEAD LOAD MOMENT.
2. POLE STRENGTH SHALL MEET REQUIREMENTS OF AASHTO STANDARD SPECIFICATIONS FOR STRUCTURAL SUPPORTS FOR HIGHWAY SIGNS, LUMINAIRES AND TRAFFIC SIGNALS. (1994 EDITION)
3. POLE SHAFT: ASTM A 572 GRADE 50, 60, OR 65 ( $F_y=50, 60, \text{OR } 65 \text{ KSI}$  RESPECTIVELY), OR ASTM A 595 GRADE A OR B ( $F_y=55 \text{ OR } 60 \text{ KSI}$  RESPECTIVELY).
4. POLE BASE PLATE AND HANDHOLE REINFORCING RIM: ASTM A 36 OR ASTM A 572 GRADE 42. BASE PLATE  $F_y \geq 0.65$  POLE SHAFT  $F_y$ . THE BASE PLATE THICKNESS MAY BE REDUCED BY  $1/4"$  IF ASTM A 572 GRADE 42 STEEL IS USED.
5. POLE SHAFTS SHALL HAVE NO MORE THAN 2 LONGITUDINAL WELDS IN EACH PLY.
6. MINIMUM SHAFT WALL THICKNESS OF EACH PLY SHALL BE  $0.239"$  (3 GAUGE). THE POLE SHALL HAVE A MAXIMUM OF 2 PLYS.
7. MAXIMUM SILICON CONTENT IN STEEL SHALL BE 0.04%. SEE STD SPEC SEC 9-33.1(3) FOR GENERAL GALVANIZING REQUIREMENTS.
8. POLE DIAMETER FOR 12 OR MORE SIDED POLES SHALL BE MEASURED FROM THE FLAT TO FLAT DIMENSION.
9. POLES SHALL MEET DEFLECTION CRITERIA STATED IN THE STD SPEC SEC 9-33.2(2) WITH THE DEAD LOAD APPLIED AT 27' ABOVE GROUNDLINE.
10. THE POLES SHALL BE COMPACT AND MUST MEET REQUIREMENTS IN AASHTO SECTION 4, TABLE 1.4 1B (1).



STRAIN POLE BASE


REF STD SPEC SEC 8-32



City of Seattle

NOT TO SCALE

TYPE T  
STRAIN POLE DETAILS  
TRAFFIC SIGNAL ONLY



ADJUSTABLE 4-WAY BAND

REF STD SPEC SEC 8-31




City of Seattle

NOT TO SCALE

POLE BAND

## REV DATE: 2005



1° TO 4°  
UNDER  
LOAD

NOM SPAN

BEND RADIUS

0.14" / FT TAPER

23/16"

"H"

26°

MAX

1/4"

NOTE: BEVEL TUBE AS NECESSARY  
FOR FLUSH WELD

SEE LUMINAIRE  
ARM FLANGE  
PLATE DETAIL 2

## STEEL STREET LIGHT POLE



MATERIAL SPECIFICATION	
PLATE AND SHAPES	ASTM A 36
POLE SHAFTS	ASTM A 570 GR 40 MIN.
ANCHOR BOLTS	ASTM A 307
ARM FLANGE PLATE BOLT	ASTM A 325

REF STD SPEC SEC 8-32




NOT TO SCALE

## STEEL STREET LIGHT POLE WITH BRACKET ARM

# STANDARD PLAN NO 580

REV DATE: 2003



## CONDUIT RISER (WITH STAND-OFF BRACKET\*)

\*WHEN THERE WILL BE ONLY ONE CONDUIT (1 1/2" OR SMALLER) ON THE POLE, ONE HOLE MALLEABLE IRON CLAMPS WITH 4" LAG SCREWS SHALL BE USED TO SECURE THE CONDUIT TO THE POLE IN LIEU OF THE STAND-OFF BRACKETS

### NOTES:

1. ON POLES WITH EXISTING CONDUITS, NEW CONDUITS SHALL BE INSTALLED IN ACCORDANCE WITH THIS STANDARD PLAN.
2. RIGID STEEL CONDUIT SHALL BE GROUNDED JUST BELOW COUPLING, APPROXIMATELY 8'-0" TO 10'-0" ABOVE GROUND, AS SHOWN
3. WHEN 2 OR MORE RIGID STEEL CONDUITS ARE INSTALLED ON ONE POLE, ONE CONDUIT SHALL BE GROUNDED AS SHOWN. THE CONDUIT SUPPORTS & STRAPS SHALL SERVE AS A BONDING DEVICE BETWEEN THE STEEL CONDUITS
4. THE GROUND WIRE SHALL BE ONE CONTINUOUS LENGTH. INSERT THE GROUND WIRE FORM THE BOTTOM OF THE GROUND CLAMP & BEND OVER THE CLAMP BEFORE TIGHTENING
5. PLACE GROUND WIRE IN QUADRANT BETWEEN POLE FACE & SECONDARY NEUTRAL
6. ALL STEEL HARDWARE SHALL BE HOT DIPPED GALVANIZED AFTER FABRICATION PER ASTM A123
7. CONDUIT CLAMP SPACING SHALL BE PER THE NEC WITH A MINIMUM OF TWO HOLE CLAMP PER 10'-0" LENGTH OF CONDUIT




REF STD SPEC SEC 8-33, SCL CONSTRUCTION GUIDELINES U 7-10



City of Seattle

NOT TO SCALE

CONDUIT RISER

**NOTES:**

1. ALL STEEL HARDWARE TO BE HOT DIP GALVANIZED OR STAINLESS STEEL UNLESS OTHERWISE STIPULATED IN THE DRAWINGS
2. SPAN WIRE SHALL BE ALUMINUM COATED STEEL
3. SPREAD THIMBLE TO FIT THE BAIL OF THE AUTOMATIC DEAD END





REF STD SPEC SEC 8-21 &amp; SCL MATERIAL STANDARD 6901.1



City of Seattle

NOT TO SCALE

SPAN WIRE INSTALLATION



## NOTES

1. ALL HARDWARE SHALL BE STAINLESS STEEL. OTHER THAN HARDWARE SHALL BE HOT DIP GALVANIZED.
2. NEOPRENE GASKETS SHALL NOT BE USED FOR SPAN WIRE OR AERIAL CONNECTIONS.



REF STD SPEC SEC 8-21




City of Seattle

NOT TO SCALE

OVERHEAD WOOD SIGNS  
SPANWIRE MOUNTED



SIGN MOUNTING ON MAST ARM



- NOTES:
1. EXCEPT AS NOTED OTHERWISE, ALL HARDWARE SHALL BE STAINLESS STEEL.
  2. MOUNTING OF TRAFFIC SIGNS SHALL BE AS FOLLOWS:  
ON METAL POLE THINNER THAN 7 GAUGE, USE 3/8" STAINLESS STEEL RIVNUTS ON METAL POLES 7 GAUGE OR THICKER, DRILL AND TAP FOR 3/8" BOLT (STAINLESS STEEL RIVNUT OPTIONAL) ON POLES FILLED WITH OR MADE FROM CONCRETE, USE 3/8" X2 1/2" MIN STUD BOLT ANCHORS WITH HEX NUT
  3. FOR SIGN FEATURE, CONTACT TRAFFIC ENGINEER

TEMPORARY SIGN MOUNTING ON METAL POLE

REF STD SPEC SEC 8-21




City of Seattle

NOT TO SCALE

SIGN INSTALLATION  
(NON-SPANWIRE MOUNTING)

STANDARD PLAN NO 610

REV DATE: 2003



REF STD SPEC SEC 8-21




City of Seattle



NOT TO SCALE

STANDARD SIGN INSTALLATION  
STEEL POLES





NOTE  
ALL HARDWARE SHALL BE  
STAINLESS STEEL.



REF STD SPEC SEC 8-21




City of Seattle


NOT TO SCALE

SDS BRACKET FOR STEEL  
MAST ARM POLES

## REV DATE: 2003





## SDS BRACKET FOR STEEL OR WOOD POLES




## NOTES:

1. STAGGER SNS BLADES WITH THE "AVENUE" DESIGNATION BLADE BELOW THE "STREET" DESIGNATION BLADE
2. SNS SHALL BE INSTALLED PARALLEL TO CORRESPONDING STREET
3. ALL NUTS, BOLTS & WASHERS TO BE STAINLESS STEEL EXCEPT ALUMINUM RIV NUTS ON ALUMINUM POLES.



ON ALUMINUM POLES USE 5/16" ALUMINUM RIVNUTS  
FOR STEEL POLES LESS THAN SEVEN (7) GAUGE USE  
5/16" STAINLESS STEEL RIVNUTS  
(RIVNUTS OPTIONAL ON HEAVIER GAUGE STEEL POLES)



REF STD SPEC SEC 8-21







City of Seattle

NOT TO SCALE

SNS BRACKET FOR  
STEEL POLES

# STANDARD PLAN NO 616

REV DATE: 2003



## NOTES:

1. FOR STEEL POLES LESS THEN SEVEN (7) GAUGE USE 5/16" STAINLESS STEEL RIVNUTS. STAINLESS STEEL RIVNUTS OPTIONAL ON HEAVIER GAUGE STEEL POLES
2. ON ALUMINUM POLES USE 5/16" ALUMINUM RIVNUTS
3. ON POLES FILLED WITH OR MADE FROM CONCRETE USE 5/16" X 2 1/2" MIN STUD BOLT ANCHORS WITH HEX NUT
4. FOR SIGNS OVER 2'-6" X 3'-6" USE STD PLAN NO 612. MOUNT SIGNS VERTICALLY ON STRAIN POLE WITH THREE (3) FASTENERS MIN
5. FOR DARK COLORED POLES PAINT BAND TO MATCH POLE
6. ALL HARDWARE TO BE STAINLESS STEEL.


REF STD SPEC SEC 8-21



City of Seattle

NOT TO SCALE

TRAFFIC SIGN MOUNTING  
ON METAL POLES

NOTES:

1. 5/16" X 3 1/4" GALVANIZED OR PLATED LAG SCREW & 3/8" ID X 1" OD NYLON WASHER
2. INSTALL 30D GALV COMMON SPIKE ON THE FACE SIDE OF POST EXCEPT WHEN CONCRETE PAVING EXISTS. SPIKE SHALL BE 8" ABOVE BOTTOM OF POST AND SHALL PROTRUDE 2" FROM POST
3. CONTACT SEATTLE TRANSPORTATION (684-5087) FOR DETAILS REGARDING SIGN MESSAGE AND FOUNDATION
4. SIGN POST MATERIAL SHALL BE STANDARD GRADE WESTERN RED CEDAR



REF STD SPEC SEC 8-21



City of Seattle

NOT TO SCALE

STOP AND YIELD SIGN  
WOOD POST AND  
ANCHOR INSTALLATION




REF STD SPEC SEC 8-21




City of Seattle

NOT TO SCALE


WARNING AND REGULATORY  
SIGN POST




SURFACE MOUNT



NOTE: FOR UNEVEL SIDEWALKS INSERT WASHERS AS SPACERS BETWEEN PLATE AND SIDEWALK. GROUT ALL SPACE AS SHOWN. IF BOLT CANNOT PENETRATE SIDEWALK AT LEAST 2", CONTACT THE ENGINEER.



LIGHT DUTY ANCHOR



HEAVY DUTY ANCHOR


REF STD SPEC SEC 8-21



City of Seattle

NOT TO SCALE

WARNING AND REGULATORY  
SIGN POST ANCHOR INSTALLATIONS



REF STD SPEC SEC 8-21




City of Seattle

NOT TO SCALE

STREET NAME SIGN  
INSTALLATION






REF STD SPEC SEC 8-21



City of Seattle

NOT TO SCALE

STREET NAME SIGN  
PEDESTAL INSTALLATION



- NOTES:
- 1. CAP SHALL BE MADE OF THE SAME MATERIAL AS THE SURROUNDING PAVED SURFACE AND SHALL BE MOUNDED FOR DRAINAGE AWAY FROM POST
  - 2. BLOCKOUTS SHALL BE PROVIDED FOR POST LOCATIONS WHERE NEW CONCRETE PAVEMENT (SIDEWALK, ROADWAY, ETC) IS BEING INSTALLED
  - 3. WHERE POST IS BEING INSTALLED IN EXISTING PAVED AREAS, HOLE IN PAVED SURFACE SHALL NOT EXCEED 1'-0" NOMINAL DIAMETER


REF STD SPEC SEC 8-21



City of Seattle

NOT TO SCALE

POST CAP



QWIK PUNCH TELES PAR STANDARD SIGN POST  
(TS-5, TS-10, TS-12)

WOOD STOP & YIELD SIGN POST  
(P4-12S, P4-12Y)

NOTES:

1. FOR "STOP" SIGN, PAINT STRIPES ON ALL FOUR SIDES.
2. FOR "YIELD" SIGN, PAINT STRIPES ONLY ON SIDE FACING TRAFFIC.
3. SEE STD PLAN NO 620
4. "STOP" AND "YIELD" SIGN POST MATERIAL SHALL BE STANDARD GRADE WESTERN RED CEDAR


REF STD SPEC SEC 8-21



City of Seattle

NOT TO SCALE

TRAFFIC SIGN POSTS

**NOTES:**

1. IN THE CASE WHERE ALL APPROACHES OF THE INTERSECTION ARE PRIMARILY AT THE SAME LEVEL WITH RESPECT TO GRADES (LESS THAN 3%) THE LOWER SET OF SIGNS SHALL FACE THE HIGHER TRAFFIC VOLUME STREET
2. IN THE CASE WHERE AN APPROACH HAS A GRADE LARGER THAN 3% THE HIGHER SIGNS WILL FACE THE STEEPEST APPROACH TO ALLOW BETTER SIGHT DISTANCE
3. PLACE A MINIMUM OF THREE (3) REFLECTORS ON EACH AND EVERY SIDE OF POST OR PLACE THREE (3) HIGH INTENSITY REFLECTORIZED STRIPS COMPLETELY AROUND POST

REF STD SPEC SEC 8-21




City of Seattle

NOT TO SCALE


OBJECT MARKER INSTALLATION

# STANDARD PLAN NO 627

REV DATE: 2003





**METER POST CAP**  
(TO BE USED W/ SIGN INSTALLATION)



**METER POST**


PRIME WITH "RUSTOLEUM" OR APPROVED EQUAL AND  
PAINT WITH TWO (2) COATS OF ALUMINUM



**METER POST BASE CANOPY**  
MATERIAL: 0.062' 2-5-0 ALUM

CUT OFF  
SQUARE PLAIN  
END - REAM

2" NOM DIA  
ASTM A 53  
SCHD 40  
GALV STD.  
STEEL  
PIPE



**SECTION A-A**


REF STD SPEC SEC 8-21



City of Seattle

NOT TO SCALE

**PARKING METER POST &  
ACCESSORIES**



REF STD SPEC SEC 8-21




City of Seattle

NOT TO SCALE

SURFACE MOUNT METER  
POST INSTALLATION DETAIL

# STANDARD PLAN NO 629

REV DATE: 2003



## NOTES:

1. POST TO BE PLUMB
2. NOTIFY SEATTLE TRANSPORTATION (684-5087) FOR REMOVAL OF EXISTING POSTS
3. WHEN NEW POSTS HAVE BEEN SET, NOTIFY SEATRAN TO REINSTALL METERS
4. A 2 1/2" NOM DIA ASTM A 53 GALV STD STEEL PIPE SHALL BE FITTED OVER THE 2" PIPE FULL LENGTH. ENDS OF SLEEVE PIPE TO BE GROUND SMOOTH AND FREE OF BURRS

REF STD SPEC SEC 8-21



City of Seattle

NOT TO SCALE


DIRECT BURIAL METER POST  
INSTALLATION DETAIL

# STANDARD PLAN NO 630


REV DATE: 2005

## NOTES:


1. POST ANCHOR RIVETS SHALL BE 1 1/2" ABOVE GROUND LEVEL
2. ATTACHMENT BRACKETS SHALL FACE AWAY FROM STREET AS WHEN POST IS LOCATED 3'-0" FROM EDGE OF CURB. ATTACHMENT BRACKETS SHALL FACE TOWARDS STREET (TS) WHEN POST IS LOCATED AT BACK SIDE OF SIDEWALK
3. FOR POST RELOCATIONS, OLD CONCRETE SHALL BE REMOVED FROM POST
4. ALL SIGNS, STRUCTURES AND HARDWARE PROVIDED BY METRO EXCEPT WHERE NOTED OTHERWISE ON THIS STD PLAN.
5. WHERE SURFACE MOUNTED BUS ZONE SIGNS ARE REQUIRED ON SLOPED SIDEWALK, THE CONTRACTOR SHALL PLUMB THE POST BY BUILDING A NON-SHRINK GROUT PAD UNDER PEDESTAL ASSEMBLY WITH SMOOTH 1H TO 1V TAPER ON THE GROUT EDGE. THE BOLT ANCHOR LENGTH SHALL BE ADJUSTED TO PROVIDE A MIN 3 1/2 INCH EMBEDMENT THROUGH THE GROUT INTO THE EXISTING CONCRETE.




DIRECT BURIAL INSTALLATION



SIGN LOCATION DETAIL



POST ANCHOR DETAIL



SURFACE MOUNT INSTALLATION

REF STD SPEC SEC 8-21




City of Seattle

NOT TO SCALE

METRO BUS ZONE SIGN  
INSTALLATION





$a = 5/8" \pm 1/8"$   
 $b = 1/8" \pm 1/16"$





LANE MARKER-TYPE 1

▲ DIRECTION OF TRAFFIC



SECTION B-B

LANE MARKER-TYPE 2A  
4" PRISMATIC REFLECTIVE MARKER



SECTION C-C

LANE MARKER-TYPE 2B


REF STD SPEC SEC 9-21



City of Seattle

NOT TO SCALE

TRAFFIC BUTTONS  
& LANE MARKERS



#### TYPICAL TYPE 1 TRAFFIC BUTTON (4") INSTALLATION DETAILS

TRAFFIC BUTTONS SHALL BE INSTALLED TO CONFORM WITH TYPE OF PAVEMENT MARKING (DESIGNATED AS L-1, L-4, L-5, ETC) AND ARE TO BE ARRANGED AND SPACED AS SHOWN ON THIS DRAWING. COLOR OF TRAFFIC BUTTONS IS TO MATCH COLOR OR PAVEMENT MARKINGS. TRAFFIC BUTTONS SHALL BE INSTALLED PRIOR TO ANY PAINT LINE INSTALLATION, EXISTING CHANNELIZATION IN CONFLICT WITH NEW OR REVISED CHANNELIZATION SHALL BE REMOVED (SEE STD SPEC SEC 2-02.3(3)J)


REF STD SPEC SEC 8-08



City of Seattle


NOT TO SCALE

CHANNELIZATION STANDARD

TYPICAL LEFT TURN CHANNELIZATION


NUMBER OF LEGEND SETS REQUIRED BASED ON THE LENGTH OF APPROACH LINES

APPROACH LINE LENGTH	LEGEND SETS
LESS THAN 50 FEET	1 SET AT X-WALK END OF POCKET
50 FEET-120 FEET	2 SETS
125 FEET-300 FEET	3 SETS (SECOND LEGEND LOCATED MIDWAY BETWEEN FIRST AND LAST LEGENDS)
OVER 300 FEET	ADDITIONAL SETS SPACED AT APPROX 100 FT INTERVALS BETWEEN FIRST AND LAST SETS

TYPICAL TWO WAY LEFT TURN LANES

NUMBER OF LEGEND SETS REQUIRED BASED ON THE LENGTH OF TYPICAL TWO WAY LEFT TURN LANES

LANE LENGTH	LEGEND SETS
LESS THAN 50 FEET	1 SET (CENTERED BETWEEN BOTH ENDS OF LANE)
0 FEET-300 FEET	2 SETS
OVER 300 FEET	3 SETS (SECOND LEGEND LOCATED MIDWAY BETWEEN FIRST AND LAST LEGENDS)
	ADDITIONAL SETS SPACED AT APPROX 300 FT INTERVALS

LEGEND PLACEMENT

LEGENDS IN ADJACENT LANES SHALL BE ALIGNED AS SHOWN

LEGENDS SHALL BE CENTERED WITHIN THE LANE TO WHICH THEY APPLY, AS SHOWN

LEGEND COMBINATIONS

OBLIQUE LEFT & 90° LEFT LEGENDS AND OBLIQUE RIGHT & 90° RIGHT LEGENDS MAY BE COMBINED AS SHOWN


REF STD SPEC SEC 8-22




City of Seattle

NOT TO SCALE

TYPICAL LEFT TURN  
CHANNELIZATION AND LEGEND  
PLACEMENT



TYPICAL PEDESTRIAN  
CROSSWALKS & STOP LINES



TYPICAL LADDER  
PEDESTRIAN CROSSWALKS

\* WHERE TRAFFIC LANE LINES ARE NOT USED, LADDER BARS SHALL BE 5'-0" CENTER TO CENTER, BEGINNING AT THE MARKED CENTERLINE OF THE ROADWAY

#### NOTES:

1. EXACT LOCATION OF CROSSWALK LINES AND STOP LINES SHALL BE DESIGNATED BY SEATTLE DEPARTMENT OF TRANSPORTATION
2. EXISTING CROSSWALKS IN CONFLICT WITH NEW OR REVISED CROSSWALKS SHALL BE REMOVED BY MACHINE GRINDING


REF STD SPEC SEC 8-22




City of Seattle

NOT TO SCALE

TYPICAL CROSSWALK & STOP  
LINE INSTALLATION DETAILS




L-10  
PASSENGER LOAD ZONE, ETC  
(WHITE)




L-11  
TOW-AWAY ZONE  
(RED)



L-12  
COMMERCIAL LOAD, TRUCK LOAD, LOAD & UNLOAD ZONE, ETC  
(YELLOW)



L-13  
BUS ZONE (NON PARKING METERED AREAS)  
BUS ZONES ARE PAINTED ON TOP & FACE OF CURB



L-13  
BUS ZONE (PARKING METERED AREAS)  
BUS ZONES ARE PAINTED ON TOP & FACE OF CURB

- NOTES:**
1. TOTAL LENGTH OF CURB MARKINGS SHALL BE AS SHOWN ON DRAWINGS
  2. PAINT SHALL BE APPLIED NEATLY ON THE CURB AND ALL PAINT SMEARS ON ADJACENT SURFACES SHALL BE REMOVED





REF STD SPEC SEC 8-22



City of Seattle

NOT TO SCALE

CURB SPACE  
MARKING DETAILS




REF STD SPEC SEC 8-22



City of Seattle


NOT TO SCALE

PAVEMENT MARKINGS  
LEGENDS/SYMBOLS




L-17, L-17T  
LEFT & RIGHT ARROWS


NOTE:  
"T" = THERMOPLASTIC



L-22, L-22T  
THROUGH ARROW



L-23  
LEFT & THROUGH ARROWS



L-24  
RIGHT & THROUGH ARROWS


REF STD SPEC SEC 8-22




City of Seattle

NOT TO SCALE


PAVEMENT MARKINGS  
LEGENDS/SYMBOLS




L-25, L-25T  
"ONLY" LEGEND



L-26, L-26T  
"OK" LEGEND



L-29, L-29T  
DISABLED PERSON SYMBOL



L-35, L-35T  
"SCHOOL" LEGEND

REF STD SPEC SEC 8-22

NOTE:  
"T" = THERMOPLASTIC



City of Seattle



NOT TO SCALE

PAVEMENT MARKINGS  
LEGENDS/SYMBOLS



NOTES:

- 1. "T" = THERMOPLASTIC
- 2. L-28AT INCLUDE BICYCLE SYMBOL AND ARROW




REF STD SPEC SEC 8-22




City of Seattle

NOT TO SCALE

BICYCLIST & PEDESTRIAN  
SYMBOLS



L-9A, L-9AT  
YIELD LINE



L-28B, L-28BT  
DENVER ARROW




City of Seattle

NOT TO SCALE

PAVEMENT MARKINGS  
LEGENDS / SYMBOLS

## REV DATE: 2003



BEVELED BLOCK FOR FORMING  
SHEAR KEY IN WALL SECTION TO  
BE MADE FROM STANDARD  
2" X4" X6" WOOD OR OTHER  
SUITABLE MATERIAL (SEE NOTE 3)

1. BASE OF SUPPORT WALL TO BE BEARING ON COMPACTED SUITABLE MATERIAL
2. BACK FORM FOR SUPPORT WALL MAY BE OMITTED AND CONCRETE PLACED AGAINST NATIVE EARTH WHEN GROUND CONDITIONS PERMIT. CLEARANCE TO REINF STEEL IN BACK FACE SHALL BE 21/2"
3. WHEN CONSTRUCTION OF ALLEY PAVEMENT IS NOT PLACED INTEGRAL WITH SUPPORT WALL, SHEAR KEYS SHALL BE INSTALLED 1'-6" ON CENTERS
4. CONCRETE FOR SUPPORT WALL SHALL BE CL 6 (11/2)
5. REINFORCING STEEL ASTM A615 GR 60
6. VEHICULAR & PEDESTRIAN RAILING PER STREET DESIGN MANUAL

SHEAR KEY

NOT TO SCALE

SUPPORT WALL

## REV DATE: 2003

