

APPENDIX 3D

Sample Notes for Water Services

I. INTRODUCTION

All notes in these sets are illustrative and require review and revision by the Engineer for each project and specific project conditions. These notes may be more appropriate on water plan sheets or on a service list sheet. **Yellow highlights indicate a note to the designer.**

2. WATER SERVICE LIST SHEETS

For water service list sheets unless otherwise noted.

1. SERVICE TRANSFERS: CONTRACTOR MUST ASSIST SPU WITH WATER SERVICE CONNECTION TRANSFERS PER STANDARD SPECIFICATION SECTION 7-15. FOR SERVICES LARGER THAN 2 INCHES, CONTRACTOR MUST SUPPLY PIPE, FITTINGS AND VALVES. FOR SERVICES 2 INCHES AND SMALLER SPU WILL PROVIDE ALL MATERIALS.
2. CONTRACTOR MUST ASSIST SPU WITH WATER SERVICE CONNECTIONS PER STANDARD SPECIFICATION SECTION 7-11.3(9)C. CONTRACTOR MUST SUPPLY AND INSTALL PIPE, FITTINGS AND VALVES FOR SERVICES GREATER THAN 2 INCHES. SPU WILL PROVIDE ALL MATERIALS FOR SERVICES 2 INCHES AND SMALLER.
3. MECHANICAL JOINT ON DIP AT EACH SYSTEM CONNECTION. THE ENGINEER MUST REVIEW FOR EACH SPECIFIC PROJECT AND DECIDE IN ADVANCE WITH CONSULTATION WITH THE LOB IF SPU CREW OR THE CONTRACTOR WILL INSTALL TEMPORARY SERVICES.

2.1 WATER SERVICE NOTES

For water service notes unless otherwise noted.

1. ALL UNDERGROUND WATER SERVICE PIPING ON PRIVATE PROPERTY MUST BE INSPECTED PRIOR TO BACKFILLING TRENCH. FOR INFORMATION AND INSPECTION, CALL 206-684-5800.
2. WATER SERVICE TRANSFERS FROM THE EXISTING MAIN TO THE NEW MAIN WILL BE MADE BY SPU WITH CONTRACTOR ASSISTANCE.
3. WATER SERVICE RELOCATIONS, AS SHOWN ON THE PLANS AND CALLED OUT ON SERVICE LIST, WILL BE MADE BY SPU WITH CONTRACTOR ASSISTANCE.
4. REPLACEMENT OF WATER METER BOXES IN DRIVING SURFACES WITH FRAMES AND COVERS HAVING INSPECTION COVERS (F&C W/IC) ARE CALLED OUT ON THE SERVICE LIST AND MUST BE PLACED BY CONTRACTOR.
5. WATER SERVICE RENEWALS, FROM NEW MAIN TO METER TAIL- RUN AND UNION CONNECTION, ARE CALLED OUT ON SERVICE LIST AND WILL BE PERFORMED BY SPU WITH CONTRACTOR ASSISTANCE.
6. WHERE THE PROPOSED WATER MAIN DESIGNED ELEVATION OR ADJUSTED ELEVATION CROSSES THROUGH THE LOCATION OF EXISTING WATER SERVICES, THE CONTRACTOR

Chapter 3 Design for Construction
Appendix 3D Sample Notes for Water Services

MUST COORDINATE WORK WITH SPU WHO WILL PROVIDE AN OFFSET IN THE SERVICE LINE AHEAD OF THE WATER MAIN WORK.

IF NEEDED, ADD THE FOLLOWING:

APPLICATION FOR NEW METERED WATER SERVICE WITH ALL FEES PAID IS REQUIRED 60 TO 90 (OR LONGER IF A WATER MAIN EXTENSION OR ADDITIONAL VALVES ARE NEEDED CHECK WITH DSO) DAYS BEFORE SERVICE WILL BE AVAILABLE. OWNER WILL NEED WATER AVAILABILITY CERTIFICATE AND LEGAL DESCRIPTION OF PROPERTY WHEN MAKING APPLICATION. SEE [HTTP://WWW.SEATTLE.GOV/UTIL/ENGINEERING/DEVELOPMENTSERVICESOFFICE/WATERSERVICE/INDEX.HTM](http://www.seattle.gov/util/engineering/developmentservicesoffice/waterservice/index.htm).