

2011 Wholesale Mechanical Meter Test Report

DISTRICT	STA #	PREM #	TESTED	2011 WO#	MANU	SIZE	PASSED/FAILED	TOP
20	23	461108	1/20/2011	2603450	NEP	6	100/100/99.8	
20	126	461419	7/6/2011	2823546	NEP	8	100/103/103	
20	127	461063	7/12/2011	2823573	NEP	6	100/100/100	
20	128	460742	7/8/2011	2823600	NEP	6	100/100/100	
20	129	461093	7/8/2011	2823627	NEP	6	100/102/102	
20	130	461061	7/7/2011	2823655	NEP	6	100/100/100	
20	132	461329	7/12/2011	2823682	NEP	8	100/100/102	
20	134	460273	7/8/2011	2823709	NEP	4	101/97/97	
20	135	460591	7/7/2011	2823736	NEP	6	102/99/100	
20	136	461422	1/20/2011	2603714	BAD	10	100/99/98	
	10			10				
45	20	461060	6/2/2011	2781984	NEP	8	100/100/100	
45	176	909301	6/1/2011	2782011	NEP	6	100/100/99	
45	184	479202	6/2/2011	2782038	NEP	6	100/100/99	
	3			3				
49	139	461052	7/19/2011	2823763	NEP	10	100/102/103	
49	142	461424	7/19/2011	2823790	NEP	8	100/99/102	
49	143	460585	1/26/2011	2603903	NEP	10	100/98/101	
	3			3				
119	116	460940	1/28/2011	2603951	NEP	4	100/97/97	
119	117	461010	1/28/2011	2603978	NEP	6	100/101/99	
	2			2				
125	8	460574	1/26/2011	2604005	NEP	6	100/101/99.6	
125	9	461335	6/3/2011	2782065	NEP	6	100/99/99	
125	10	461148	7/12/2011	2782092	NEP	8	98/97/100	
125	17	461421	6/7/2011	2782119	NEP	10	99/101/101	
125	121	461102	6/7/2011	2782146	NEP	4	100/102/100	
	5			5				
BOTHELL	95	461020	1/27/2011	2610073	NEP	10	98/99/100	
BOTHELL	96	460241	1/27/2011	2610640	NEP	8	97/99/100	
	2			2				
COAL CREEK	54	461099	6/8/2011	2782173	NEP	4	102/102/102	

2011 Wholesale Mechanical Meter Test Report

	1			1				
DUVALL	111	461012	2/9/2011	2610100	NEP	4	102/99.8/101	
	112	461023	2/9/2011	2610127	NEP	6	100/100/100	
	2			2				
HIGHLINE	42	460743	6/9/2011	2782200	NEP	16		
	2			1				
MERCER ISLAND	171	460740	6/10/2011	2782227	NEP	10	100/100/99	
	N/A	460247	6/10/2011	2782254	NEP	10	100/99/102	
	2			2				
NORTHSHORE	81	461018	1/11/2011	2610181	NEP	6	99/99.7/102	
	83	461026	8/25/2011	2870018	NEP	10	100/97.4/98.6	
	85	461024	1/13/2011	2610208	NEP	6	100/ 98.4/ 99.6	
	92	461004	1/13/2011	2610235	NEP	6	100/100/102	
	94	460246	1/11/2011	2610262	NEP	10	100/98.1/100	
	5			5				
NORTH BEND	190	971210	2/4/2011	2609992	MET	8	103/100/100	
	1			1				
RENTON	37	460281	6/8/2011	2782308	SEN (ROC)	3	100/100/100	
	38	460578	3/30/2011	2610343	NEP	6	99/103/97	
	179	460257	6/14/2011	2782350	NEP	10	100/101.5/103	
	180	460256	6/14/2011	2782377	NEP	10	100/99.7/99.3	
	4			4				
SHORELINE	103	459353	2/4/2011	2610370	NEP	6	100/101/102	
	1			1				
SOOS CREEK	27	461124	7/19/2011	2823952	NEP	10	100/100/NA	
SOOS CREEK	28	461155	7/19/2011	2782281	NEP	10	100/99/100	
SOOS CREEK	189	971209			BAD	10		
	3			2				
WOODINVILLE	53	461022	2/4/2011	2610532	NEP	8	100/98/100	
WOODINVILLE	76	461027	2/4/2011	2610586	NEP	4	102/99.4/98.6	
WOODINVILLE	77	461096	2/4/2011	2610478	NEP	6	99/99/100	
WOODINVILLE	78	461019	2/4/2011	2610559	NEP	8	100/99/99	
WOODINVILLE	80	461028	2/3/2011	2610505	NEP	8	102/100/100	

2011 Wholesale Mechanical Meter Test Report

WOODINVILLE	125	460564	2/3/2011	2610451	NEP	6	102/97/99	
WOODINVILLE	167	461097	2/2/2011	2610694	NEP	6	100/100/99	
	7			7				
TOTAL METERS	53							
BACK UP METERS - DO NOT TEST UNTIL 2014								
49	25	460590			NEP	8		
125	119	461089			NEP	6		
125	174	459141			HER	10		
125	175	459140			HER	10		
BELLEVUE	46	460239			HER	6		
CEDAR RIVER	30	461103			NEP	8		
COAL CREEK	48	461094			NEP	8		
EDMONDS	110	460571			NEP	10		
LAKE FOREST PARK	97	460303			NEP	8		
LAKE FOREST PARK	188	971083			NEP	8		
MERCER ISLAND	68	461333			NEP	6		
NORTHSHORE	89	461205	2/1/2011	2598702-A	HEX	6	99/101/99	
NORTHSHORE	90	461206			HER	6		
RENTON	33	460263			NEP	6		
RENTON	34	460581			NEP	8		
RENTON	36	460260			NEP	6		
RENTON	39	460573			NEP	10		
SKYWAY	172	460570			NEP	6		
TUKWILA	14	461149			NEP	8		
WOODINVILLE	123	461011			HER	6		
				1				
TOTAL # BACK UP METERS	20							
TURBINE METERS TO BE TESTED EVERY 3 YEARS - NEXT TEST 2013								
20	133	461330			ROC	10	TURBINE	
90	45	460274			ROC	10	TURBINE	
125	120	466490			ROC	8	TURBINE	
BELLEVUE	56	461091			SEN (ROC)	8	TURBINE	
BELLEVUE	59	461098			ROC	8	TURBINE	
BELLEVUE	63	461245	2/17/2011	2653777	ROC	10	TURBINE	

2011 Wholesale Mechanical Meter Test Report

BOTHELL	99	461029			ROC	6	TURBINE	10
HIGHLINE	43	460748			NEP	12	TURBINE	
OLY.VIEW	107	461242			ROC	8	TURBINE	7
OLY.VIEW	108	459418			ROC	8	TURBINE	22
OLY.VIEW	109	459419			ROX	8	TURBINE	1190897
SHORELINE	102	472896			ROC	10	TURBINE	10
SHORELINE	104	461207			ROX	8	TURBINE	23
SHORELINE	101	480005			ROC	10	TURBINE	12?
SOOS	29	460576			SEN (ROC)	8	TURBINE	22
SOOS	181	461441			ROC	6	TURBINE	60
				1				
TOTAL # of TURBINE METERS	16							
TOTAL # of MECHANICAL METERS	89							
EXEMPT METERS IN 2011	36							
METERS TESTED TO DATE (MECH)	67							
METERS TESTED TO DATE (TURBINE)	2							
METERS NOT TESTED IN 2011								

Not scheduled for any tests in 2011.
 Scheduled to be tested July, 2011

2011 Wholesale Mechanical Meter Test Report

August 31, 2011

2011 Wholesale Mechanical Meter Test Report

NOT A TURBINE METER

August 31, 2011

2011 Wholesale Mechanical Meter Test Report

|

August 31, 2011

2011 Wholesale Mechanical Meter Test Report

|

August 31, 2011

2011 Wholesale Mechanical Meter Test Report

August 31, 2011

2011 Wholesale Mechanical Meter Test Report

August 31, 2011

2011 Wholesale Mechanical Meter Test Report

August 31, 2011